

Sub	TENDER CHANGE NOTICE (TCN-01 DTD. 25/08/14)	
Job	Design, Manufacture, Assembly, Transport and delivery of 01 set Bunk House (consisting of 07 nos. Bunk House of various sizes as per specification) at BHEL, Namrup site ( Assam).	
Ref	TENDER NO.: PSER: PUR: PMX: 163(XI): 061	Date: 21/08/2014

A) With the following clarifications, relevant to tender, may please be noted and complied with while submitting the offer:-

Sl. no.	Description/ Clause as per NIT	Bidder's Queries	BHEL's Clarifications
01	PART-C TECHNICAL SPECIFICATION CLAUSE NO 1 <b>Container Size &amp; Handling</b>	Please clarify if only four top corner castings are required or total of 8 is required, 4 at the top and four at the bottom similar to logistic/marine container.	No change; Please refer to clause no. 1 of technical spec for handling – "The storage shell can be handled and secured at <b>eight corner fittings</b> positions by means of twist locks. The shell can be lifted empty and full at the <b>four top corner fittings</b> , vertically by means of spreaders fitted with twist locks shackles and hooks."
02	PART-C TECHNICAL SPECIFICATION CLAUSE NO 4 <b>Side &amp; End walls</b>	Please clarify if Square sections of 50x50x3.2 / 60x60x3.2 mm confirming to IS: 4963 can be used as top cant rails similar to logistic containers as it provide more rigidity to shell.	No change; As per PART-C TECHNICAL SPECIFICATION CLAUSE NO 4
03	PART-C TECHNICAL SPECIFICATION CLAUSE NO 5 <b>Roof</b>	Please clarify if roof bows made with rolled equal angle of 40 x 40 x 3.15 mm can be used in strengthening of roof and sloping for drainage of water.	No change; As per PART-C TECHNICAL SPECIFICATION CLAUSE NO 5
04	PART-C TECHNICAL SPECIFICATION CLAUSE NO 7 <b>Inner Paneling</b>	Please clarify if alternately we can use 9 mm thick Bhutan make Pre-laminated boards (IS: 12823:1990) on the side walls and 6 mm thick on ceiling which are resistant to termite and water.  ii) All wall and roof panels shall be supported by Tubular steel frames.	No change; As per PART-C TECHNICAL SPECIFICATION CLAUSE NO 7

Sl. no.	Description/ Clause as per NIT	Bidder's Queries	BHEL's Clarifications
05	PART-C TECHNICAL SPECIFICATION CLAUSE NO 8 <b>Insulation</b>	Please clarify if 50 mm thick glass wool of 32Kg/Sq. Mtr. density can be used between outside steel panel and inside wooden panel on side wall and Ceiling as an insulation material in place of 50 & 30 mm of PUF.	No change; As per PART-C TECHNICAL SPECIFICATION CLAUSE NO 8
06	PART-C TECHNICAL SPECIFICATION CLAUSE NO 14 <b>AC Opening</b>	Since the fitment of wooden frame on outer shell wall of 1.6 mm shall not be robust, clarify if AC opening can be made from Rectangular steel sections as per BHEL required size in place of wooden frame as it can be easily welded with shell.	No change; As per PART-C TECHNICAL SPECIFICATION CLAUSE NO 14
07	PART-C TECHNICAL SPECIFICATION CLAUSE NO 22 <b>Telephone JB</b>	Please clarify if Telephone JB as per specification shall be required.	No change; Please refer to clause no. 22 of the technical specification for Telephone JB.
08	PART-C TECHNICAL SPECIFICATION SURFACE TREATMENT	Please clarify if Sand blasting as per SA 2 is also permissible.	No change; As per PART-C TECHNICAL SPECIFICATION. Sand blasting may not be permitted.

B) Bidders are requested to acknowledge TCN(s) as a token of acceptance in their techno-commercial offer.

C) 'No deviation certificate' is attached. Bidder to submit their offer along with stamped & signed copy of TCN(s) & 'No deviation certificate' as per attached format only.

D) All other terms & conditions shall remain unchanged.

Thanking you,

Yours faithfully,  
for BHARAT HEAVY ELECTRICALS LTD.

DY. MANAGER (PURCHASE)

(Signature, date & seal of authorized representative of the contractor)

**NO DEVIATION CERTIFICATE**

BHARAT HEAVY ELECTRICALS LIMITED,  
Power Sector - Eastern Region,  
Plot no 9/1, DJ Block, Sector – II, Salt Lake City,  
Kolkata – 700 091

Sub	No Deviation Certificate.	
Job	<b>Design, Manufacture, Assembly, Transport and delivery of 01 set Bunk House (consisting of 07 nos.Bunk House of various sizes as per specification) at BHEL, Namrup site ( Assam).</b>	
Ref	1	Tender no.: PSER:PUR:PMX: <b>163(XI):061</b> Date.21/08/2014 & TCN-01 DTD.25/08/14
	2	Other references (if any).

Dear Sirs,

With reference to above, this is to confirm you that we have gone through each and every terms and conditions mentioned in the enquiry and we offer our unqualified acceptance of the same. We confirm that we have not changed/modified the tender documents as appeared in the website/newspapers and in case of observance at any stage; it shall be treated as null and void.

It is also confirmed that the price has been quoted in the format received with the enquiry.

In the event of observance of any deviation in any part of our offer at a later date whether implicit or explicit, the deviations shall stand null & void.

We confirm to have submitted offer strictly in accordance with tender instructions.

Thanking you,

Yours faithfully,

(Signature, date & seal of authorized  
representative of the contractor)