



भारत हेवी इलेक्ट्रिकल्स लिमिटेड

(भारत सरकार का उपक्रम)

BHARAT HEAVY ELECTRICALS LIMITED

(A Govt. of India Undertaking)

TCN – 01

Ref: PSER:SCT:BNP-Q1624:TCN-01

Date: 13-11-2014

Sub	Tender Change Notice (TCN-01).	
Job	Package-A: Providing Safety Services for different working areas for Unit- 3&4 at 2x660 MW units, IBV TPS, Banharpalli, Odisha. & Package-B: Providing Services of Field Quality Assurance Engineer for different working areas for Unit- 3&4 at 2x660 MW units, IBV TPS, Banharpalli, Odisha.	
Ref	01	Tender No. PSER:SCT:BNP-Q1624:14.
	02	BHEL's NIT, vide reference no PSER:SCT: BNP-Q1624: 4021, dated 04-11-2014.
	03	Other references (if any).

With reference to above, following points, relevant to tender, may please be noted and complied with while submitting offer.

- 1.0 Extension of due date of offer submission from **14-11-2014 to 18-11-2014 (15:00 Hrs)**.
- 2.0 Clarification to bidder's query as per **Annexure-I** to TCN-01.
- 3.0 Revised 'No deviation certificate' is attached. Bidder to submit 'No deviation certificate' as per attached format only.
- 4.0 All other terms & conditions shall remain unchanged.

Thanking you,

Yours faithfully,
for BHARAT HEAVY ELECTRICALS LTD

SR. ENGINEER (SCT)

Encl

- 1.0 Revised 'No deviation certificate' format.
- 2.0 Clarifications to bidder's queries- ANNEXURE-I.

पावर सेक्टर पूर्वी क्षेत्र (मुख्यालय)

POWER SECTOR EASTERN REGION, DJ-9/1, SALT LAKE CITY, KOLKATA - 700 091

फैक्स/Fax : (033) 23211960 फोन/Phone : बोर्ड/EPABX : 23211798/ 1691

FORMAT FOR NO DEVIATION CERTIFICATE
(To be submitted in the bidder's letter head)

BHARAT HEAVY ELECTRICALS LIMITED,
Power Sector - Eastern Region,
Plot no 9/1, DJ Block, Sector – II, Salt Lake City,
Kolkata – 700 091

Sub	No Deviation Certificate.	
Job	Package-A: Providing Safety Services for different working areas for Unit- 3&4 at 2x660 MW units, IBV TPS, Banharpalli, Odisha. & Package-B: Providing Services of Field Quality Assurance Engineer for different working areas for Unit- 3&4 at 2x660 MW units, IBV TPS, Banharpalli, Odisha.	
Ref	1.0	Tender No. PSER:SCT:BNP-Q1624:14.
	2.0	BHEL's NIT, vide reference no PSER:SCT: BNP-Q1624: 4021, dated 04-11-2014.
	3.0	BHEL's TCN-01, vide reference no: Ref: PSER:SCT: BNP-Q1624: TCN-01, dated 13-11-2014.
	4.0	Other references (if any).

Dear Sirs,

With reference to above, this is to confirm that as per tender conditions, we have visited site before submission of our offer and noted the job content & site conditions etc. We also confirm that we have not changed/ modified the tender documents as appeared in the website/ issued by you and in case of such observance at any stage, it shall be treated as null and void.

We hereby confirm that we have not taken any deviation from tender clauses together with other references as enumerated in the above referred NIT. We hereby confirm our unqualified acceptance to all terms & conditions, unqualified compliance to technical specification, integrity pact (if applicable) and acceptance to reverse auctioning process.

In the event of observance of any deviation in any part of our offer at a later date whether implicit or explicit, the deviations shall stand null & void.

We confirm to have submitted offer in accordance with tender instructions and as per aforesaid references.

Thanking you,

Yours faithfully,

(Signature, date & seal of authorised
representative of the contractor)

पावर सेक्टर पूर्वी क्षेत्र (मुख्यालय)

POWER SECTOR EASTERN REGION, DJ-9/1, SALT LAKE CITY, KOLKATA - 700 091

फैक्स/Fax : (033) 23211960

फोन/Phone : बोर्ड/EPABX : 23211798/ 1691

REPLY TO CLARIFICATIONS OF BIDDER

Package-A: Providing Safety Services for different working areas for Unit- 3&4 at 2x660 MW units, IBV TPS, Banharpalli, Odisha.

&

Package-B: Providing Services of Field Quality Assurance Engineer for different working areas for Unit- 3&4 at 2x660 MW units, IBV TPS, Banharpalli, Odisha.

TENDER NO. PSER:SCT:BNP-Q1624:14.

SL No	PAGE NO.	Section No.	Clause No.	Details as per specification	Bidder's Queries	BHEL 's REPLY
1	Page 7 of 17	TS & SCC	4.3.3	Contractor shall advise site in setting up of mechanical laboratory and recommend, requisite facility and type of equipment to be installed in such laboratories.	Both clauses are contradicting. Second clause is ok. But first clause is not in the scope of FQA Service Providing Contractor. Such labs are set up well in advance and we have no role in such establishment.	What we have asked for is your advice in setting up the lab.. your person will check adequacy and accuracy of the measuring equipments available at the site to carry out measurements and tests as per the Quality Plan. He will be required to carry out testing as and when called for.
2	Page 10 of 17	TS & SCC	6.2.2	Facility of lab for various NDT on structure, piping and pressure parts will be provided at site by BHEL or by their sub contractors, free of any charge.		
3	Page 13 of 17	TS & SCC	7.1.1	AICTE/STATE BOARD OF TECHNICAL EDUCATION/DGFASLI/UGC APPROVED UNIVERSITY	What is DGFASLI and we have not heard such body? Please clarify....	It's a body under Ministry of Labour, Govt of India. It runs all RLIs.
4	Page 13 of 17	TS & SCC	7.2.1	Engineer must have valid Level-2 certificates in RT & UT and approved by INST/ASNT and experience of Radiography & Ultrasonic testing	There is not INST as per our knowledge, it is ISNT Indian Society for Non Destructive Testing. It may be print mistake. Please clarify.	Printing mistake.It shall be ISNT.