



भारत हेवी इलेक्ट्रिकल्स लिमिटेड

(भारत सरकार का उपक्रम)

BHARAT HEAVY ELECTRICALS LIMITED

(A Govt. of India Undertaking)

TCN - 01

Ref: PSER:SCT:FKK-S1672:TCN-01

Date: 21-05-2015

Sub	No Deviation Certificate.	
Job	Dismantling of existing C&I system, erection of new C&I system during shutdown period for 1 x 500 MW unit #4 at NTPC Farakka, West Bengal.	
Ref	1.0	Tender no PSER:SCT:FKK-S1672:15
	2.0	BHEL's NIT, vide reference no PSER:SCT:FKK-S1672:4448 Date:05-05-2015.
	3.0	All other pertinent issues till date.

With reference to above, following points/ documents, relevant to tender, may please be noted and complied with while submitting offer.

- 1.0 The clarifications to bidder's queries are attached at **Annexure-A**.
- 2.0 Revised 'No deviation certificate' as per enclosed Annexure-2. Bidder shall submit no deviation certificate as per enclosed format only.
- 3.0 All other terms & conditions shall remain unchanged.

Thanking you,

Yours faithfully,
for BHARAT HEAVY ELECTRICALS LTD

ENGR (SCT)

Encl : As above.

पावर सेक्टर पूर्वी क्षेत्र (मुख्यालय)

POWER SECTOR EASTERN REGION, DJ-9/1, SECTOR-II, SALT LAKE CITY, KOLKATA - 700 091

फैक्स/Fax : (033) 23211960

फोन/Phone : बोर्ड/EPABX : 23211691, 23211798, 23211796

Tender no PSER:SCT:FKK-S1672:15

Dismantling of existing C&I system, erection of new C&I system during shutdown period for 1 x 500 MW unit #4 at NTPC Farakka, West Bengal.

SL	Ref. clause of Tender	Existing Provision	Bidder's query	BHEL's clarification
1	Vol-1F CI 14.0	Price Variation Clause/Escalation not applicable for this tender (AS PER TCC)	Kindly refer CL 2.17 GCC. It says PVC is applicable kindly clarify.	PVC shall be applicable as per GCC for the works executed beyond original contract period.
2		Over Run Charges not applicable for this tender (AS PER TCC)	Kindly refer CL 2.12 GCC. It says ORC applicable, please clarify.	ORC shall not be applicable.
3	Vol-1F CI 3A	As per TCC Dismantling of existing C&I during shutdown period , like panels, cables, cable trays,batteries and other hardwires, and transport the same to waste bay designated by NTPC after weighing the same. Qty of waste material (SCH-1 of Rate Schedule):140 MT+/- 20%.	As per GCC,the quoted rates shall remain firm irrespective of any variations in the individual quantities. No compensation becomes payable in case the variation of the final executed contract value is within the limits of Plus (+) or Minus (-) 15% of awarded contract value .Kindly confirm the Quantity variation ,Since TCC CL Vol-1F CL3A/3B says Qty variations, please clarify	refer Sl. No. 30 of NIT.
4	Vol-1F CI 3B	As per TCC Scope of work for E&C of C&I items and commissioning of following auto control loops (Related list of materials are given in SCH- 2 of Rate Schedule) Variation of Qty for SCH-2 : +/- 15%		
5	GENERAL	As per Quantaties For SCH-A & B	Kindly confirm all the panels should be erected in existing control room or new control room , if in existing control room , kindly confirm wheather removal and re-termination of all control cables for existing panels is included in the given quantity kindly provide the dimension of the control room.	All panels are to be erected in old control room, old control panels are to be removed. Vendor has to erect new panels. Cabling, glanding, termination, dressing of cables are to be taken care by other agency. Dimension of a suit of single panel is 750mm x 800mm x 2415mm.
6	GENERAL		Total Schedule given as per GCCis 60 Days. Please clarify the mobilisation period,pre shutdown activities period,demobilisation period, since lot of dismantling works are involved in this job	Mobilisation period: 5 days Pre-shutdown work: 15 days Shutdown period: 45 days
7	GENERAL		All above points not disclosed in SCC .Please clarify wheather we will take take GCC/TCC for our estimation purposes.	refer Sl. No. 30 of NIT.

Tender no PSER:SCT:FKK-S1672:15

Dismantling of existing C&I system, erection of new C&I system during shutdown period for 1 x 500 MW unit #4 at NTPC Farakka, West Bengal.

SL	Ref. clause of Tender	Existing Provision	Bidder's query	BHEL's clarification
8	GENERAL		cable laying, glanding and termination portion BOQ is missing in the tender.	Please note that cable laying and termination is not the scope. Therefore cable dressing and glanding are not required to be done by the vendor.

FORMAT FOR NO DEVIATION CERTIFICATE
(To be submitted in the bidder's letter head)

BHARAT HEAVY ELECTRICALS LIMITED,
Power Sector - Eastern Region,
Plot no 9/1, DJ Block, Sector – II, Salt Lake City,
Kolkata – 700 091

Sub	No Deviation Certificate.	
Job	Dismantling of existing C&I system, erection of new C&I system during shutdown period for 1 x 500 MW unit #4 at NTPC Farakka, West Bengal.	
Ref	1.0	Tender no PSER:SCT:FKK-S1672:15
	2.0	BHEL's NIT, vide reference no PSER:SCT:FKK-S1672:4448 Date:05-05-2015.
	3.0	BHEL's TCN-01, vide reference PSER:SCT: FKK-S1672:TCN-01, dated 21-05-2015.
	4.0	All other pertinent issues till date.

Dear Sirs,

With reference to above, this is to confirm that as per tender conditions, we have visited site before submission of our offer and noted the job content & site conditions etc. We also confirm that we have not changed/ modified the tender documents as appeared in the website/ issued by you and in case of such observance at any stage, it shall be treated as null and void.

We hereby confirm that we have not taken any deviation from tender clauses together with other references as enumerated in the above referred NIT. We hereby confirm our unqualified acceptance to all terms & conditions, unqualified compliance to technical specification, integrity pact (if applicable) and acceptance to reverse auctioning process.

In the event of observance of any deviation in any part of our offer at a later date whether implicit or explicit, the deviations shall stand null & void.

We confirm to have submitted offer in accordance with tender instructions and as per aforesaid references.

Thanking you,

Yours faithfully,

(Signature, date & seal of authorized representative of the bidder)

पावर सेक्टर पूर्वी क्षेत्र (मुख्यालय)

POWER SECTOR EASTERN REGION DJ-9/1, SECTOR-II, SALT LAKE CITY, KOLKATA - 700 091

फैक्स/Fax : (033) 23211960

फोन/Phone : बोर्ड/EPABX : 23211691, 23211798, 23211796