



भारत हेवी इलेक्ट्रिकल्स लिमिटेड

(भारत सरकार का उपक्रम)

BHARAT HEAVY ELECTRICALS LIMITED

(A Govt. of India Undertaking)

TCN – 01

Ref: PSER:SCT:SNG-T1483:TCN-01

Date: 10-10-2013

Sub	Tender Change Notice (TCN-01).	
Job	Package-A: Erection, testing, commissioning etc of Steam Turbine & auxiliaries, Generator & auxiliaries, Pumps, Piping, Misc Equipments for 1x600 MW unit #1 along with the common system for both unit# 1 & 2 and Erection ,testing commissioning, handing over of Air Conditioning System Package for 2x600 MW SINGARENI TPP,ADILABAD,A.P. Package-B: Erection, testing, commissioning etc of Steam turbine & auxiliaries, generator & auxiliaries , pumps, piping, Misc. equipments for Unit#2 for 2 X 600 MW SINGARENI TPP,ADILABAD,A.P.	
Ref	01	Tender No. PSER:SCT:SNG-T1483:13.
	02	BHEL's NIT, vide reference no PSER:SCT:SNG-T1483: 3429, dated 27-09-2013.
	03	Other references (if any).

With reference to above, following points, relevant to tender, may please be noted and complied with while submitting offer.

- 1.0 Clarification to bidder's query as per **Annexure-I** to TCN-01.
- 2.0 Revised 'No deviation certificate' is attached. Bidder to submit 'No deviation certificate' as per attached format only.
- 3.0 All other terms & conditions shall remain unchanged.

Thanking you,

Yours faithfully,
for BHARAT HEAVY ELECTRICALS LTD

ENGINEER (SCT)

Encl

- 1.0 Revised 'No deviation certificate' format.
- 2.0 Clarifications to bidder's queries- ANNEXURE-I.

पावर सेक्टर पूर्वी क्षेत्र (मुख्यालय)

POWER SECTOR EASTERN REGION, DJ-9/1, SALT LAKE CITY, KOLKATA - 700 091

फैक्स/Fax : (033) 23211960 फोन/Phone : बोर्ड/EPABX : 23211798/ 1691

ANNEXURE - II

FORMAT FOR NO DEVIATION CERTIFICATE
(To be submitted in the bidder's letter head)

BHARAT HEAVY ELECTRICALS LIMITED,
Power Sector - Eastern Region,
Plot no 9/1, DJ Block, Sector – II, Salt Lake City,
Kolkata – 700 091

Sub	No Deviation Certificate.	
Job	Package-A: Erection, testing, commissioning etc of Steam Turbine & auxiliaries, Generator & auxiliaries, Pumps, Piping, Misc Equipments for 1x600 MW unit #1 along with the common system for both unit# 1 & 2 and Erection ,testing commissioning, handing over of Air Conditioning System Package for 2x600 MW SINGARENI TPP,ADILABAD,A.P. Package-B: Erection, testing, commissioning etc of Steam turbine & auxiliaries, generator & auxiliaries , pumps, piping, Misc. equipments for Unit#2 for 2 X 600 MW SINGARENI TPP,ADILABAD,A.P.	
Ref	1.0	Tender No. PSER:SCT:SNG-T1483:13..
	2.0	BHEL's NIT, vide reference no PSER:SCT:SNG- T1483: 3429, dated 27-09-2013..
	3.0	BHEL's TCN-01, vide reference no: Ref: PSER:SCT:SNG-T1483: TCN-01, dated 10-10-2013.
	4.0	Other references (if any).

Dear Sirs,

With reference to above, this is to confirm that as per tender conditions, we have visited site before submission of our offer and noted the job content & site conditions etc. We also confirm that we have not changed/ modified the tender documents as appeared in the website/ issued by you and in case of such observance at any stage, it shall be treated as null and void.

We hereby confirm that we have not taken any deviation from tender clauses together with other references as enumerated in the above referred NIT. We hereby confirm our unqualified acceptance to all terms & conditions, unqualified compliance to technical specification, integrity pact (if applicable) and acceptance to reverse auctioning process.

In the event of observance of any deviation in any part of our offer at a later date whether implicit or explicit, the deviations shall stand null & void.

We confirm to have submitted offer in accordance with tender instructions and as per aforesaid references.

Thanking you,

Yours faithfully,

(Signature, date & seal of authorised
representative of the contractor)

पावर सेक्टर पूर्वी क्षेत्र (मुख्यालय)

POWER SECTOR EASTERN REGION, DJ-9/1, SALT LAKE CITY, KOLKATA - 700 091

फैक्स/Fax : (033) 23211960

फोन/Phone : बोर्ड/EPABX : 23211798/ 1691

CLARIFICATIONS TO BIDDER'S QUERIES

Tender No. PSER:SCT:SNG - T 1483: 13

Sl.No.	Reference clause or tender document	Existing Provision	Bidder's query	BHEL's clarification
1	4.8.1	Generator Stator unloading, placement to TG floor with the help of EOT crane & lifting beam. Handling, lifting from special trailer / resting place in front of 'A' row and placment on TG deck foundation is included in the scope of contractor.	Please clarify the method of the Generator stator lifting i.e. (by EOT crane or Strand Jack / Portal crane). As it is mentioned in Tender, the Generator stator is supposed to lift from in front of 'A' row. In that case, lifting of Generator Stator with EOT crane may not be possible. Please clarify.	<p>Clause no 4.8.1 shall be read as following-</p> <p>The Generator Stator, weighing 292 Metric Tonnes (approx.) , will be delivered to site on a special wagon /trailer .</p> <p>Generator Unloading , placement to TG floor with the help of EOT crane & lifting beam” :</p> <p>The vendor shall extend all necessary assistance for releasing the special trailer in which generator stator reaches site.</p> <p>In case the stator is not lifted directly from the trailer, necessary assistance in Unloading of Generator in unloading bay is included in the scope of work.</p> <p>For Unloading/Loading/Assembly/Dismantling/Fabrication /Erection and Handling of the Equipment /T&Ps / Structural to be mobilized by contractor for Genrator Stator handling and lifting. Suitable Crawler/Mobile Crane (with Fuel and Operator) including TG Hall EOT Crane (with Fuel) shall be provided by BHEL on free of cost at Site as per work requirement.</p>
2	TCC -Section - 111 (B) Exclusions	Thermal insulation of Turbine, ESV, IV, LPBP Valves.	What about Heaters, FST and Deaerator, BFP etc.	Included in the scope of vendor.