



भारत हेवी इलेक्ट्रिकल्स लिमिटेड

(भारत सरकार का उपक्रम)

BHARAT HEAVY ELECTRICALS LIMITED

(A Govt. of India Undertaking)

TCN - 02

Ref: PSER:SCT:BNP-C1591:TCN-02

Date: 17-09-2014

Sub	Tender Change Notice (TCN)- 02	
Job	Design, manufacturing, supply, receipt at site, erection, site painting etc. including civil and handing over of removable/ re- erectable type pre-engineered, pre-fabricated closed storage sheds(5nos. of size approx. 900SQM), security room(1 no. of size 150SQFT), safety training hall (1 no. of size 120Ftx220Ft) & community toilet blocks(2 nos.) for 2x660 MW units at IB TPS, OPGCL, Banharpalli, Odisha.	
Ref	1.0	Tender no PSER:SCT: BNP-C1591:14.
	2.0	BHEL's NIT, vide reference no PSER:SCT: BNP-C1591 3914 Date: 29-08-2014
	3.0	BHEL's TCN-01,vide reference no PSER:SCT: BNP-C1591:TCN-01 Date: 1-09-2014
	4.0	Other References, if any.

With reference to above, following points, relevant to tender, may please be noted and complied with while submitting the offer.

1. The clarifications to bidders queries are attached at Annexure-A.
2. Revised 'No deviation certificate' is attached. Bidder to submit 'No deviation certificate' as per attached format only.
3. All other terms & conditions shall remain unchanged.

Thanking you,

Yours faithfully,
for BHARAT HEAVY ELECTRICALS LTD

DY MGR (SCT)

Encl:

1.0 As Above.

पावर सेक्टर पूर्वी क्षेत्र (मुख्यालय)

POWER SECTOR EASTERN REGION, DJ-9/1, SALT LAKE CITY, KOLKATA - 700 091

फैक्स/Fax : (033) 23211960 फोन/Phone : बोर्ड/EPABX : 23211798/ 1691

ANNEXURE-A to TCN- 02

Design, manufacturing, supply, receipt at site, erection, site painting etc. including civil and handing over of removable/ re- erectable

Tender no. PSER:SCT:BNP-1591:14

SL	Ref. clause of Tender Document	SUBJECT	BIDDER'S QUERY	BHEL'S CLARIFICATION
1	SL NO 1.00.00, TCC,VOLUME-IF-TS-1-REV-00	Sl no a), b), c),d), Scope of work	Is all the work is one location at site or at different location.	All five closed storage shed shall be located nearby. Security and safety training rooms shall be nearby. Toilets blocks shall be at different locations.
			Regarding the Security room, Training hall – Only floor area is given. Dimension Required (Security Room) Dimension Required (Safety Training Hall-1) Dimension Required (Safety Training Hall-2)	(Security Room) -Length – 15', Width - 10', Height – 10'. (Safety Training Hall-1) -Length – 12', Width - 10', Height – 10' (Safety Training Hall-2) -Length – 18', Width - 12', Height – 10'.
			Door and windows - No of windows , no of door & type of doors and windows material to be used	No. and size shall be suitable as per design, to be provided by Bidder for approval. Type of Door- Flush Door; Type of Window – Aluminum Panel Glass Window.

Tender no. PSER:SCT:BNP-1591:14				
SL	Ref. clause of Tender Document	SUBJECT	BIDDER'S QUERY	BHEL'S CLARIFICATION
			Wall panel – Sand wick panel 50 mm thickness PUF is mention and later it is mentioned that PUF thickness as 60 mm. If 50 mm PUF panel , PUF thickness will be of 50 mm only not 60	Wall total thickness shall be 60mm.
			Roofing material - Details not mentioned such as closed shed roof sheet or PUF panel roof sheet. If we provide the PUF panel roof sheet false ceiling made of PUF panel 30 mm can be avoided-	Refer "Volume IF TCC" clause no. 2.02 (cladding).
		SL NO 2.03.00	Electrical – No. of lights, fans, electrical plug points, AC required and etc, required is not mentioned for inside area	Electrical lay out to be submitted by the bidder for approval.
2	SL NO 1.00.00, TCC,VOLUME-IF-TS-1-REV-00	Scope of work	<p>Toilet block – Only Floor area is given.</p> <p>Dimension – Length -10Ft , Width -8Ft, Height –</p> <p>Door, windows & ventilator- No of windows , no of door, No of Ventilators & type of doors and windows material to be used N-</p> <p>Roofing material - Details not mentioned such as closed shed roof sheet or PUF panel roof sheet. If we provide the PUF panel roof sheet false ceiling made of PUF panel 30 mm can be avoided</p>	<p>Dimension – Length -10Ft , Width -8Ft, Height – 10 Ft.</p> <p>Suitable as per design, to be provided by Bidder for approval.</p> <p>Roofing material details as per "Volume IF TCC" clause no. 2.02 (cladding). For design, bidder to submit drawing for approval.</p>

Tender no. PSER:SCT:BNP-1591:14				
SL	Ref. clause of Tender Document	SUBJECT	BIDDER'S QUERY	BHEL'S CLARIFICATION
			Electrical – No of lights and exhaust fans required for toilet is not mentioned for inside area	Electrical lay out to be submitted by the bidder for approval.
			Septic tank – Scope of is not mentioned. Connection between the toilet and septic tank is also not mentioned	Septic tank including required civil work is in the scope of bidder. Refer TCN 01
			Plumbing – scope of Plumbing for toilet is not mentioned. External connection to the toilet is not mentioned	Internal plumbing lay out to be submitted the bidder for approval. External plumbing work not in the scope of tender.
3	SL NO 2.00.01, TCC,VOLUME-IF-TS-1-REV-00	DESIGN CONSIDERATIONS	Air conditioners (AC's) - closed shed – One no. air conditioner room having dimension (15'x15') has to be constructed in only one closed shed out of 5 nos. at any one corner as directed by the BHEL site engineer. ACS – 2nos of 1 Ton capacity has to be supplied and installed. Out of the 2 nos. of AC's one is for closed shed and another for training Hall or both the AC'S has to be fixed at closed shed and additional Ac's has to be considered for training hall.	Both AC are for closed storage shed only. No AC has been kept under the scope of supply for Security and safety training rooms.
4		GENERAL	Please clarify that one store in-charge room is required in all five sheds or each shed will have store in-charge rooms with required furniture.	Only one store in-charge room will be there in any one of the five closed storage sheds.

FORMAT FOR NO DEVIATION CERTIFICATE
(To be submitted in the bidder's letter head)

BHARAT HEAVY ELECTRICALS LIMITED,
Power Sector - Eastern Region,
Plot no 9/1, DJ Block, Sector – II, Salt Lake City,
Kolkata – 700 091

Sub	No Deviation Certificate.	
Job	Design, manufacturing, supply, receipt at site, erection, site painting etc. including civil and handing over of removable/ re- erectable type pre-engineered, pre-fabricated closed storage sheds(5nos. of size approx. 900SQM), security room(1 no. of size 150SQFT), safety training hall (1 no. of size 120Ftx220Ft) & community toilet blocks(2 nos.) for 2x660 MW units at IB TPS, OPGCL, Banharpalli, Odisha.	
Ref	1.0	Tender no PSER:SCT: BNP-C1591:14
	2.0	BHEL's NIT, vide reference no PSER:SCT: : BNP-C1591:3914 Date: 29-08-2014
	3.0	BHEL's TCN-01,vide reference no PSER:SCT: BNP-C1591:TCN-01 Date: 1-09-2014
	4.0	BHEL's TCN-02,vide reference no PSER:SCT:BNP-C1591:TCN-02 Date: 17-09-2014
	5.0	All other pertinent issues till date.

Dear Sirs,

With reference to above, this is to confirm that as per tender conditions, we have visited site before submission of our offer and noted the job content & site conditions etc. We also confirm that we have not changed/ modified the tender documents as appeared in the website/ issued by you and in case of such observance at any stage, it shall be treated as null and void.

We hereby confirm that we have not taken any deviation from tender clauses together with other references as enumerated in the above referred NIT. We hereby confirm our unqualified acceptance to all terms & conditions, unqualified compliance to technical specification, integrity pact (if applicable) and acceptance to reverse auctioning process.

In the event of observance of any deviation in any part of our offer at a later date whether implicit or explicit, the deviations shall stand null & void.

We confirm to have submitted offer in accordance with tender instructions and as per aforesaid references.

Thanking you,

Yours faithfully,

(Signature, date & seal of authorized representative of the bidder)