



भारत हेवी इलेक्ट्रिकल्स लिमिटेड

(भारत सरकार का उपक्रम)

BHARAT HEAVY ELECTRICALS LIMITED

(A Govt. of India Undertaking)

TCN – 02

Ref: PSER:SCT:SNG-E1547:TCN-02

Date: 21-05-2014

Sub	Tender Change Notice (TCN-02).	
Job	Electrical-1-Erection, Testing, Commissioning etc of Generator Transformer, Station Transformer, Unit Auxilliary Transformer, Other Misc Transformer, HT/ LT Bus Duct, DG Set, Associated Equipments/ Items/ Panel, etc for 2X600 MW Singareni Thermal Power Plant at Adilabad, Andhra Pradesh.	
Ref	01	Tender No. PSER:SCT:SNG-E1547:14.
	02	BHEL's NIT, vide reference no PSER:SCT:SNG-E1547: 3730, dated 07-05-2014.
	03	BHEL's TCN-01, vide reference no: Ref: PSER:SCT:SNG-E1547:TCN-01, dated 15-05-2014.
	04	Other references (if any).

With reference to above, following points, relevant to tender, may please be noted and complied with while submitting offer.

- 1.0 Clarifications to Bidder's queries has been attached herewith as per ANNEXURE-I.
- 2.0 Revised 'No deviation certificate' is attached. Bidder to submit 'No deviation certificate' as per attached format only.
- 3.0 All other terms & conditions shall remain unchanged.

Thanking you,

Yours faithfully,
for BHARAT HEAVY ELECTRICALS LTD

SR. ENGINEER (SCT)

Encl

- 1.0 Revised 'No deviation certificate' format.
- 2.0 Clarifications to bidder's queries- ANNEXURE-I.

पावर सेक्टर पूर्वी क्षेत्र (मुख्यालय)

POWER SECTOR EASTERN REGION, DJ-9/1, SALT LAKE CITY, KOLKATA - 700 091

फैक्स/Fax : (033) 23211960

फोन/Phone : बोर्ड/EPABX : 23211798/ 1691

FORMAT FOR NO DEVIATION CERTIFICATE
(To be submitted in the bidder's letter head)

BHARAT HEAVY ELECTRICALS LIMITED,
Power Sector - Eastern Region,
Plot no 9/1, DJ Block, Sector – II, Salt Lake City,
Kolkata – 700 091

Sub	No Deviation Certificate.	
Job	Electrical-1-Erection, Testing, Commissioning etc of Generator Transformer, Station Transformer, Unit Auxiliary Transformer, Other Misc Transformer, HT/ LT Bus Duct, DG Set, Associated Equipments/ Items/ Panel, etc for 2X600 MW Singareni Thermal Power Plant at Adilabad, Andhra Pradesh.	
Ref	1.0	Tender No. PSER:SCT:SNG-E1547:14.
	2.0	BHEL's NIT, vide reference no PSER:SCT:SNG-E1547: 3730, dated 07-05-2014.
	3.0	BHEL's TCN-01, vide reference no: Ref: PSER:SCT:SNG-E1547:TCN-01, dated 15-05-2014.
	4.0	BHEL's TCN-02, vide reference no: Ref: PSER:SCT:SNG-E1547:TCN-02, dated 21-05-2014.
	5.0	Other references (if any).

Dear Sirs,

With reference to above, this is to confirm that as per tender conditions, we have visited site before submission of our offer and noted the job content & site conditions etc. We also confirm that we have not changed/ modified the tender documents as appeared in the website/ issued by you and in case of such observance at any stage, it shall be treated as null and void.

We hereby confirm that we have not taken any deviation from tender clauses together with other references as enumerated in the above referred NIT. We hereby confirm our unqualified acceptance to all terms & conditions, unqualified compliance to technical specification, integrity pact (if applicable) and acceptance to reverse auctioning process.

In the event of observance of any deviation in any part of our offer at a later date whether implicit or explicit, the deviations shall stand null & void.

We confirm to have submitted offer in accordance with tender instructions and as per aforesaid references.

Thanking you,

Yours faithfully,

(Signature, date & seal of authorised
representative of the contractor)

CLARIFICATION TO BIDDER'S QUERIES

JOB		Electrical-1-Erection, Testing, Commissioning etc of Generator Transformer, Station Transformer, Unit Auxiliary Transformer, Other Misc Transformer, HT/ LT Bus Duct, DG Set, Associated Equipments/ Items/ Panel, etc for 2X600 MW Singareni Thermal Power Plant at Adilabad, Andhra Pradesh.		
TENDER NO.		PSER:SCT: SNG-E1547:14.		
Sl no	Reference clause of tender document	Existing provision	Bidder's query	BHEL's clarification
1	TCC, VOLUME-IF-CML-R-0, Cl.No.23.4.3 (Page 20 of 36) & Cl. No. 41.3 (Page 26 of 36)	The successful bidder is liable to furnish all documentary evidences towards payment of Works Contract Tax as and when required by BHEL. Service Tax along with Educational Cess to Service Tax as legally leviable & payable by the Contractor under 'Erection, commissioning and installation services' of Service Tax law/ Act, vide Sec-65 (105)(zzd), shall be paid by BHEL on contractor's gross bill.	Whether this contract will be considered as a "Works Contract" and what percentage of WCT is to be deducted from our bills. We have considered this contract as a Labour Oriented Contract and hence WCT will not be applicable as per our understanding. Please Confirm	Since the material supplied are consumable in nature ,It will be governed by service tax only . WCT shall not be applicable.
2	VOLUME-III, Price Schedule, Rev-00, Sl.No.1.1 (Page 2 of 4)	Oil Filled Transformers	Please provide the Oil Qty. in Ltrs. For each Transformer	Shall be furnished during execution
3	VOLUME-III, Price Schedule, Rev-00, Sl.No.2.1.1, 2.1.2 & 2.1.3 (Page 2 of 4)	IP Bus Duct	Please provide the no. of Welding Joints for Main , Tap-Off and Delta Bus Duct	Detailed drg shall be made available during execution
4	VOLUME-III, Price Schedule, Rev-00, Sl.No.4.2.2 (Page 3 of 4)	Aux. Distribution Board	Please provide the weight and size of each shipping section per each SET of Aux. Distribution Board	Approx. dimensions – 3.6m(W) x 0.65m (D) x 2.33m(H) – Total 1 set Weight 3000Kgs (approx)
5	VOLUME-III, Price Schedule, Rev-00, Sl.No.4.2.3 (Page 3 of 4)	Cranking and Control Supply Battery with stand	Please provide no. of Cells and weight of each Cell per SET of Battery	Cranking & Control Supply Battery with stand –24V,400AH(12V,400 AH-2 no.s) – Total 6 sets
6	VOLUME-III, Price Schedule, Rev-00, Sl.No.6 & 7 (Page 4 of 4)	Dragging of Generator Transformer	Please provide the approx. Length in Mtrs. For dragging the GT from Unloading place to respective foundation	Within a radial distance of 50 Metres
7	VOLUME-III, Price Schedule, Rev-00, Sl.No.8 (Page 4 of 4)	Dragging of Station Transformer	Please provide the approx. Length in Mtrs. For dragging the ST from Unloading place to respective foundation	Within a radial distance of 50 Metres