



भारत हेवी इलेक्ट्रिकल्स लिमिटेड

(भारत सरकार का उपक्रम)

BHARAT HEAVY ELECTRICALS LIMITED

(A Govt. of India Undertaking)

TCN - 02

Ref: PSER:SCT:BOK-E1600:TCN-02

Date: 6-10-2014

Sub	Tender Change Notice (TCN-02).	
Job	Operation & Maintenance of construction power system for 1 X 500 MW Bokaro-A Thermal Power Project, Jharkhand.	
Ref	01	Tender No. PSER:SCT:BOK-E1600:14
	02	BHEL's NIT, vide reference no PSER:SCT:BOK-E1600:3946 dated 17-09-2014
	03	BHEL's TCN-01, vide ref no Ref: PSER:SCT:BOK-E1600:TCN-01 Date: 29-09-2014
	04	Other references (if any).

With reference to above, following points, relevant to tender, may please be noted and complied with while submitting offer.

- 1.0 Due date of submission of offer is extended from 7-10-2014 to 10-10-2014 (15-00 hrs). Bidders are requested to submit their offer by extended due date positively.
- 2.0 Point No 2 of SI No 5 of NIT (Notice Inviting tender), page no 2, written as "PART-II (Price Bid) – in sealed and superscribed envelope (ENVELOPE-III & IV FOR PKG-A & PKG-B Respectively)" shall be superseded by the following :
"PART-II (Price Bid) – in sealed and superscribed envelope (ENVELOPE-III) "
- 3.0 **ENVELOPE-V** (MAIN ENVELOPE / OUTER ENVELOPE) written in page no. 3, is to be read as ' **ENVELOPE-IV** (MAIN ENVELOPE / OUTER ENVELOPE) '.
- 4.0 Revised 'No deviation certificate' is attached. Bidder to submit 'No deviation certificate' as per attached format only.
- 5.0 All other terms & conditions shall remain unchanged.

Thanking you,

Yours faithfully,
for BHARAT HEAVY ELECTRICALS LTD

DY MGR (SCT)

Encl

- 1.0 Revised 'No deviation certificate' format.

पावर सेक्टर पूर्वी क्षेत्र (मुख्यालय)

POWER SECTOR EASTERN REGION, DJ-9/1, SALT LAKE CITY, KOLKATA - 700 091

फैक्स/Fax : (033) 23211960

फोन/Phone : बोर्ड/EPABX : 23211798/ 1691

ANNEXURE - II

FORMAT FOR NO DEVIATION CERTIFICATE
(To be submitted in the bidder's letter head)

BHARAT HEAVY ELECTRICALS LIMITED,
Power Sector - Eastern Region,
Plot no 9/1, DJ Block, Sector – II, Salt Lake City,
Kolkata – 700 091

Sub	No Deviation Certificate.	
Job	Operation & Maintenance of construction power system for 1 X 500 MW Bokaro-A Thermal Power Project, Jharkhand	
Ref	1.0	Tender No. PSER:SCT:BOK-E1600:14
	2.0	BHEL's NIT, vide reference no PSER:SCT:BOK-E1600:3946 dated 17-09-2014
	3.0	BHEL's TCN-01, vide reference no: PSER:SCT:BOK-E1600:TCN-01 Date: 29-09-2014
	4.0	BHEL's TCN-02, vide ref no : PSER:SCT:BOK-E1600:TCN-02 Date: 6-10-2014
	5.0	Other references (if any).

Dear Sirs,

With reference to above, this is to confirm that as per tender conditions, we have visited site before submission of our offer and noted the job content & site conditions etc. We also confirm that we have not changed/ modified the tender documents as appeared in the website/ issued by you and in case of such observance at any stage, it shall be treated as null and void.

We hereby confirm that we have not taken any deviation from tender clauses together with other references as enumerated in the above referred NIT. We hereby confirm our unqualified acceptance to all terms & conditions, unqualified compliance to technical specification, integrity pact (if applicable) and acceptance to reverse auctioning process.

In the event of observance of any deviation in any part of our offer at a later date whether implicit or explicit, the deviations shall stand null & void.

We confirm to have submitted offer in accordance with tender instructions and as per aforesaid references.

Thanking you,

Yours faithfully,

(Signature, date & seal of authorised
representative of the contractor)

पावर सेक्टर पूर्वी क्षेत्र (मुख्यालय)

POWER SECTOR EASTERN REGION, DJ-9/1, SALT LAKE CITY, KOLKATA - 700 091

फैक्स/Fax : (033) 23211960

फोन/Phone : बोर्ड/EPABX : 23211798/ 1691