



भारत हेवी इलेक्ट्रिकल्स लिमिटेड

(भारत सरकार का उपक्रम)

BHARAT HEAVY ELECTRICALS LIMITED

(A Govt. of India Undertaking)

TCN - 02

Ref: PSER:SCT: IIS-M1315:TCN-02

Date: 03-04-2012

Sub	Tender change notice (TCN) 02.	
Job	Fabrication of bends and erection / commissioning of cold blast piping along with filter & silencer equipment of 3x18 MW Power & Blowing station for IISCO steel plant, Burnpur, W.B.	
Ref	1.0	Tender no PSER:SCT:IIS-M1315:12
	2.0	BHEL's NIT, vide reference no PSER:SCT:IIS-M1315:2740, dated 12-03-2012.
	3.0	BHEL's TCN-01, vide reference no PSER:SCT:IIS-M1315:TCN-01, dated 29-03-2012.
	4.0	All other pertinent issues till date.

With reference to above, following points/ documents, relevant to tender, may please be noted and complied with while submitting offer.

- 1.0 Clarification to bidder's queries as per enclosed Annexure-A.
- 2.0 Revised 'No deviation certificate' as per enclosed Annexure-2. Bidder shall submit no deviation certificate as per enclosed format only.
- 3.0 All other terms & conditions shall remain unchanged.

Thanking you,

Yours faithfully,
for BHARAT HEAVY ELECTRICALS LTD

ENGR (SCT)

Encl

- 1.0 As above.

पावर सेक्टर पूर्वी क्षेत्र (मुख्यालय)

POWER SECTOR EASTERN REGION, DJ-9/1, SECTOR-II, SALT LAKE CITY, KOLKATA - 700 091

फैक्स/Fax : (033) 23211960

फोन/Phone : बोर्ड/EPABX : 23211691, 23211798, 23211796

FORMAT FOR NO DEVIATION CERTIFICATE
(To be submitted in the bidder's letter head)

BHARAT HEAVY ELECTRICALS LIMITED,
Power Sector - Eastern Region,
Plot no 9/1, DJ Block, Sector – II, Salt Lake City,
Kolkata – 700 091

Sub	No Deviation Certificate.	
Job	Fabrication of bends and erection / commissioning of cold blast piping along with filter & silencer equipment of 3x18 MW Power & Blowing station for IISCO steel plant, Burnpur, W.B.	
Ref	1.0	Tender no PSER:SCT:IIS-M1315:12.
	2.0	BHEL's NIT, vide reference no PSER:SCT:SDG-E1222:2439, dated 23-06-2011.
	3.0	BHEL's TCN-01, vide reference no PSER:SCT: IIS-M1315:TCN-01, dated 29-03-2012.
	4.0	BHEL's TCN-02, vide reference no PSER:SCT: IIS-M1315:TCN-02, dated 03-04-2012.
	5.0	All other pertinent issues till date.

Dear Sirs,

With reference to above, this is to confirm that as per tender conditions, we have visited site before submission of our offer and noted the job content & site conditions etc. We also confirm that we have not changed/ modified the tender documents as appeared in the website/ issued by you and in case of such observance at any stage, it shall be treated as null and void.

We hereby confirm that we have not taken any deviation from tender clauses together with other references as enumerated in the above referred NIT. We hereby confirm our unqualified acceptance to all terms & conditions, unqualified compliance to technical specification, integrity pact (if applicable) and acceptance to reverse auctioning process.

In the event of observance of any deviation in any part of our offer at a later date whether implicit or explicit, the deviations shall stand null & void.

We confirm to have submitted offer in accordance with tender instructions and as per aforesaid references.

Thanking you,

Yours faithfully,

(Signature, date & seal of authorized
representative of the bidder)

SL.NO	Page no.	Tender Cl.Sl.no	Bidder's queries	BHEL Reply /Comments
1	16 of 22	Cl.no.22.1 of TS	Equipment Weight Details Please provide us the Data sheet/Drawing /Sketch for Equipment to see the dimension i.e. MOC, Height , wall thickness & end connection of Silencer &filter, diameter & length of silencer vent pipes, etc which are not find attached . In absence of the tentative size of above stated all equipment. It is very difficult to ascertain the estimated cost of such equipment erection.	As per tender technical specification weight schedule of equipments has already been furnished along with GA drawing.
2	17 of 22	Cl.no.22.2 of TS	PIPE AND PIPE FITTINGS From the listed pipes & pipe fittings it is envisaged that Pipe fittings of sizes 10”NB and above are need to be Pre-Fabricated, welded & tested according tender specification by bidder at project site & Pipe fittings sizes up to 8”NB will be forged fittings to be supplied by BHEL Free issue at site	All bends above 12” are to be fabricated at site by vendor.12” and below bends to be supplied in ready made by BHEL,
3	18 of 22	Cl.no.22.2 of TS	FLANGES ,BLIND FLANGES, TUDS/Bolts, NUTS &Gasket, etc. It is envisaged that various size of FLANGES ,BLIND FLANGES,STUDS/Bolts ,NUTS & Gasket, etc. Will be supplied by BHEL on free issue basis to the bidder	Yes. It is confirmed that BHEL shall supply on free issue basis.
4	8 of 47	Cl.no4.1.4 of scc.	<u>TIG Filler wire for Boiler and Filler wires for Electrodes for P91/T91 piping:</u> From the list of pipes &pipe fittings it is unable to envisage the quantity of piping works are involved for carrying out welding to be done with P91 class of TIG filler &Electrodes.	There is no welding in P-91, however all filler wires applicable in GTAW welding shall have to be supplied by bidder.
			Please make ensure that induction heating Machine shall be provided by BHEL on free charges basis to bidder .	As there is no pre-heating and post heating, there is no requirement of induction heating m/c.

पावर सेक्टर पूर्वी क्षेत्र (मुख्यालय)

POWER SECTOR EASTERN REGION, SECTOR-II, DJ-9/1, SALT LAKE CITY, KOLKATA - 700 091

फैक्स/Fax : (033) 23211960

फोन/Phone : बोर्ड/EPABX : 23211691/ 23211798/ 23211796