



# भारत हेवी इलेक्ट्रिकल्स लिमिटेड

( भारत सरकार का उपक्रम )

## BHARAT HEAVY ELECTRICALS LIMITED

(A Govt. of India Undertaking)

TCN - 02

Ref: PSER:SCT:SLB-M1451:TCN-02

Date: 07-06-2013

|     |  |   |
|-----|--|---|
| Sub | Tender change notice (TCN) - 02  |   |
| Job | Supply, Installation & Testing of Water Treatment plant at BHEL Bhavan, Salt lake , Kolkata. |   |
| Ref | 1.0  | Tender no PSER:SCT:SLB-M1451:13.  |
|     | 2.0  | BHEL's NIT, vide ref no Ref: PSER:SCT: SLB-M1451:3284 , Dated 13-05-2013.     |
|     | 3.0  | BHEL's TCN-01, vide ref no Ref: PSER:SCT: SLB- M1451:TCN-01, Dated 30-05-2013 |
|     | 4.0  | Other references (if any).  |

With reference to above, following points, relevant to tender, may please be noted and complied with while submitting offer.

- 1.0 Due date of submission of offer is extended from **10-06-2013** to **17-06-2013 (14-00 hrs)**. Bidders are requested to submit their offer by extended due date positively.
- 2.0 Clarification to bidder's query as per **Annexure-A** to TCN-02.
- 3.0 Revised 'No deviation certificate' is attached. Bidder to submit 'No deviation certificate' as per attached Format only.
- 4.0 All other terms & conditions shall remain unchanged.

Thanking you,

Yours faithfully,  
for BHARAT HEAVY ELECTRICALS LTD

Encl

- 1.0 Revised 'No deviation certificate' format.
- 2.0 ANNEXURE-A

ENGR (SCT)

पावर सेक्टर पूर्वी क्षेत्र ( मुख्यालय )

POWER SECTOR EASTERN REGION, DJ-9/1, SALT LAKE CITY, KOLKATA - 700 091

फैक्स/Fax : (033) 23211960 फोन/Phone : बोर्ड/EPABX : 23211798/ 1691

**FORMAT FOR NO DEVIATION CERTIFICATE**  
**(To be submitted in the bidder's letter head)**

BHARAT HEAVY ELECTRICALS LIMITED,  
Power Sector - Eastern Region,  
Plot no 9/1, DJ Block, Sector – II, Salt Lake City,  
Kolkata – 700 091

|     |  |  |
|-----|--|--|
| Sub | No Deviation Certificate.  |  |
| Job | Supply, Installation & Testing of Water Treatment plant at BHEL Bhavan, Salt lake , Kolkata. |  |
| Ref | 1.0  | Tender no PSER:SCT:SLB-M1451:13.   |
|     | 2.0  | BHEL's NIT, vide ref no Ref: PSER:SCT: SLB-M1451:3284 , Dated 13-05-2013.      |
|     | 3.0  | BHEL's TCN-01, vide reference no PSER:SCT: SLB-M1451:TCN-01, dated 30-05-2013. |
|     | 4.0  | BHEL's TCN-02, vide reference no PSER:SCT: SLB-M1451:TCN-02, dated 07-06-2013. |
|     | 5.0  | All other pertinent issues till date.  |

Dear Sirs,

With reference to above, this is to confirm that as per tender conditions, we have visited site before submission of our offer and noted the job content & site conditions etc. We also confirm that we have not changed/ modified the tender documents as appeared in the website/ issued by you and in case of such observance at any stage, it shall be treated as null and void.

We hereby confirm that we have not taken any deviation from tender clauses together with other references as enumerated in the above referred NIT. We hereby confirm our unqualified acceptance to all terms & conditions, unqualified compliance to technical specification, integrity pact (if applicable) and acceptance to reverse auctioning process.

In the event of observance of any deviation in any part of our offer at a later date whether implicit or explicit, the deviations shall stand null & void.

We confirm to have submitted offer in accordance with tender instructions and as per aforesaid references.

Thanking you,

Yours faithfully,

(Signature, date & seal of authorized  
representative of the bidder)

## ANNEXURE – A TO TCN-02

|                  |  |
|------------------|--|
| <b>JOB</b>       | Supply, Installation & Testing of Water Treatment plant at BHEL Bhavan, Salt lake , Kolkata. |
| <b>TENDER NO</b> | <b>PSER:SCT:SLB-M1451:13</b>   |

| <b>Sr. no</b> | <b>Reference clause of tender document</b>             | <b>Existing provision</b>                     | <b>Bidder's query</b>   | <b>BHEL's clarification</b> |
|---------------|--|---|---|-----------------------------|
| 1             | Volume II, REV I<br>Mandatory Items<br>Page no. I of 3 | Raw water quality is not given in the tender. | Kindly provide the Raw Water Test report/ analysis from water testing laboratory.<br>It is not possible to analyze the water quality by just coming on site.  | As per Tender.              |
| 2             | Volume II, REV I<br>Mandatory Items<br>Page no. I of 3 | Outlet water guaranty                         | In case the raw water quality is not provided by you, we can just supply the materials as specified in the tender, but outlet water guaranty will not be provided. And hence no charges is acceptable in case of outlet water parameters given in tender exceeds. | As per Tender.              |