



# Bharat Heavy Electricals Limited

(A Govt. Of India Undertaking)

Power Sector, Eastern Region

BHEL BHAWAN, PLOT NO. DJ-9/1 , SECOTR II , SALT LAKE CITY , KOLKATA  
, WEST BENGAL, INDIA

Phone : 033-23216130-31,033-23216130 FAX : 033-23211960

<b>Sub</b>	<b>TENDER CHANGE NOTICE (TCN-02) DATED: 20/07/2013.</b>
<b>Job</b>	<b>“OVERHAULING OF GENERATOR, BEARING INSPECTION WITH ASSOCIATED VALVES &amp; EXCITER, PMG ETC. AT UNIT-1, 525 MW, MAITHON TPS, MPL, JHARKHAND”.</b>
<b>Ref</b>	<b>TENDER NO.: PSER: PUR: MPL-S115:13: ENQ: 13: PP: 0015: PUR 71 DATE: 16/07/2013, TENDER CHANGE NOTICE (TCN-01) DATED: 19/07/2013</b>

**Bidders please note following technical clarifications:--**

<b>Sl. no.</b>	<b>Description/ tender clause</b>	<b>Bidder's Queries</b>	<b>BHEL's Clarifications</b>
1	Annexure - I (Scope of work) Generator and Auxiliaries : Sub Clause No. 2.13 & Sub clause no. 3.7	Sub clause no 2.13 & 3.7 of Annexure-I (Scope of work) - Generator & Auxiliaries says that "Any leakages from the CC bolt sealing washers during air leakage are to be attended" for Generator & Exciter rotor respectively. How the air leakage to be find out, by visual inspection or by means of any test? If the leakage to be find out by means of any testing where instruments/T&P and Man Powers are required then what is the provision of payment to vendor for the same?	<b>Vendor to refer Sub Clause 2.12 &amp; 3.6 of Annexure - I (Scope of work) Generator and Auxiliaries: where it is clearly allocated 0.5% each for air leakage tests of generator rotor &amp; exciter. If there will be any leakage after performing the air leakage tests then only it is to be attended through Ex-BHEL technician and another 2.0% for each case will be applicable.</b>

**BIDDERS ARE REQUESTED TO ACKNOWLEDGE THIS TCN-02 AS A TOKEN OF ACCEPTANCE IN THEIR TECHNO-COMMERCIAL OFFER.**

**ALL OTHER TERMS AND CONDITIONS OF THE SUBJECT TENDER SHALL REMAIN UNCHANGED.**

Thanking you,

Yours faithfully,  
for BHARAT HEAVY ELECTRICALS LTD

DY. MANAGER (PURCHASE)

[ANNEXURE - IV](#)

**FORMAT FOR NO DEVIATION CERTIFICATE**  
**(To be submitted in the bidder's letter head)**

To,  
Bharat Heavy Electricals Limited,  
POWER SECTOR – EASTERN REGION  
2<sup>nd</sup> FLOOR, Block-DJ, Plot- 9/1, SECTOR  
SALT LAKE CITY, KOLKATA – 700 091  
FAX – 033-2321-1960

**Sub: NO DEVIATION CERTIFICATE “OVERHAULING OF GENERATOR, BEARING INSPECTION WITH ASSOCIATED VALVES & EXCITER, PMG ETC. AT UNIT-1, 525 MW, MAITHON TPS, MPL, JHARKHAND”.**

**Tender No. PSER: PUR: MPL-S115:13: ENQ:13:PP:0015:PUR:71 DATE: 16/07/2013, ALONG WITH TENDER CHANGE NOTICE (TCN-01) DATED: 19/07/2013, TENDER CHANGE NOTICE (TCN-02) DATED: 20/07/2013**

Dear Sirs,

**With** reference to above, this is to confirm that as per tender conditions, we have visited site before submission of our offer and noted the job content & site conditions etc. We also confirm that we have not changed/modified the tender documents as appeared in the website/newspapers and in case of observance at any stage, it shall be treated as null and void.

**We** hereby confirm that we have not taken any deviation from tender clauses together with other references as enumerated in the above referred NIT and confirm our acceptance to **reverse auctioning process** and we hereby convey our unqualified acceptance to all terms and conditions as stipulated in the tender and NIT.

In the event of observance of any deviation in any part of our offer at a later date whether implicit or explicit, the deviations shall stand null & void.

We confirm to have submitted offer strictly in accordance with tender instructions.

Thanking you,

Yours faithfully,

(Signature, date & seal of authorized  
representative of the contractor)