



# Bharat Heavy Electricals Limited

(A Govt. Of India Undertaking)

Power Sector, Eastern Region

BHEL BHAWAN, PLOT NO. DJ-9/1 , SECOTR II ,

SALT LAKE CITY , KOLKATA ,WEST BENGAL, INDIA

Phone : 033-23216130-31,033-23216130 FAX : 033-23211960

## **TENDER CHANGE NOTICE**

Sub	TENDER CHANGE NOTICE (TCN-02 DTD. 04/04/2015)
Job	<b>“SUPPLY OF (53MT +/- 10%) FACTORY MADE 40 MM THICK ELECTROFORGED MILD STEEL GRATING AS PER TENDER SPECIFICATION TO BHEL SITE, 2x195 MW KANTI BIJLEE UTPAD NIGAM LTD), MUZAFFARPUR TPS ST-II, ON ‘F.O.R’ SITE BASIS”.</b>
Ref	TENDER NO.: PSER:PUR:PMX:141(III):163 dated 19/03/2015. & TCN-01 dtd 1/04/15

1) [With reference to above, following clarifications / changes, relevant to tender, may please be noted and complied with while submitting the offer.](#)

Sl. no.	Description/ Tender clause	Bidder's queries	BHEL's Clarification
1	Scope of supply	Please mention the exact scope of supply as we have also seen the nut bolt part in your drawings.	Details of scope of supply shall be as per SCC of tender to be read in conjunction with the price schedule (part E of tender).
2	Requirement of Circular grating	We would like to know where you would need platform gratings in circular shape	Requirement of Grating in Circular shape is not envisaged as per tender.
3	PANEL size/ CUT size of Gratings	We are not clear about the supply part in cut sizes of gratings. Is it that you want us to supply a standard grating panel size	Requirement of Grating is in Standard Sizes only. However BHEL reserves the right to specify cut sizes of grating which shall be intimated to you during Material dispatch Clearance
4	Nature of bars to be used in gratings	Cross bar to be used in gratings would be twisted bar or a flat bar	Nature of bars shall be as per Drawing
5	Warranty (clause no. 2 of SCC of tender.)	You have also mentioned that you need 12 month warranty period, we would like to know on what all parts the warranty part would cover	Warranty Shall be for Supply Item only, as per tender.

6	Painting/ galvanization of gratings	In NIT No.PSER:PUR:PMX:141(III):163 dated 19/03/2015 Clearly written Galvanized Gratings but (2) in your Part-C :Technical Specification and Special Condition of Contract (SCC), Page 2 of 2 : in Drawing clearly written Painted gratings - please tell us which is applicable for this NIT Gratings	Galvanized Grating is applicable. Drawing appended with tender can be referred, wherein under the heading 'painting for gratings' galvanization is clearly mentioned
7	Bill Of Materials for grating	BOM is not available	BOM shall be as per Price Schedule available in the tender documents.

- 2) Bidder to submit their offer along with stamped & signed copy of this TCN as a token of acceptance.
- 3) All other terms & conditions shall remain unchanged.

Thanking you,

Yours faithfully,  
for BHARAT HEAVY ELECTRICALS LTD

Sr. Engineer (Purchase)

(Signature, date & seal of authorized representative of the contractor)