



भारत हेवी इलेक्ट्रिकल्स लिमिटेड

(भारत सरकार का उपक्रम)

BHARAT HEAVY ELECTRICALS LIMITED

(A Govt. of India Undertaking)

TCN - 02

Ref: PSER:SCT:FKK-S1643:TCN-02

Date: 17-01-2015

Sub	TCN-02	
Job	Dismantling of existing C&I system, erection of new C&I system at U#4 for post shutdown job for 1 x 500 MW unit #4 at NTPC Farakka, West Bengal.	
Ref	1.0	Tender no PSER:SCT:FKK-S1643:14.
	2.0	BHEL's NIT, vide reference no PSER:SCT: FKK-S1643:4134 Date:26-12-2014.
	3.0	BHEL's TCN-01, vide reference PSER:SCT: FKK-S1643:TCN-01, dated 15-01-2015.
	4.0	All other pertinent issues till date.

With reference to above, following points/ documents, relevant to tender, may please be noted and complied with while submitting offer.

- 1.0 The clarifications to bidder queries are attached at **Annexure-A**.
- 2.0 Revised 'No deviation certificate' as per enclosed Annexure-2. Bidder shall submit no deviation certificate as per enclosed format only.
- 3.0 All other terms & conditions shall remain unchanged.

Thanking you,

Yours faithfully,
for BHARAT HEAVY ELECTRICALS LTD

ENGR (SCT)

Encl : As above.

पावर सेक्टर पूर्वी क्षेत्र (मुख्यालय)

POWER SECTOR EASTERN REGION, DJ-9/1, SECTOR-II, SALT LAKE CITY, KOLKATA - 700 091

फैक्स/Fax : (033) 23211960

फोन/Phone : बोर्ड/EPABX : 23211691, 23211798, 23211796

ANNEXURE-A to TCN- 02

Dismantling of existing C&I system, erection of new C&I system at U#4 for post shutdown job for 1 x 500 MW unit #4 at NTPC Farakka, West Bengal.

Tender No. PSER:SCT:FKK-S1643:14.

SL	Reference clause of tender document	Existing provision	Bidder's query	BHEL's clarification
1	VOL-III, PRICE SCHEDULE	--	How much no. of cable gland required for different category of Instrumentation cable. Termination Qty has not been specified. Weather the cable is urmoured or unurmoured. The cable gland size will be different for armoured & unarmoured. Accordingly price will be effected.	CABLE SPECIFICATION IS FIXED. AT LEAST 3000-3500 +/- 20% RUNS OF CABLE SHALL BE LAID
2	VOL-III, PRICE SCHEDULE	--	For Un armoured power cable Double compression cable gland is not required as you have mentioned as un armoured. It should be armoured. So it has to be specify .	AS PER TENDER
3	VOL-III, PRICE SCHEDULE	--	For control cable : Cable should be armoured. For unarmoured cable double compression cable is not required.	AS PER TENDER
4	VOL-III, PRICE SCHEDULE	--	Cable route should be cleared. Height has to be mentioned.	NEW CABLE ROUT SHALL BE PARALLEL TO THE EXISTING ONE. BIDDERS ARE REQUESTED TO VISIT THE SITE.
5	VOL-III, PRICE SCHEDULE	--	in price schedule , Qty. is very high. In 500 MW Generator , Qty should not be so high. Please send the exact B.O.Q . Cable Tray qty is not matching with Total Qty. of cable laying.	AS PER TENDER
6	VOL-III, PRICE SCHEDULE	--	Detail Gland qty. should be mentioned	REFER REPLY AT SL. NO. -01
7	VOL-IF	--	Payment Terms : 5 % against Guaranty Clause should be omitted. 1.5 % payment is not cleared .	AS PER TENDER

FORMAT FOR NO DEVIATION CERTIFICATE
(To be submitted in the bidder's letter head)

BHARAT HEAVY ELECTRICALS LIMITED,
 Power Sector - Eastern Region,
 Plot no 9/1, DJ Block, Sector – II, Salt Lake City,
Kolkata – 700 091

Sub	No Deviation Certificate.	
Job	Dismantling of existing C&I system, erection of new C&I system at U#4 for post shutdown job for 1 x 500 MW unit #4 at NTPC Farakka, West Bengal.	
Ref	1.0	Tender no PSER:SCT:FKK-S1643:14.
	2.0	BHEL's NIT, vide reference no PSER:SCT: FKK-S1643:4134 Date:26-12-2014.
	3.0	BHEL's TCN-01, vide reference PSER:SCT: FKK-S1643:TCN-01, dated 15-01-2015.
	4.0	BHEL's TCN-02, vide reference PSER:SCT: FKK-S1643:TCN-02, dated 17-01-2015.
	5.0	All other pertinent issues till date.

Dear Sirs,

With reference to above, this is to confirm that as per tender conditions, we have visited site before submission of our offer and noted the job content & site conditions etc. We also confirm that we have not changed/ modified the tender documents as appeared in the website/ issued by you and in case of such observance at any stage, it shall be treated as null and void.

We hereby confirm that we have not taken any deviation from tender clauses together with other references as enumerated in the above referred NIT. We hereby confirm our unqualified acceptance to all terms & conditions, unqualified compliance to technical specification, integrity pact (if applicable) and acceptance to reverse auctioning process.

In the event of observance of any deviation in any part of our offer at a later date whether implicit or explicit, the deviations shall stand null & void.

We confirm to have submitted offer in accordance with tender instructions and as per aforesaid references.

Thanking you,

Yours faithfully,

(Signature, date & seal of authorized representative of the bidder)

पावर सेक्टर पूर्वी क्षेत्र (मुख्यालय)

POWER SECTOR EASTERN REGION DJ-9/1, SECTOR-II, SALT LAKE CITY, KOLKATA - 700 091

फैक्स/Fax : (033) 23211960

फोन/Phone : बोर्ड/EPABX : 23211691, 23211798, 23211796