



भारत हेवी इलेक्ट्रिकल्स लिमिटेड

(भारत सरकार का उपक्रम)

BHARAT HEAVY ELECTRICALS LIMITED

(A Govt. of India Undertaking)

TCN - 03

Ref: PSER:SCT:SNG-M1625:TCN-03

Date: 20/11/2014

Sub	Tender change notice (TCN) 03	
Job	Design, engineering, manufacturing, supply/Delivery, erection, Commissioning, trial run, handing over to customer etc of ventilation System for 2x600MW Unit at Singareni STPP, Adilabad , Andhra pradesh .	
Ref	1.0	Tender no PSER:SCT:SNG-M1625:14
	2.0	BHEL's NIT, vide ref no PSER:SCT:SNG-M1625:4039 Dated 11/11/2014
	3.0	BHEL's TCN 01 dated Ref: PSER:SCT:SNG-M1625:TCN-01 Date: 12/11/2014
	4.0	BHEL' s TCN 02 dated ref:PSER:SCT:SNG-M1625:TCN-02 date 18/11/2014
	5.0	Other references (if any).

With reference to above, following points , relevant to tender, may please be noted and complied with while submitting offer.

- 1.0 Due date of submission is extended from 21/11/2014 to 27/11/2014 at 15-00 Hrs.
- 2.0 Clarification to bidder's queries as per annexure-A to TCN-03.
- 3.0 Revised 'No deviation certificate' is attached. Bidder to submit 'No deviation certificate' as per attached Format only .
- 4.0 All other terms & conditions shall remain unchanged .

Thanking you,

Yours faithfully,
For BHARAT HEAVY ELECTRICALS LTD

DY MGR (SCT)

Encl

- 1.0 Annexure- A to TCN-03 .
- 2.0 Revised 'No deviation certificate' format.

पावर सेक्टर पूर्वी क्षेत्र (मुख्यालय)

POWER SECTOR EASTERN REGION, DJ-9/1, SALT LAKE CITY, KOLKATA - 700 091

फैक्स/Fax : (033) 23211960

फोन/Phone : बोर्ड/EPABX : 23211495/ 1691

ANNEXURE - A**DETAILS OF CLARIFICATIONS/CONFIRMATION NEEDED**

JOB		Design, engineering, manufacturing, supply/Delivery, erection, Commissioning, trial run, handing over to customer etc. of ventilation System for 2x600MW Unit at Singareni STPP, Adilabad, Andhra Pradesh.		
TENDER NO		PSER:SCT:SNG-M1625:14		
SI no	Reference clause of tender document	Existing provision	Bidder's query	BHEL's clarification
1	Volume-IIB Section C2 Sub-Section A-13			
1.1	Clause 5.02.00 Section VI Part-B Page 5 of 32	Specifies Inside Conditions to be maintained.	To ensure maintenance of inside conditions, we need to calculate heat-load. To calculate heat load we need to have relevant internal heat data, which is nowhere available to us in the Tender Documents. Please furnish the relevant details.	Capacity of Air washer and UAF is already mentioned in the specification. Bidder is requested to quote as per the BOQ.
1.2	Clause 5.01.00 Section-VI Part-B Page 5 of 32	Specifies required Air Flows in terms of Air changes/hr. Though with a Caveat, saying that air flows to be selected for higher of the two values calculated as per clause 5.01.00 & 5.02.00.	But this way we can only ensure equipment performance not necessarily inside conditions. It is okay to be guided by this for our offer, but how do we ensure and select for higher of the two air flows unless we estimate the heat-load (refer query above). In view of above, please furnish the required data & details or the guarantee be read as guarantee of equipment performance & capacity offered as per air flows specified at above referred clause 5.01.00 &/or BOQ (Volume-III).	Ventilation fan required for the various auxiliary buildings, battery room etc are unit rate item. Bidder is requested to quote as per the BOQ.

FORMAT FOR NO DEVIATION CERTIFICATE
(To be submitted in the bidder's letter head)

BHARAT HEAVY ELECTRICALS LIMITED,
Power Sector - Eastern Region,
Plot no 9/1, DJ Block, Sector – II, Salt Lake City,
Kolkata – 700 091

Sub	No Deviation Certificate.	
Job	Design, engineering, manufacturing, supply/Delivery, erection, Commissioning, trial run, handing over to customer etc of ventilation System for 2x600MW Unit at Singareni STPP, Adilabad , Andhra pradesh .	
Ref	1.0	Tender no PSER:SCT:SNG-M1625:14
	2.0	BHEL's NIT, vide ref no PSER:SCT:SNG-M1625:4039 Dated 11/11/2014
	3.0	BHEL's TCN-01 , vide ref no PSER:SCT:SNG-M1625:TCN-01 Dated 12/11/2014.
	4.0	BHEL's TCN-02, vide ref no PSER:SCT:SNG-M1625:TCN-02 Dated 18/11/2014
	5.0	BHEL's TCN-03, vide ref no PSER:SCT:SNG-M1625:TCN-03 Dated 20/11/2014
	6.0	Other references (if any) .

Dear Sirs,

With reference to above, this is to confirm that as per tender conditions, we have visited site before submission of our offer and noted the job content & site conditions etc. We also confirm that we have not changed/ modified the tender documents as appeared in the website/ issued by you and in case of such observance at any stage, it shall be treated as null and void .

We hereby confirm that we have not taken any deviation from tender clauses together with other references as enumerated in the above referred NIT. We hereby confirm our unqualified acceptance to all terms & conditions, unqualified compliance to technical specification, Integrity Pact (If applicable) and acceptance to reverse auctioning process.

In the event of observance of any deviation in any part of our offer at a later date whether implicit or explicit, the deviations shall stand null & void.

We confirm to have submitted offer in accordance with tender instructions and as per aforesaid references.

Thanking you,

Yours faithfully,

(Signature , date & seal of authorized
Representative of the bidder)

पावर सेक्टर पूर्वी क्षेत्र (मुख्यालय)
POWER SECTOR EASTERN REGION, DJ-9/1, SALT LAKE CITY, KOLKATA - 700 091
फैक्स/Fax : (033) 23211960 फोन/Phone : बोर्ड/EPABX : 23211798/ 1691