



भारत हेवी इलेक्ट्रिकल्स लिमिटेड

(भारत सरकार का उपक्रम)

**BHARAT HEAVY ELECTRICALS LIMITED**

(A Govt. of India Undertaking)

**TCN - 03**

Ref: PSER:SCT:IIS-T1077:TCN-03

Date: 16-02-2010

| Sub | Tender change notice (TCN- 03).  |  |
|-----|--|--|
| Job | Erection, Testing & Commissioning of steam turbine & auxiliaries, generator & auxiliaries, BPTG, Turbo-Blowers, Electrical and C & I items at 3X 18 MW, power & blowing station, IISCO Burnpur, West Bengal. |  |
| Ref | 1.0  | Tender no PSER:SCT:IIS-T1077:10.   |
|     | 2.0  | BHEL's NIT, vide reference no Ref: PSER:SCT:IIS-T1077:10 Dated 27-01-2010        |
|     | 3.0  | BHEL's TCN-01, vide reference no Ref: PSER:SCT:IIS-T1077:TCN-01 Dated 06-02-2010 |
|     | 4.0  | BHEL's TCN-02, vide reference no Ref: PSER:SCT:IIS-T1077:TCN-02 Dated 12-02-2010 |
|     | 5.0  | Other references (if any).   |

With reference to above, following points, relevant to tender, may please be noted and complied with while submitting the offer.

- 1.0 Due date of submission of offer is extended from 17-02-2010 to 22-02-2010, 15-00 hrs.
- 2.0 Revised 'No deviation certificate' is attached. Bidder to submit 'No deviation certificate' as per attached format only.
- 3.0 All other terms & conditions shall remain unchanged.

Thanking you,

Yours faithfully,  
for BHARAT HEAVY ELECTRICALS LTD

**DGM (SCT)**

Encl:

- 1.0 Revised format of 'No deviation certificate'.

पावर सेक्टर पूर्वी क्षेत्र (मुख्यालय)

POWER SECTOR EASTERN REGION, DJ-9/1, SALT LAKE CITY, KOLKATA - 700 091

फैक्स/Fax : (033) 23211960 फोन/Phone : बोर्ड/EPABX : 23211798/ 1691

**FORMAT FOR NO DEVIATION CERTIFICATE**  
**(To be submitted in the bidder's letter head)**

BHARAT HEAVY ELECTRICALS LIMITED,  
Power Sector - Eastern Region,  
Plot no 9/1, DJ Block, Sector – II, Salt Lake City,  
Kolkata – 700 091

|     |  |   |
|-----|--|---|
| Sub | No Deviation Certificate.  |   |
| Job | Erection, Testing & Commissioning of steam turbine & auxiliaries, generator & auxiliaries, BPTG, Turbo-Blowers, Electrical and C & I items at 3X 18 MW, power & blowing station, IISCO Burnpur, West Bengal. |   |
| Ref | 1.0  | Tender no PSER:SCT:IIS-T1077:10.  |
|     | 2.0  | BHEL's NIT, vide reference no Ref: PSER:SCT:IIS-T1077:10 Dated 27-01-2010   |
|     | 03   | BHEL's TCN-01, vide reference no PSER:SCT:IIS-T1077:TCN-01, dated 06-02-10. |
|     | 04   | BHEL's TCN-02, vide reference no PSER:SCT:IIS-T1077:TCN-02, dated 12-02-10. |
|     | 05   | BHEL's TCN-03, vide reference no PSER:SCT:IIS-T1077:TCN-03, dated 16-02-10. |

Dear Sirs,

With reference to above, this is to confirm that as per tender conditions, we have visited site before submission of our offer and noted the job content & site conditions etc. We also confirm that we have not changed/ modified the tender documents as appeared in the website/ issued by you and in case of such observance at any stage, it shall be treated as null and void.

We hereby confirm that we have not taken any deviation from tender clauses together with other references as enumerated in the above referred NIT. We hereby confirm our unqualified acceptance to all terms & conditions, unqualified compliance to technical specification and acceptance to reverse auctioning process.

In the event of observance of any deviation in any part of our offer at a later date whether implicit or explicit, the deviations shall stand null & void.

We confirm to have submitted offer in accordance with tender instructions and as per aforesaid references.

Thanking you,

Yours faithfully,

(Signature, date & seal of authorized  
representative of the bidder)