



भारत हेवी इलेक्ट्रिकल्स लिमिटेड

(भारत सरकार का उपक्रम)

BHARAT HEAVY ELECTRICALS LIMITED

(A Govt. of India Undertaking)

TCN - 04

Ref: PSER:SCT:BRM-M1413:TCN-04

Date: 08-01-2013

Sub	Tender change notice (TCN) 04.	
Job	Design, engineering, manufacturing, supply/delivery, erection, commissioning, trial run, handing over to customer, etc of fuel oil unloading and storage system package for 2x 250 MW Barauni Extension Project at Begusarai, Bihar.	
Ref	1.0	Tender No. PSER:SCT:BRM-M1413:12
	2.0	BHEL's NIT, vide reference no PSER:SCT: BRM-M1413:3052, dated 06-12-2012.
	3.0	BHEL's TCN-01, vide reference no PSER:SCT:BRM-M1413:TCN-01, dated 07-12-2012.
	4.0	BHEL's TCN-02, vide reference no PSER:SCT:BRM-M1413:TCN-02, dated 24-12-2012.
	5.0	BHEL's TCN-03, vide reference no PSER:SCT:BRM-M1413:TCN-03, dated 01-01-2013.
	6.0	All other pertinent issues till date.

With reference to above, following points/ documents, relevant to tender, may please be noted and complied with while submitting offer.

- 1.0 Clarification to bidder's queries as per attached annexure-A.
- 2.0 Revised 'No deviation certificate' as per enclosed Annexure-2. Bidder shall submit no deviation certificate as per enclosed format only.
- 3.0 All other terms & conditions shall remain unchanged.

Thanking you,

Yours faithfully,
for BHARAT HYEAVY ELECTRICALS LTD

ENGR(SCT)

Encl

- 1.0 As above.

पावर सेक्टर पूर्वी क्षेत्र (मुख्यालय)

POWER SECTOR EASTERN REGION, DJ-9/1, SECTOR-II, SALT LAKE CITY, KOLKATA - 700 091

फैक्स/Fax : (033) 23211960

फोन/Phone : बोर्ड/EPABX : 23211691, 23211798, 23211796

JOB	Design, engineering, manufacturing, supply/delivery, erection, commissioning, trial run, handing over to customer, etc of fuel oil unloading and storage system package for 2x 250 MW Barauni Extension Project at Begusarai, Bihar.
TENDER NO	PSER:SCT:BRM-M1413:12

SL NO	CLARIFICATION/ AMENDMENT/ MODIFICATION		
1.0	VOLUME-II		
	CLAUSE NO	QUERY	CLARIFICATION/ AMENDMENT/ MODIFICATION
1.1	Annexure – A, Cl. 1.4.0 c) of Spec. No.: PE-TS-374-166-A001, Vol. IIB, Sec. C.	This is a lumpsum contract with no provision of unit price variation. As such you are requested to furnish exact location of pump house, unloading area, tank farm area, pipe route etc. Our proposal will be based on that. If you presume that there may be enough probability of layout / route / location change, this can be taken care of through unit price adjustment. Please confirm.	Location of P/H, unloading area and tank farm area shall be considered as per plot plan. Minor Changes in various facilities location may take place during detail engineering due to layout constraints, if any. However as mentioned in TP details no commercial implication will be entertained by BHEL for any change in TP by 50 m.
1.2	Annexure – A, Cl. 1.5.0 c) of Spec. No.: PE-TS-374-166-A001, Vol. IIB, Sec. C	This point is not clear. Kindly elaborate where this extra isolation valves are intended.	Isolation valve if any which will be necessitated to meet the system requirement during detail engineering shall be provided by bidder without any commercial implication.
2.0	General		
2.1	Bidder shall submit offer strictly in compliance with technical specification and tender terms along with amendment/ clarifications issued till date within the due date.		
2.2	All other terms & conditions shall remain unchanged.		

पावर सेक्टर पूर्वी क्षेत्र (मुख्यालय)

POWER SECTOR EASTERN REGION, SECTOR-II, DJ-9/1, SECTOR-II, SALT LAKE CITY, KOLKATA - 700 091

फैक्स/Fax : (033) 23211960

फोन/Phone : बोर्ड/EPABX : 23216130/ 23216134/ 23216135

FORMAT FOR NO DEVIATION CERTIFICATE
(To be submitted in the bidder's letter head)

BHARAT HEAVY ELECTRICALS LIMITED,
 Power Sector - Eastern Region,
 Plot no 9/1, DJ Block, Sector – II, Salt Lake City,
 Kolkata – 700 091

Sub	No Deviation Certificate.	
Job	Design, engineering, manufacturing, supply/delivery, erection, commissioning, trial run, handing over to customer, etc of fuel oil unloading and storage system package for 2x 250 MW Barauni Extension Project at Begusarai, Bihar.	
Ref	1.0	Tender no PSER:SCT:BRM-M1413:12
	2.0	BHEL's NIT, vide reference no PSER:SCT:BRM-M1413:3052, dated 06-12-2012.
	3.0	BHEL's TCN-01, vide reference no PSER:SCT:BRM-M1413:TCN-01, dated 07-12-2012.
	4.0	BHEL's TCN-02, vide reference no PSER:SCT:BRM-M1413:TCN-02, dated 24-12-2012.
	5.0	BHEL's TCN-03, vide reference no PSER:SCT:BRM-M1413:TCN-03, dated 01-01-2013.
	6.0	BHEL's TCN-04, vide reference no PSER:SCT:BRM-M1413:TCN-04, dated 08-01-2013.
	7.0	All other pertinent issues till date.

Dear Sirs,

With reference to above, this is to confirm that as per tender conditions, we have visited site before submission of our offer and noted the job content & site conditions etc. We also confirm that we have not changed/ modified the tender documents as appeared in the website/ issued by you and in case of such observance at any stage, it shall be treated as null and void.

We hereby confirm that we have not taken any deviation from tender clauses together with other references as enumerated in the above referred NIT. We hereby confirm our unqualified acceptance to all terms & conditions, unqualified compliance to technical specification, integrity pact (if applicable) and acceptance to reverse auctioning process.

In the event of observance of any deviation in any part of our offer at a later date whether implicit or explicit, the deviations shall stand null & void.

We confirm to have submitted offer in accordance with tender instructions and as per aforesaid references.

Thanking you,

Yours faithfully,

(Signature, date & seal of authorized
representative of the bidder)

<p>पावर सेक्टर पूर्वी क्षेत्र (मुख्यालय) POWER SECTOR EASTERN REGION DJ-9/1, SECTOR-II, SALT LAKE CITY, KOLKATA - 700 091 फैक्स/Fax : (033) 23211960 फोन/Phone : बोर्ड/EPABX : 23211691, 23211798, 23211796</p>
