



भारत हेवी इलेक्ट्रिकल्स लिमिटेड

(भारत सरकार का उपक्रम)

BHARAT HEAVY ELECTRICALS LIMITED

(A Govt. of India Undertaking)

TCN – 04

Ref: PSER:SCT:SNG-M1429:TCN-04

Date: 12-04-2013

Sub	Tender Change Notice (TCN-04).	
Job	Design, engineering, manufacturing, supply/ delivery, erection, commissioning, trial run, handing over to customer etc. of Ventilation System for 2x600 MW unit at Singareni STPP, Adilabad,A.P.	
Ref	01	Tender No. PSER:SCT:SNG-M1429:13.
	02	BHEL's NIT, vide reference no PSER: SCT:SNG-M1429:3128, dated 06-02-2013.
	03	BHEL's TCN-01, vide reference no PSER: SCT: SNG-M1429:TCN-01, dated 21-02-2013.
	04	BHEL's TCN-02, vide reference no PSER: SCT: SNG-M1429:TCN-02, dated 16-03-2013.
	05	BHEL's TCN-03, vide reference no PSER: SCT: SNG-M1429:TCN-03, dated 02-04-2013.
	06	Other references (if any).

With reference to above, following points, relevant to tender, may please be noted and complied with while submitting offer.

- 1.0 Clarifications to bidder's queries (**ANNEXURE-I**) has been attached herewith.
- 2.0 Revised 'No deviation certificate' is attached. Bidder to submit 'No deviation certificate' as per attached format only.
- 3.0 All other terms & conditions shall remain unchanged.

Thanking you,

Yours faithfully,
for BHARAT HEAVY ELECTRICALS LTD

ENGINEER (SCT)

Encl

1.0 As above.

पावर सेक्टर पूर्वी क्षेत्र (मुख्यालय)

POWER SECTOR EASTERN REGION, DJ-9/1, SALT LAKE CITY, KOLKATA - 700 091

फैक्स/Fax : (033) 23211960

फोन/Phone : बोर्ड/EPABX : 23211798/ 1691

FORMAT FOR NO DEVIATION CERTIFICATE
(To be submitted in the bidder's letter head)

BHARAT HEAVY ELECTRICALS LIMITED,
Power Sector - Eastern Region,
Plot no 9/1, DJ Block, Sector – II, Salt Lake City,
Kolkata – 700 091

Sub	No Deviation Certificate.	
Job	Design, engineering, manufacturing, supply/ delivery, erection, commissioning, trial run, handing over to customer etc of Ventilation System for 2x600 MW unit at Singareni STPP, Adilabad,A.P.	
Ref	1.0	Tender No. PSER:SCT:SNG-M1429:13.
	2.0	BHEL's NIT, vide reference no PSER: SCT:SNG-M1429:3128, dated 06-02-2013.
	3.0	BHEL's TCN-01, vide reference no: Ref: PSER:SCT:SNG-M1429:TCN-01, Dated 21.02.2013.
	4.0	BHEL's TCN-02, vide reference no: Ref: PSER:SCT:SNG-M1429:TCN-02, Dated 16.03.2013.
	5.0	BHEL's TCN-03, vide reference no: Ref: PSER:SCT:SNG-M1429:TCN-03, Dated 02.04.2013.
	6.0	BHEL's TCN-04, vide reference no: Ref: PSER:SCT:SNG-M1429:TCN-04, Dated 12.04.2013.
	7.0	Other references (if any).

Dear Sirs,

With reference to above, this is to confirm that as per tender conditions, we have visited site before submission of our offer and noted the job content & site conditions etc. We also confirm that we have not changed/ modified the tender documents as appeared in the website/ issued by you and in case of such observance at any stage, it shall be treated as null and void.

We hereby confirm that we have not taken any deviation from tender clauses together with other references as enumerated in the above referred NIT. We hereby confirm our unqualified acceptance to all terms & conditions, unqualified compliance to technical specification, integrity pact (if applicable) and acceptance to reverse auctioning process.

In the event of observance of any deviation in any part of our offer at a later date whether implicit or explicit, the deviations shall stand null & void.

We confirm to have submitted offer in accordance with tender instructions and as per aforesaid references.

Thanking you,

Yours faithfully,

(Signature, date & seal of authorised
representative of the contractor)

पावर सेक्टर पूर्वी क्षेत्र (मुख्यालय)

POWER SECTOR EASTERN REGION, DJ-9/1, SALT LAKE CITY, KOLKATA - 700 091

फैक्स/Fax : (033) 23211960

फोन/Phone : बोर्ड/EPABX : 23211798/ 1691

2X600 MW SINGARENI STPP,ADILABAD,A. P. - VENTILATION SYSTEM**BHEL CLARIFICATION TO TECHNICAL SPECIFICATION (ANNEXURE-I)****TENDER NO. PSER:SCT:SNG-M1429:13**

Sl. No.	Clause No.	Page No.	BIDDER'S QUERY	BHEL Clarification
1	• Clause No : 5 - Section –C1	Page No : 7 of 11	Instrument for control of Air Washer unit to be consider as per your P & I diagram only. Additional instrument for interface with DDCMIS (If required) will be provided by client.	As per Clause No : 5 - Section –C1 – Page No : 7 of 11 of specification for interface with DDCMIS, if additional Instruments are required, the same shall be in bidder scope of supply. BHEL will provide the control system only.
2	• Clause No : 6.1.9 - Section –C1	Page No : 7 of 11	Thickness of GI ducting mentioned in the referred Clause 1 mm and 1.25 mm as per size of duct whereas in your Price Schedule REV – 02 under S.L. NO – 1.1.4.3 and 1.1.4.4 ,you have indicated quantity of ducting against 22 G (0.8 mm) and 24 G(0.63 mm) of GI sheet.	PI follow BOQ.
3	• Clause No : 9.06.04 - Section – VI- Part –B	Page No - 22 of 32	Material of Grilles / Diffusers mentioned in your referred specification is extruded AL, whereas in your price schedule ,it has been mentioned as MS under S.L.NO. 1.1.6 and 1.1.7.	Kindly note that Material for the Grilles / Diffusers shall be as per Clause No: 9.06.04 - Section – VI- Part –B – Page No -22 of 32 (extruded Aluminum of minimum 1.2 mm thick with powder coating).