



भारत हेवी इलेक्ट्रिकल्स लिमिटेड

(भारत सरकार का उपक्रम)

BHARAT HEAVY ELECTRICALS LIMITED

(A Govt. of India Undertaking)

TCN - 04

Ref: PSER:SCT:SRG-M1552:TCN-04

Date: 24-06-2014

Sub	Tender change notice (TCN) 04	
Job	Design, engineering, manufacturing, supply/delivery, erection & commissioning of Electro chlorination Package for RRVUNL, 2x660 MW, Stage-V, Unit # 7 & 8 Suratgarh Super Critical TPS, Rajasthan	
Ref	1.0	Tender no. PSER:SCT:SRG-M1552:14
	2.0	BHEL's NIT, vide reference no PSER:SCT:SRG-M1552:3752, dated 20-05-2014.
	3.0	BHEL's TCN-01, vide reference no: Ref: PSER:SCT:SRG-M1552:TCN-01, Dated 03.06.2014.
	4.0	BHEL's TCN-02, vide reference no: Ref: PSER:SCT:SRG-M1552:TCN-02, Dated 10.06.2014.
	5.0	BHEL's TCN-03, vide reference no: Ref: PSER:SCT:SRG-M1552:TCN-03, Dated 18.06.2014.
	6.0	All other pertinent issues till date.

With reference to above, following points/ documents, relevant to tender, may please be noted and complied with while submitting offer.

- 1.0 Amendment-2 to tech. spec. has been attached herewith.
- 2.0 Revised 'No deviation certificate' is attached. Bidder to submit 'No deviation certificate' as per attached format only.
- 3.0 All other terms & conditions shall remain unchanged.

Thanking you,

Yours faithfully,
for BHARAT HYEAVY ELECTRICALS LTD

SR. ENGR (SCT)

Encl :

1. Revised 'No deviation certificate' format (ANNEX-II).
2. Amendment-2 to tech. spec

पावर सेक्टर पूर्वी क्षेत्र (मुख्यालय)

POWER SECTOR EASTERN REGION, DJ-9/1, SECTOR-II, SALT LAKE CITY, KOLKATA - 700 091

फैक्स/Fax : (033) 23211960

फोन/Phone : बोर्ड/EPABX : 23211691, 23211798, 23211796

FORMAT FOR NO DEVIATION CERTIFICATE
(To be submitted in the bidder's letter head)

BHARAT HEAVY ELECTRICALS LIMITED,
Power Sector - Eastern Region,
Plot no 9/1, DJ Block, Sector – II, Salt Lake City,
Kolkata – 700 091

Sub	No Deviation Certificate.	
Job	Design, engineering, manufacturing, supply/delivery, erection & commissioning of Electro chlorination Package for RRVUNL, 2x660 MW, Stage-V, Unit # 7 & 8 Suratgarh Super Critical TPS, Rajasthan	
Ref	1.0	Tender No. PSER:SCT:SRG-M1552:14
	2.0	BHEL's NIT, vide reference no PSER:SCT:SRG-M1552:3752, dated 20-05-2014.
	3.0	BHEL's TCN-01, vide reference no: Ref: PSER:SCT:SRG-M1552:TCN-01, Dated 03.06.2014.
	4.0	BHEL's TCN-02, vide reference no: Ref: PSER:SCT:SRG-M1552:TCN-02, Dated 10.06.2014.
	5.0	BHEL's TCN-03, vide reference no: Ref: PSER:SCT:SRG-M1552:TCN-03, Dated 18.06.2014.
	6.0	BHEL's TCN-04, vide reference no: Ref: PSER:SCT:SRG-M1552:TCN-04, Dated 24.06.2014.
	7.0	Other references (if any).

Dear Sirs,

With reference to above, this is to confirm that as per tender conditions, we have visited site before submission of our offer and noted the job content & site conditions etc. We also confirm that we have not changed/ modified the tender documents as appeared in the website/ issued by you and in case of such observance at any stage, it shall be treated as null and void.

We hereby confirm that we have not taken any deviation from tender clauses together with other references as enumerated in the above referred NIT. We hereby confirm our unqualified acceptance to all terms & conditions, unqualified compliance to technical specification, integrity pact (if applicable) and acceptance to reverse auctioning process.

In the event of observance of any deviation in any part of our offer at a later date whether implicit or explicit, the deviations shall stand null & void.

We confirm to have submitted offer in accordance with tender instructions and as per aforesaid references.

Thanking you,

Yours faithfully,

(Signature, date & seal of authorised
representative of the contractor)

पावर सेक्टर पूर्वी क्षेत्र (मुख्यालय)

POWER SECTOR EASTERN REGION, DJ-9/1, SALT LAKE CITY, KOLKATA - 700 091

फैक्स/Fax : (033) 23211960

फोन/Phone : बोर्ड/EPABX : 23211691



**AMENDMENT ON TECHNICAL SPECIFICATION FOR
ELECTRO CHLORINATION PLANT
2X660 MW SURATGARH SUPER CRITICAL TPS,
STAGE - V UNIT 7& 8**

SPECIFICATION NO. PE-TS-392-174-12000A-A001

AMMENDMENT NO 2

Date 23.06.14

Page 1 of 2

AMENDMENT 2



AMENDMENT ON TECHNICAL SPECIFICATION FOR
ELECTRO CHLORINATION PLANT
2X660 MW SURATGARH SUPER CRITICAL TPS,
STAGE - V UNIT 7& 8

SPECIFICATION NO. PE-TS-392-174-12000A-A001

AMMENDMENT NO 2

Date 23.06.14

Page 2 of 2

Bidder to note that existing clauses as appearing in the specification stands deleted and clauses mentioned in "Modified to" column shall be applicable and complied by the bidder.

SI no	Vol No	Section /Description	Clause no	Page no	Existing	Modified to
1.	IIB	Sec C1	30	14 of 401	One no EOT Crane of 2 Ton capacity with trailing cable and supporting structure	One no EOT Crane of 5 Ton capacity and one number crane of 2 Ton capacity each with trailing cable and supporting structure
2.	IIB	Sec C-1	25.0.b	32 of 401	Number : One(1)	Number : Two (2) number (one number for handling electrolyzers & Transformers /Rectifiers and one number for handling salt)
3.	IIB	Sec C-1	25.0.c	32 of 401	Capacity : 2 ton	Capacity: minimum 5 ton capacity for handling electrolyzers & Transformers/ Rectifiers and minimum 2 ton capacity for handling salt.