



भारत हेवी इलेक्ट्रिकल्स लिमिटेड

(भारत सरकार का उपक्रम)

BHARAT HEAVY ELECTRICALS LIMITED

(A Govt. of India Undertaking)

TCN – 06

Ref: PSER:SCT:NKP-B1744:TCN-06

Date: 14-06-2016

Sub	Tender change notice (TCN) 06
Job	Erection, Testing and Commissioning of Main Boilers and Auxiliaries covering Structures, Pressure Parts, Rotating Machines, Ducts, ESP, Fuel firing system, Various SG/Critical/Misc. Piping etc. along with integrated Mill Bunker Structures of Unit # 2 including fabrication , erection and painting of Fire Water Storage Tanks at of 3x660 MW North Karanpura Project, Jharkhand.
Ref	1.0 Tender No. PSER:SCT: NKP-B1744:16
	2.0 BHEL's NIT, vide reference no PSER:SCT:NKP-B1744:5029 Date: 20-05-2016
	3.0 BHEL's TCN-01, vide reference no PSER:SCT:NKP-B1744:TCN-01, dated 25-05-2016.
	4.0 BHEL's TCN-02, vide reference no PSER:SCT:NKP-B1744:TCN-02, dated 26-05-2016.
	5.0 BHEL's TCN-03, vide reference no PSER:SCT:NKP-B1744:TCN-03, dated 30-05-2016
	6.0 BHEL's TCN-04, vide reference no PSER:SCT:NKP-B1744:TCN-04, dated 08-06-2016
	7.0 BHEL's TCN-05, vide reference no PSER:SCT:NKP-B1744:TCN-05, dated 10-06-2016
	8.0 All other pertinent issues till date.

With reference to above, following points/ documents, relevant to tender, may please be noted and complied with while submitting offer.

- 1.0 Extension of due date of offer submission from 14-06-2016 to **18-06-2016 (15:00 Hrs)**
- 2.0 Clarification to bidder's query as per attached Annexure-A.
- 3.0 Revised 'No deviation certificate' as per enclosed Annexure-2. Bidder shall submit no deviation certificate as per enclosed format only.
- 4.0 All other terms & conditions shall remain unchanged.

Thanking you,

Yours faithfully,
for BHARAT HEAVY ELECTRICALS LTD

SR.ENGR (SCT)

Encl : As above.

पावर सेक्टर पूर्वी क्षेत्र (मुख्यालय)

POWER SECTOR EASTERN REGION, DJ-9/1, SECTOR-II, SALT LAKE CITY, KOLKATA - 700 091

फैक्स/Fax : (033) 23211960

फोन/Phone : बोर्ड/EPABX : 23211691, 23211798, 23211796

FORMAT FOR NO DEVIATION CERTIFICATE
(To be submitted in the bidder's letter head)

BHARAT HEAVY ELECTRICALS LIMITED,
Power Sector - Eastern Region,
Plot no 9/1, DJ Block, Sector – II, Salt Lake City,
Kolkata – 700 091

Sub	No Deviation Certificate.	
Job	Erection, Testing and Commissioning of Main Boilers and Auxiliaries covering Structures, Pressure Parts, Rotating Machines, Ducts, ESP, Fuel firing system, Various SG/Critical/Misc. Piping etc. along with integrated Mill Bunker Structures of Unit # 2 including fabrication , erection and painting of Fire Water Storage Tanks at of 3x660 MW North Karanpura Project, Jharkhand.	
Ref	1.0	Tender No. PSER:SCT: NKP-B1744:16
	2.0	BHEL's NIT, vide reference no PSER:SCT:NKP-B1744:5029 Date: 20-05-2016
	3.0	BHEL's TCN-01, vide reference no PSER:SCT:NKP-B1744:TCN-01, dated 25-05-2016.
	4.0	BHEL's TCN-02, vide reference no PSER:SCT:NKP-B1744:TCN-02, dated 26-05-2016.
	5.0	BHEL's TCN-03, vide reference no PSER:SCT:NKP-B1744:TCN-03, dated 30-05-2016
	6.0	BHEL's TCN-04, vide reference no PSER:SCT:NKP-B1744:TCN-04, dated 08-06-2016
	7.0	BHEL's TCN-05, vide reference no PSER:SCT:NKP-B1744:TCN-05, dated 10-06-2016
	8.0	BHEL's TCN-06, vide reference no PSER:SCT:NKP-B1744:TCN-06, dated 14-06-2016
	9.0	All other pertinent issues till date.

Dear Sirs,

With reference to above, this is to confirm that as per tender conditions, we have visited site before submission of our offer and noted the job content & site conditions etc. We also confirm that we have not changed/ modified the tender documents as appeared in the website/ issued by you and in case of such observance at any stage, it shall be treated as null and void.

We hereby confirm that we have not taken any deviation from tender clauses together with other references as enumerated in the above referred NIT. We hereby confirm our unqualified acceptance to all terms & conditions, unqualified compliance to technical specification, integrity pact (if applicable) and acceptance to reverse auctioning process.

In the event of observance of any deviation in any part of our offer at a later date whether implicit or explicit, the deviations shall stand null & void.

We confirm to have submitted offer in accordance with tender instructions and as per aforesaid references.

Thanking you,

Yours faithfully,

(Signature, date & seal of authorized
representative of the bidder)

<p>पावर सेक्टर पूर्वी क्षेत्र (मुख्यालय) POWER SECTOR EASTERN REGION DJ-9/1, SECTOR-II, SALT LAKE CITY, KOLKATA - 700 091 फैक्स/Fax : (033) 23211960 फोन/Phone : बोर्ड/EPABX : 23211691, 23211798, 23211796</p>

ANNUXURE-A TO TCN-06

Erection, Testing and Commissioning of Main Boilers and Auxiliaries covering Structures, Pressure Parts, Rotating Machines, Ducts, ESP, Fuel firing system, Various SG/Critical/Misc. Piping etc. along with integrated Mill Bunker Structures of Unit # 2 including fabrication , erection and painting of Fire Water Storage Tanks at of 3x660 MW North Karanpura Project, Jharkhand.

Tender No. PSER:SCT: NKP-B1744:16

SI No	Reference clause of Tender Document	Existing provision	Bidder's Query	BHEL's clarification
1	VOL-III, R-0, serial No. 1.13		Refer volume – III, Price Schedule for above referred tender, against serial No. 1.13, fabrication and installation of fire water storage tank under quantity column it is mentioned as one and in second half it is mentioned as LS. Please confirm that the lump sum rate to be given is for two tanks or one tank as quantity is two nos. as mentioned in clause no. 3 & 5 on page of 1 & 2 of 90 of TCC of tender document.	Total lumpsum price for the works of 2 nos fire water storage tank is to be quoted against this item.
2	Page-86 of TCC	Induction Heating Equipment with all required spares, consumables and accessories for P-91 pipe welding.Power rating:	As per TCC & TCN-05, Contractor is supposed to bring 05 nos of Heating Induction machine of capacity 75 KW. We are done with market survey & the maximum capacity available is of 35 KW only.	Induction Heating machine of suitable capacity for P-91 pipe welding.Min. 05 nos. required. Deployment qty. may require to be increased as per job requirement and decision/direction of BHEL.