



# भारत हेवी इलेक्ट्रिकल्स लिमिटेड

(भारत सरकार का उपक्रम)

## BHARAT HEAVY ELECTRICALS LIMITED

(A Govt. of India Undertaking)

TCN – 07

Ref: PSER:SCT:NKP-M1634:TCN-07

Date: 15-01-2015

|     |   |   |
|-----|---|---|
| Sub | Tender change notice (TCN) 07   |   |
| Job | Design, engineering, manufacturing, supply, erection, testing, commissioning, etc of CPU System for 3x660 MW units at North Karanpura super thermal power project, Jharkhand. |   |
| Ref | 1.0   | Tender no PSER:SCT:NKP-M1634:14   |
|     | 2.0   | BHEL's NIT, vide reference no PSER:SCT: NKP-M1634:4111, dated 09-12-2014      |
|     | 3.0   | BHEL's TCN-01, vide reference no PSER:SCT:NKP-M1634:TCN-01, dated 18-12-2014. |
|     | 4.0   | BHEL's TCN-02, vide reference no PSER:SCT:NKP-M1634:TCN-02, dated 24-12-2014. |
|     | 5.0   | BHEL's TCN-03, vide reference no PSER:SCT:NKP-M1634:TCN-03, dated 02-01-2015. |
|     | 6.0   | BHEL's TCN-04, vide reference no PSER:SCT:NKP-M1634:TCN-04, dated 07-01-2015. |
|     | 7.0   | BHEL's TCN-05, vide reference no PSER:SCT:NKP-M1634:TCN-05, dated 12-01-2015. |
|     | 8.0   | BHEL's TCN-06, vide reference no PSER:SCT:NKP-M1634:TCN-06, dated 14-01-2015. |
|     | 9.0   | All other pertinent issues till date.   |

With reference to above, following points/ documents, relevant to tender, may please be noted and complied with while submitting offer.

- 1.0 Clarification to bidder's queries as per attached Annexure-A.
- 2.0 Revised 'No deviation certificate' as per enclosed Annexure-2. Bidder shall submit no deviation certificate as per enclosed format only.
- 3.0 All other terms & conditions shall remain unchanged.

Thanking you,

Yours faithfully,  
for BHARAT HEAVY ELECTRICALS LTD

SR.ENGR (SCT)

Encl

- 1.0 As above.

पावर सेक्टर पूर्वी क्षेत्र (मुख्यालय)

POWER SECTOR EASTERN REGION, DJ-9/1, SECTOR-II, SALT LAKE CITY, KOLKATA - 700 091

फैक्स/Fax : (033) 23211960

फोन/Phone : बोर्ड/EPABX : 23211691, 23211798, 23211796

**FORMAT FOR NO DEVIATION CERTIFICATE**  
**(To be submitted in the bidder's letter head)**

BHARAT HEAVY ELECTRICALS LIMITED,  
Power Sector - Eastern Region,  
Plot no 9/1, DJ Block, Sector – II, Salt Lake City,  
Kolkata – 700 091

|     |   |   |
|-----|---|---|
| Sub | No Deviation Certificate.   |   |
| Job | Design, engineering, manufacturing, supply, erection, testing, commissioning, etc of CPU System for 3x660 MW units at North Karanpura super thermal power project, Jharkhand. |   |
| Ref | 1.0   | Tender no PSER:SCT:NKP-M1634:14   |
|     | 2.0   | BHEL's NIT, vide reference no PSER:SCT: NKP-M1634:4111, dated 09-12-2014      |
|     | 3.0   | BHEL's TCN-01, vide reference no PSER:SCT:NKP-M1634:TCN-01, dated 18-12-2014. |
|     | 4.0   | BHEL's TCN-02, vide reference no PSER:SCT:NKP-M1634:TCN-02, dated 24-12-2014. |
|     | 5.0   | BHEL's TCN-03, vide reference no PSER:SCT:NKP-M1634:TCN-03, dated 02-01-2015. |
|     | 6.0   | BHEL's TCN-04, vide reference no PSER:SCT:NKP-M1634:TCN-04, dated 07-01-2015. |
|     | 7.0   | BHEL's TCN-05, vide reference no PSER:SCT:NKP-M1634:TCN-05, dated 12-01-2015. |
|     | 8.0   | BHEL's TCN-06, vide reference no PSER:SCT:NKP-M1634:TCN-06, dated 14-01-2015. |
|     | 9.0   | BHEL's TCN-07, vide reference no PSER:SCT:NKP-M1634:TCN-07, dated 15-01-2015. |
|     | 10.0  | All other pertinent issues till date.   |

Dear Sirs,

With reference to above, this is to confirm that as per tender conditions, we have visited site before submission of our offer and noted the job content & site conditions etc. We also confirm that we have not changed/ modified the tender documents as appeared in the website/ issued by you and in case of such observance at any stage, it shall be treated as null and void.

We hereby confirm that we have not taken any deviation from tender clauses together with other references as enumerated in the above referred NIT. We hereby confirm our unqualified acceptance to all terms & conditions, unqualified compliance to technical specification, integrity pact (if applicable) and acceptance to reverse auctioning process.

In the event of observance of any deviation in any part of our offer at a later date whether implicit or explicit, the deviations shall stand null & void.

We confirm to have submitted offer in accordance with tender instructions and as per aforesaid references.

Thanking you,

Yours faithfully,

(Signature, date & seal of authorized representative of the bidder)

पावर सेक्टर पूर्वी क्षेत्र (मुख्यालय)

POWER SECTOR EASTERN REGION DJ-9/1, SECTOR-II, SALTLAKE CITY, KOLKATA - 700 091

फैक्स/Fax : (033) 23211960

फोन/Phone : बोर्ड/EPABX : 23211691, 23211798, 23211796

## ANNEXURE-A TO TCN-07

|           |   |
|-----------|---|
| JOB       | Design, engineering, manufacturing, supply, erection, testing, commissioning, etc of CPU System for 3x660 MW units at North Karanpura super thermal power project, Jharkhand. |
| TENDER NO | PSER:SCT:NKP-M1634:14   |

| SI no | Reference clause of tender document                               | Existing provision   | Bidder's query  | BHEL's clarification  |
|-------|---|--|---|---|
| 1     | Volume II-B, Section-D1, Clause No. 20.00.00 (e), Page 152 of 505 | Bidder to check influent water quality indicated and adopt higher valves, if felt necessary to meet specified effluent quality                 | Please note that it cannot be done by the CPU Supplier. If any change is needed, then BTG / EPC Vendor is the best agency to make any change, if needed.  | Bidder to please follow the condensate influent & effluent quality as indicated tender technical specification.   |
| 2     | Volume II-B, Section-C1, Clause No. 16, Page 20 of 505            | Lime Tank for regeneration has been included in CPU scope (probably to be used for common N-PIT (DM & CPU) regeneration waste neutralization). | Kindly indicate the quantity of Lime needed / capacity of Lime Tank for neutralization of regeneration waste, both of DM & CPU (DM is not known to us). Please also clarify whether Co2 breather is necessary for Lime Tank as indicated in the specifications. | The capacity of the lime tank has been indicated at Volume II-B, Section-C1, Clause No. 3.8 (iv), Page 87 of 505. Bidder to please follow tender technical specification. |