



भारत हेवी इलेक्ट्रिकल्स लिमिटेड

(भारत सरकार का उपक्रम)

BHARAT HEAVY ELECTRICALS LIMITED

(A Govt. of India Undertaking)

TCN - 08

Ref: PSER:SCT:SNG-M1625:TCN-08

Date: 6/12/2014

Sub	Tender change notice (TCN) 08	
Job	Design, engineering, manufacturing, supply/Delivery, erection, Commissioning, trial run, handing over to customer etc of ventilation System for 2x600MW Unit at Singareni STPP, Adilabad , Andhra pradesh .	
Ref	1.0	Tender no PSER:SCT:SNG-M1625:14
	2.0	BHEL's NIT, vide ref no PSER:SCT:SNG-M1625:4039 Dated 11/11/2014
	3.0	BHEL's TCN 01 dated Ref: PSER:SCT:SNG-M1625:TCN-01 Date: 12/11/2014
	4.0	BHEL's TCN 02 dated ref:PSER:SCT:SNG-M1625:TCN-02 date 18/11/2014
	5.0	BHEL's TCN 03 dated ref:PSER:SCT:SNG-M1625:TCN-03 date 20/11/2014
	6.0	BHEL's TCN 04 dated PSER:SCT:SNG-M1625:TCN-04 Date: 25/11/2014
	7.0	BHEL's TCN 05 dated PSER:SCT:SNG-M1625:TCN-05 Date: 27/11/2014
	8.0	BHEL's TCN 06 dated PSER:SCT:SNG-M1625:TCN-06 Date: 28/11/2014
	9.0	BHEL's TCN 07 ref PSER:SCT:SNG-M1625:TCN-07 dated 2/12/14
	10.0	Other references (if any).

With reference to above, following points , relevant to tender, may please be noted and complied with while submitting offer.

- 1.0 Due date of submission is extended from 6/12/14 to 8/12/14 at 15-00 Hrs.
- 2.0 Revised 'No deviation certificate' is attached. Bidder to submit 'No deviation certificate' as per attached Format only .
- 3.0 All other terms & conditions shall remain unchanged .

Thanking you,

Yours faithfully,
For BHARAT HEAVY ELECTRICALS LTD

DY MGR (SCT)

Encl

- 1.0 Revised 'No deviation certificate' format.

पावर सेक्टर पूर्वी क्षेत्र (मुख्यालय)

POWER SECTOR EASTERN REGION, DJ-9/1, SALT LAKE CITY, KOLKATA - 700 091

फैक्स/Fax : (033) 23211960 फोन/Phone : बोर्ड/EPABX : 23211495/ 1691

FORMAT FOR NO DEVIATION CERTIFICATE
(To be submitted in the bidder's letter head)

BHARAT HEAVY ELECTRICALS LIMITED,
Power Sector - Eastern Region,
Plot no 9/1, DJ Block, Sector – II, Salt Lake City,
Kolkata – 700 091

Sub	No Deviation Certificate.	
Job	Design, engineering, manufacturing, supply/Delivery, erection, Commissioning, trial run, handing over to customer etc of ventilation System for 2x600MW Unit at Singareni STPP, Adilabad , Andhra pradesh .	
Ref	1.0	Tender no PSER:SCT:SNG-M1625:14
	2.0	BHEL's NIT, vide ref no PSER:SCT:SNG-M1625:4039 Dated 11/11/2014
	3.0	BHEL's TCN-01 , vide ref no PSER:SCT:SNG-M1625:TCN-01 Dated 12/11/2014.
	4.0	BHEL's TCN-02, vide ref no PSER:SCT:SNG-M1625:TCN-02 Dated 18/11/2014
	5.0	BHEL's TCN-03, vide ref no PSER:SCT:SNG-M1625:TCN-03 Dated 20/11/2014
	6.0	BHEL's TCN-04, vide ref no PSER:SCT:SNG-M1625:TCN-04 Dated 25/11/2014
	7.0	BHEL's TCN 05 vide ref no PSER:SCT:SNG-M1625:TCN-05 Date: 27/11/2014
	8.0	BHEL's TCN 06 vide ref no PSER:SCT:SNG-M1625:TCN-06 Date: 28/11/2014
	9.0	BHEL's TCN 07 vide ref no PSER:SCT:SNG-M1625:TCN-07 Date: 2/12/2014
	10.0	BHEL's TCN 08 vide ref no PSER:SCT:SNG-M1625:TCN-08 Date: 6/12/2014
	11.0	Other references (if any) .

Dear Sirs,

With reference to above, this is to confirm that as per tender conditions, we have visited site before submission of our offer and noted the job content & site conditions etc. We also confirm that we have not changed/ modified the tender documents as appeared in the website/ issued by you and in case of such observance at any stage, it shall be treated as null and void .

We hereby confirm that we have not taken any deviation from tender clauses together with other references as enumerated in the above referred NIT. We hereby confirm our unqualified acceptance to all terms & conditions, unqualified compliance to technical specification, Integrity Pact (If applicable) and acceptance to reverse auctioning process.

In the event of observance of any deviation in any part of our offer at a later date whether implicit or explicit, the deviations shall stand null & void.

We confirm to have submitted offer in accordance with tender instructions and as per aforesaid references.

Thanking you,

Yours faithfully,

(Signature , date & seal of authorized
Representative of the bidder)

पावर सेक्टर पूर्वी क्षेत्र (मुख्यालय)
POWER SECTOR EASTERN REGION, DJ-9/1, SALT LAKE CITY, KOLKATA - 700 091
फैक्स/Fax : (033) 23211960 फोन/Phone : बोर्ड/EPABX : 23211798/ 1691