



भारत हेवी इलेक्ट्रिकल्स लिमिटेड

(भारत सरकार का उपक्रम)

BHARAT HEAVY ELECTRICALS LIMITED

(A Govt. of India Undertaking)

TCN - 11

Ref: PSER:SCT: NKP-M1738:TCN-11

Date: 01-06-2016

Sub	Tender Change Notice (TCN) - 11	
Job	Design, Engineering, Manufacturing, Supply/Delivery, Erection, Commissioning, Trial Run, Handing Over to Customer etc of WATER TREATMENT PACKAGES (PRE TREATMENT PLANT, EFFLUENT TREATMENT PLANT & SEWAGE TREATMENT PLANT) including supervision of civil construction work for 3X 660 MW North Karanpura Super Thermal Power Project at Jharkhand.	
Ref	1.0	Tender No. PSER:SCT:NKP-M1738:16
	2.0	BHEL's NIT, vide reference no PSER:SCT: NKP-M1738:4966, Dated 05-04-2016.
	3.0	BHEL's TCN-01, vide reference PSER:SCT: NKP-M1738:TCN-01, Dated 06-04-2016
	4.0	BHEL's TCN-02, vide reference PSER:SCT: NKP-M1738:TCN-02, Dated 12-04-2016
	5.0	BHEL's TCN-03, vide reference PSER:SCT: NKP-M1738:TCN-03, Dated 23-04-2016
	6.0	BHEL's TCN-04, vide reference PSER:SCT: NKP-M1738:TCN-04, Dated 28-04-2016
	7.0	BHEL's TCN-05, vide reference PSER:SCT: NKP-M1738:TCN-05, Dated 02-05-2016
	8.0	BHEL's TCN-06, vide reference PSER:SCT: NKP-M1738:TCN-06, Dated 11-05-2016
	9.0	BHEL's TCN-07, vide reference PSER:SCT: NKP-M1738:TCN-07, Dated 13-05-2016
	10.0	BHEL's TCN-08, vide reference PSER:SCT: NKP-M1738:TCN-08, Dated 16-05-2016
	11.0	BHEL's TCN-09, vide reference PSER:SCT: NKP-M1738:TCN-09, Dated 17-05-2016
	12.0	BHEL's TCN-10, vide reference PSER:SCT: NKP-M1738:TCN-10, Dated 27-05-2016
	13.0	All other pertinent issues till date.

With reference to above, following points, relevant to tender, may please be noted and complied with while submitting the offer.

1. Clarification of Bidder's queries attached vide **Annexure-A to TCN-11**.
2. Revised 'No deviation certificate' as per enclosed Annexure-2. Bidder shall submit no deviation certificate as per enclosed format only.
3. All other terms & conditions shall remain unchanged.

Thanking you,

Yours faithfully,
for BHARAT HEAVY ELECTRICALS LTD

SR.ENGR (SCT)

Encl: As above.

पावर सेक्टर पूर्वी क्षेत्र (मुख्यालय)

POWER SECTOR EASTERN REGION, DJ-9/1, SECTOR-II, SALT LAKE CITY, KOLKATA - 700 091

फैक्स/Fax : (033) 23211960

फोन/Phone : बोर्ड/EPABX : (033) 2339-8000/ 2339-8236(D)

ANNEXURE-A TO TCN-11

TENDER NO : PSER:SCT:NKP-M1738:16

Design, Engineering, Manufacturing, Supply/Delivery, Erection, Commissioning, Trial Run, Handing Over to Customer etc of WATER TREATMENT PACKAGES (PRE TREATMENT PLANT, EFFLUENT TREATMENT PLANT & SEWAGE TREATMENT PLANT) including supervision of civil construction work for 3X 660 MW North Karanpura Super Thermal Power Project at Jharkhand.

CLARIFICATION OF BIDDER'S QUERY

SL NO	REFERENCE CLAUSE OF TENDER DOCUMENT	EXISTING PROVISION	BIDDER'S QUERY	BHEL'S CLARIFICATION
1.0	CL 17.1.4 - VOLUME IC SPECIAL CONDITIONS OF CONTRACT (SUPPLY)	10% OF THE BASIC PRICE SHALL BE RELEASED AGAINST COMPLETION OF ERECTION OF THE EQUIPMENT SUPPLIED	REQUEST NOT TO LINK SUPPLY PAYMENT WITH ERECTION WORK. SEPARATE PAYMENT TERMS IS THERE FOR ERECTION. THIS WILL RESULT IN NEGATIVE CASH FLOW.	Shall be as per tender provision.
2.0	VOLUME IC SPECIAL CONDITIONS OF CONTRACT (SUPPLY)		REQUEST FOR 10% INTEREST FREE INITIAL ADVANCE AGAINST BG	Not applicable as per tender provision.
3.0	VOLUME IC SPECIAL CONDITIONS OF CONTRACT (SUPPLY)		PLEASE CONFIRM THAT BHEL WILL ISSUE NECESSARY C FORM TO US	Shall be as per tender provision.
4.0	VOLUME IC SPECIAL CONDITIONS OF CONTRACT (SUPPLY)		PLEASE CONFIRM THAT ALL ROAD PERMITS FOR DESPATCH OF BOUGHT OUTS FROM VENDORS / SUB VENDORS WORKS SHALL BE ISSUED BY NTPC / BHEL.	Road Permits shall be issued by Customer through BHEL
5.0	CI 4.2 - VOLUME ID SPECIAL CONDITIONS OF CONTRACT (ERECTION)	Water	Please confirm that water for testing shall be arranged by BHEL	BHEL will provide construction as well as potable water at one strategic point within plant premises.
6.0	CI 7.2 - VOLUME ID SPECIAL CONDITIONS OF CONTRACT (ERECTION)	All required chemicals up to trial run of the complete system including post trial-run operation of the system for maximum duration of 12 months period shall be in the supply scope of vendor.	However CI 15 (2) of Vol II M 1738 specifies that Chemicals are not in scope of supply. Accordingly we are not considering supply of any chemical like alum, lime, sodium hypochlorite, coagulant aid, poly electrolyte etc in our scope of work.	This issue has already been clarified vide TCN-04 to the Tender. Refer SL NO 31.0 - ANNEXURE-A TO TCN-04, of TCN-04 ref no. PSER:SCT: NKP-M1738:TCN-04, dated 28-04-2016.
7.0	CI 9.6 – VOLUME ID SPECIAL CONDITIONS OF CONTRACT (ERECTION)	Statutory Approval	No statutory approval issue is in scope of this package. Please confirm.	Obtaining all Statutory approvals is in the scope of vendor.
8.0	CI 19.0 – VOLUME ID SPECIAL CONDITIONS OF CONTRACT (ERECTION)	Completion Period	Please confirm that trail run & PG test shall be carried out within 16 months.	Entire work of erection, testing, commissioning, trial run, PG test, handing over, etc. shall be completed within 16 (Sixteen) months from the date of LOI.
9.0	CI 3.25 of Vol II M 1738 (66/279)		EDGE ANGLES FOR PRECASTS / DRAINS, STRUCTURES NOT RELATED TO ELECTROMECHANICAL WORK SHALL NOT BE IN BIDDER'S SCOPE. PLEASE CONFIRM.	Pl. refer cl. No. 9.0 of Technical Specification (Vol-II, M1738) (Page 68 of 279) wherein all "EXCLUSIONS" have been clearly indicated.
10.0			INSERTS ON FOUNDATION, CHANNELS FOR PIPE SUPPORTS NOT IN BIDDER'S SCOPE. PLEASE CONFIRM.	Pl. refer cl. No. 9.0 of Technical Specification (Vol-II, M1738) (Page 68 of 279) wherein all "EXCLUSIONS" have been clearly indicated.

FORMAT FOR NO DEVIATION CERTIFICATE
(To be submitted in the bidder's letter head)

BHARAT HEAVY ELECTRICALS LIMITED,
Power Sector - Eastern Region,
Plot no 9/1, DJ Block, Sector – II, Salt Lake City,
Kolkata – 700 091

Sub	No Deviation Certificate.
Job	Design, Engineering, Manufacturing, Supply/Delivery, Erection, Commissioning, Trial Run, Handing Over to Customer etc of WATER TREATMENT PACKAGES (PRE TREATMENT PLANT, EFFLUENT TREATMENT PLANT & SEWAGE TREATMENT PLANT) including supervision of civil construction work for 3X 660 MW North Karanpura Super Thermal Power Project at Jharkhand.
Ref	01 Tender no PSER:SCT:NKP-M1738:16
	02 BHEL's NIT, vide reference no PSER:SCT:NKP-M1738:4966 Date: 05-04-2016
	03 BHEL's TCN-01, vide reference PSER:SCT: NKP-M1738:TCN-01, dated 06-04-2016
	04 BHEL's TCN-02, vide reference PSER:SCT: NKP-M1738:TCN-02, dated 12-04-2016
	05 BHEL's TCN-03, vide reference PSER:SCT: NKP-M1738:TCN-03, dated 23-04-2016
	06 BHEL's TCN-04, vide reference PSER:SCT: NKP-M1738:TCN-04, dated 28-04-2016
	07 BHEL's TCN-05, vide reference PSER:SCT: NKP-M1738:TCN-05, dated 02-05-2016
	08 BHEL's TCN-06, vide reference PSER:SCT: NKP-M1738:TCN-06, dated 11-05-2016
	09 BHEL's TCN-07, vide reference PSER:SCT: NKP-M1738:TCN-07, dated 13-05-2016
	10 BHEL's TCN-08, vide reference PSER:SCT: NKP-M1738:TCN-08, dated 16-05-2016
	11 BHEL's TCN-09, vide reference PSER:SCT: NKP-M1738:TCN-09, dated 17-05-2016
	12 BHEL's TCN-10, vide reference PSER:SCT: NKP-M1738:TCN-10, dated 27-05-2016
	13 BHEL's TCN-11, vide reference PSER:SCT: NKP-M1738:TCN-11, dated 01-06-2016
	14 All other pertinent issues till date.

Dear Sirs,

With reference to above, this is to confirm that as per tender conditions, we have visited site before submission of our offer and noted the job content & site conditions etc. We also confirm that we have not changed/ modified the tender documents as appeared in the website/ issued by you and in case of such observance at any stage, it shall be treated as null and void.

We hereby confirm that we have not taken any deviation from tender clauses together with other references as enumerated in the above referred NIT. We hereby confirm our unqualified acceptance to all terms & conditions, unqualified compliance to technical specification, integrity pact (if applicable) and acceptance to reverse auctioning process.

In the event of observance of any deviation in any part of our offer at a later date whether implicit or explicit, the deviations shall stand null & void.

We confirm to have submitted offer in accordance with tender instructions and as per aforesaid references.

Thanking you,

Yours faithfully,

(Signature, date & seal of authorized representative of the bidder)

<p>पावर सेक्टर पूर्वी क्षेत्र (मुख्यालय) POWER SECTOR EASTERN REGION DJ-9/1, SECTOR-II, SALT LAKE CITY, KOLKATA - 700 091 फैक्स/Fax : (033) 23211960 फोन/Phone : बोर्ड/EPABX : (033) 2339-8000/ 2339-8236(D)</p>
--