

PRE-QUALIFICATION CRITERIA

JOB	DESIGN, ENGINEERING, MANUFACTURING, SUPPLY/ DELIVERY TO SITE OF 1.1 kV COPPER CONDUCTOR, EPR INSULATED FIRE SURVIVAL CABLES FOR 2 X 660 MW SURATGARH TPS.
CONTRACT DURATION	MONTHS
APPROXIMATE COST (NOT TO BE PUBLISHED IN THE WEBSITE)	

BIDDER SHALL NOTE & COMPLY WITH THE POINTS REFERRED BELOW.

SL NO	CRITERIA FOR BIDDERS NOT APPROVED WITH BHEL-PEM, NOIDA:
1.0	BIDDER SHOULD BE A MANUFACTURER OF 1.1 kV COPPER CONDUCTOR, EPR INSULATED FIRE SURVIVAL CABLES.
2.0	BIDDER SHOULD HAVE IN-HOUSE CAPABILITY TO CARRY OUT ALL ROUTINE & TYPE TESTS INCLUDING FIRE SURVIVAL TEST AS PER LATEST REVISION OF RELEVANT STANDARDS GIVEN IN TECHNICAL SPECIFICATION. IN CASE FACILITY FOR FIRE SURVIVAL TEST IS NOT AVAILABLE WITH BIDDER, THEN BIDDER SHALL CARRY OUT TYPE TESTS AT AN INDEPENDENT LABORATORY.
3.0	BIDDER TO FURNISH A TYPE TESTED DESIGN. THE TYPE TESTS SHOULD HAVE BEEN CARRIED OUT EITHER IN INDEPENDENT LABORATORY OR TESTS SHOULD HAVE BEEN WITNESSED BY CLIENT ON 1.1 kV COPPER CONDUCTOR, EPR INSULATED FIRE SURVIVAL CABLES.
4.0	BIDDER SHOULD HAVE SUPPLIED & INSTALLED 1.1 KV COPPER CONDUCTOR, EPR INSULATED, FIRE SURVIVAL CABLES FOR MINIMUM TWO POWER STATIONS/ PROCESS PLANT.
5.0	BIDDER SHOULD HAVE SUPPLIED & INSTALLED AT LEAST 10 KM OF 1.1 KV COPPER CONDUCTOR, EPR INSULATED, FIRE SURVIVAL CABLES IN ONE SINGLE CONTRACT.
6.0	BIDDER SHOULD HAVE MANUFACTURED & SUPPLIED 1.1 KV COPPER CONDUCTOR, EPR INSULATED, FIRE SURVIVAL CABLES SIZES MINIMUM 35 SQ. MM. FOR SINGLE/ MULTI CORE CATAGORY.
7.0	BIDDER TO FURNISH THE FOLLOWING: (A) LIST OF CUSTOMERS & PURCHASE ORDERS ALONG WITH CUSTOMER APPROVED DATA SHEET AND QUALITY PLAN FOR WHICH BIDDER HAS SUPPLIED THE 1.1 KV COPPER CONDUCTOR, EPR INSULATED, FIRE SURVIVAL CABLES IN THE PAST 5 YEARS. (B) TYPE TEST REPORT CONDUCTED AT INDEPENDENT LABORATORY/ WITNESSED BY CLIENT. (C) ISO CERTIFICATION. (D) TECHNICAL CATALOGUE. (E) CONFIRMATION ON S. NO. 2 ABOVE REGARDING TEST FACILITIES/ TIE-UP DETAILS FOR FIRE SURVIVAL TEST WITH REQUIRED DOCUMENTS.

NOTES

- 1.0 AFTER SATISFACTORY FULFILLMENT OF ALL THE ABOVE CRITERIA/ REQUIREMENT, OFFER SHALL BE CONSIDERED FOR FURTHER EVALUATION AS PER NIT AND ALL OTHER TERMS OF THE TENDER.
- 2.0 CONSIDERATION OF OFFER WILL BE SUBJECT TO CUSTOMER'S APPROVAL OF BIDDER.

Relhand
10/10/13

Q. Y.
10.10.13

A. J. S. S. S.
10/10/13