

Technical Amendment No. 2

Project: 1X800MW Kothagudem TPS Unit-12

Package: NDCT

Technical Specification No.: PE-TS-410-165-N001 (Rev. 0)

Sl.no.	Specification Clause No.	Existing provisions	Revised Provisions
1.	Sl. No. 2.11 of Datasheet-A, Section-D, Vol-IIB	Design pressure for hot water distribution = 6.2 kg/cm ² (g)	Design pressure for hot water distribution = 5.5 kg/cm ² (g)