

TECHNICAL CLARIFICATION

NIT NO. 23749 / ENQUIRY NO. T7B1O88410

ITEM : RCC Cooling Tower

CLARIFICATION:

Please note that we have already furnished Pile capacities in CT area with which the design of foundation can be finalized.

Pile length is not required for finalizing the design of foundation.