

Cable glands specification to be followed for Barauni Project shall be as follows;

“Double compression, Heavy Duty Nickel-Chromium plated (coating thickness not less than 10 microns) brass cable glands shall be provided by the vendor for all power and control cables to provide dust and weather proof terminations. The cable glands shall be tested as per BS: 6121. They shall comprise of heavy duty, brass casting, machine finished and Nickel-Chromium plated, to avoid corrosion and oxidation. Rubber components used in cable glands shall be neoprene and of tested quality. The glands shall be dust proof, screw on type, shrouded complete with necessary armour clamp and tapered washers etc.”