

SECTION - 1

SCOPE, SPECIFIC TECHNICAL REQUIREMENTS & QUANTITIES

1.1.0 SCOPE

1.1.1 The scope of work under this specification is Land development and Boundary Wall works of 220/132kV Substation at Pusuali in Bihar being executed by BHEL on turnkey basis. The Customer is Bihar state electricity board.

1.1.2 The Civil Works shall generally include, *but not limited to*, following:

- (i) Land development including cutting shrubs and bushes, cutting and backfilling the earth, earth filling, dewatering & sludge removal, contour mapping etc.
- (ii) Construction of Boundary Wall.
- (iii) Any other work required for the project.

1.1.3 The works to be performed in this specification are land cleaning, cutting of shrubs, bushes, cutting and backfilling the earth, earth filling brought from outside place and compaction in layers, dewatering, contour mapping etc. The works also includes preparation of bar bending schedules, based on the drawings released for construction and getting the same approved by the Engineer-in-charge plus the execution of the work including providing of all labour, supervision, materials, scaffolding, power, fuel, construction equipments, tools and plants, supplies, transportation, all incidental items necessary for successful completion of the work including contractor's supervision and in strict accordance with the drawings and specifications and with inspection and testing standards. The nature of work shall generally involve excavation in all type of soil including dewatering, shoring, strutting, and filling under and around structures, backfilling with available excavated earth around completed structures, disposal of surplus soil, formwork, concreting, brickwork, plastering etc. all complete as per detailed specification, drawings and directions of Engineer-in-charge

1.2.0 SPECIFIC TECHNICAL REQUIREMENT

1.2.1 The specific technical requirements for the execution of civil works shall be as per Customer's Specification (Section-3) / CPWD Specification. In case of any conflict between these, Customer's Specification shall prevail.

1.3.0 BILL OF QUANTITIES

1.3.1 The Bill of Quantity cum Price Schedule shall be as per page 3 & 4.

- 1.3.2 The quantities indicated in the 'Bill of Quantity Cum Price Schedule' are indicative and can vary to any extent. Contractor shall not be entitled for any claim for any such variation in the quantities.
- 1.3.3 The provision of Bill of Quantity Cum Price Schedule, specifications and drawings shall be read in conjunction with each other and in case of conflict amongst them, the clarification shall be obtained from the Engineer-in-charge whose decision shall be final and binding.
- 1.3.4 The mode of measurement:
Excavation shall be measured in cubic meters. The lateral dimensions to be considered for working out excavation quantity shall be the PCC dimensions below the footing as per approved drawing. Nothing extra shall be paid for slope cutting, etc. Backfilling and disposal quantities shall be worked out based on the above dimensions only.
For other items, unless otherwise described the method of measurement as described in 'Method of measurement of Building and Civil Engineering Works' - IS 1200(Part I to XXV) latest edition of BIS shall be followed.