

BILL OF QUANTITIES FOR UNDER GROUND EARTHING AND ELECTRODES REV.01

Name of Project		400 kV Switchyard at North Chennai TPS (Stage II)					
Name of Work		Bill of Quantity for Under Ground Earthing and Electrodes					
S. No	Description	Unit	Quantities			Unit Rate (Rs.)	Amount (Rs.)
			Unit 1	Unit2	Total		
1	Unloading, storing and laying of 40 mm dia MS Rods at a depth of 600 mm measured from the top of Finished Ground Level for bringing out risers just below gravel level near the equipment foundations as per requirement including following works: - excavation of trenches - laying of MS rod - welding of rods (refer Drg No. TB-STD-316-Rod Welding Rev 00 for Welding details of rods) - backfilling of soil for bringing out pig tail risers of 40 dia MS rod (approximately 1000) for equipments. Risers shall be raised from the earthmat (at 600 mm depth) to 150 mm above ground level to the nearest point of the equipment. This shall include all cutting, bending, welding, fixing, application of zinc rich paint on cutting surface, etc to the main earthmesh. - any other work necessary to complete the laying of earthmat (40 mm dia MS rod will be supplied by BHEL).	kM	9	4.5	13.5		
2	Installation of Pipe Electrode(to be driven - 3.0 Mtr) as per Drg. No. TB-STD-316-Pipe Electrode Rev 00 including following works: - excavation - installing the pipe electrode with alternate layers of Coke/charcoal and salt - backfilling and compaction - Casting the Test Pit with Cast Iron covers - any other work necessary to complete the work (GI Pipe, Nuts, Bolts & Washers and funnel with wire mesh will be supplied by BHEL).	Nos.	6	2	8		
3	Installing of 40 mm diameter Rod Electrode with test pit as per Drg. No. TB-STD-316-Rod Electrode Rev 00 including following works: - excavation - installing the rod electrode - backfilling and compaction - Casting the Test Pit with Cast Iron covers - any other work necessary to complete the work (40 mm dia MS rod will be supplied by BHEL).	Nos.	4	0	4		
4	Installing of 40 mm diameter Rod Electrode without test pit including following works: - excavation/hammering of rod in earth - installing the rode electrode - backfilling and compaction - any other work necessary to complete the work (40 mm dia MS rod will be supplied by BHEL).	Nos.	90	50	140		
5	Unloading, storing and laying of 75X12 mm GS Flat embedded in the floor slab with approximately 50 mm concrete cover for bringing out risers near the equipment foundations as per requirement including following works: - laying of GS Flat - welding of GS Flat - any other work necessary to complete the laying of earthmat (75x12 mm GS Flat will be supplied by BHEL).	kM	1.15	0.4	1.55		
TOTAL AMOUNT							