PROJECT : 1X800 MW KOTHAGUDAM STPP
PACKAGE : COOLING TOWER.
ENQUIRY NO.: E-4750/2014 Dtd 27.03.2015

Sr. No.	Reference clause of tender document	Existing Provision	Vendor's Query	BHEL Reply
1.	Clause No. 9.02.03.E & 9.02.07.g of VOLUME –IIB, TECHNICAL SPECIFICATION FOR COOLING TOWER Specification No. : PE-TS-410-165-N001 (REV. 0) And NIT	**Technical Specification** All reinforcements used shall be corrosion resistant steel/HCRM **NIT** Structural & Reinforced Steel shall be free issue items by BHEL	We presume, Reinforcement steel issued by BHEL shall meet the requirement of technical specification i.e. BHEL shall issue us corrosion resistant steel/HCRM free of cost. Please confirm. We presume, Structural steel issued by BHEL shall meet the requirement of technical specification. Please confirm.	Confirmed confirmed