

TENDER SPECIFICATION

SI No	Tender Specification Number	Unit Number & Project
1	BHE/PW/PUR/SKT-BAL STG U#3/1236	250 MW STG Set of Unit 3

FOR

RECEIPT OF MATERIALS FROM BHEL/ CUSTOMER STORES/ STORAGE YARD, SITE AND OTHER LOCATIONS, HANDLING AT STORES/ STORAGE YARD, SITE OF WORK, TRANSPORTATION BETWEEN STORES AND SITE OF WORK, ERECTION, TESTING, COMMISSIONING, FINAL PAINTING AND HANDING OVER OF STEAM TURBINE, TURBO-GENERATOR, CONDENSER, STG INTEGRAL PIPING, EXTERNAL/ REGENERATIVE ETC. WITH ASSOCIATED EQUIPMENTS/ TANKS/ VESSELS, FST, HP & LP HEATERS, DEAERATOR WITH ASSOCIATED PLATFORM, POWER CYCLE PUMPS & ASSOCIATED AUXILIARIES, R.E. JOINTS & B.F. VALVES ETC., LP BYPASS SYSTEM WITH ASSOCIATED AUX., BOUGHT OUT ITEMS AND PEM PACKAGES OF UNIT-3 OF 250 MW

AT

2 x 250 MW SIKKA THERMAL POWER STATION
GUJARAT STATE ELECTRICITY COORPORATION LIMITED
DIST- JAMNAGAR
GUJARAT

VOLUME – I-Technical Bid

CONSISTING OF:

- **Notice Inviting Tender,**
- **Volume-IA : Technical Conditions of Contract,**
- **Volume-IB : Special Conditions of Contract,**
- **Volume-IC : General Conditions of Contract**
- **Volume-ID : Forms & Procedures**



Bharat Heavy Electricals Limited
(A Government of India Undertaking)
Power Sector - Western Region
345-Kingsway, Nagpur-440001

CONTENTS

Volume No	Description	No. of pages	Hosted in website bhel.com as files titled
NIL	Tender Specification Issue Details	1	(Part of <u>Vol-IA-1236</u>)
NIL	Notice Inviting Tender	19	(Part of <u>Vol-IA-1236</u>)
I-A	Technical Conditions of Contract	90	Vol-IA-1236-
I-B	Special Conditions of Contract	47	Vol-IBCD-1236
I-C	General Conditions of Contract	29	(Part of Vol-IBCD-1236)
I-D	Forms & Procedures	69	(Part of Vol-IBCD-1236)
II	Price Bid Specification	4	Vol-II-1236

TENDER SPECIFICATION

SI No	Tender Specification Number	Unit Number & Project
1	BHE/PW/PUR/SKT-STG U-3/	250 MW STG Set of Unit 3

FOR

RECEIPT OF MATERIALS FROM BHEL/ CUSTOMER STORES/ STORAGE YARD, SITE AND OTHER LOCATIONS, HANDLING AT STORES/ STORAGE YARD, SITE OF WORK, TRANSPORTATION BETWEEN STORES AND SITE OF WORK, ERECTION, TESTING, COMMISSIONING, FINAL PAINTING AND HANDING OVER OF STEAM TURBINE, TURBO-GENERATOR, CONDENSER, STG INTEGRAL PIPING, EXTERNAL/ REGENERATIVE ETC. WITH ASSOCIATED EQUIPMENTS/ TANKS/ VESSELS, FST, HP & LP HEATERS, DEAERATOR WITH ASSOCIATED PLATFORM, POWER CYCLE PUMPS & ASSOCIATED AUXILIARIES, R.E. JOINTS & B.F. VALVES ETC., LP BYPASS SYSTEM WITH ASSOCIATED AUX., BOUGHT OUT ITEMS AND PEM PACKAGES OF UNIT-3 OF 250 MW

AT

2 x 250 MW SIKKA THERMAL POWER STATION
GUJARAT STATE ELECTRICITY CORPORATION LIMITED
DIST- JAMNAGAR
GUJARAT

EARNEST MONEY DEPOSIT: Refer Notice Inviting Tender

LAST DATE FOR TENDER SUBMISSION Refer Notice Inviting Tender .

THESE TENDER SPECIFICATION DOCUMENTS CONTAINING VOLUME-I REV01 DTD 15/02/2012 AND VOLUME- II ARE ISSUED TO:

M/s.

.....

PLEASE NOTE:
THESE TENDER SPECS DOCUMENTS ARE NOT TRANSFERABLE.

For Bharat Heavy Electricals Limited

AGM (Purchase)
Place: Nagpur
Date:

1236

NOTICE INVITING TENDER

Bharat Heavy Electricals Limited



NOTICE INVITING TENDER (NIT)
NOTE: BIDDER MAY DOWNLOAD FROM WEB SITES
OR
PURCHASE TENDERS FROM THIS OFFICE ALSO

To

Dear Sir/Madam

Sub : NOTICE INVITING TENDER

Sealed offers in two part bid system are invited from reputed & experienced bidders (meeting [PRE QUALIFICATION CRITERIA](#) as mentioned in Annexure-I) for the subject job by the undersigned on the behalf of BHARAT HEAVY ELECTRICALS LIMITED as per the tender document. Following points relevant to the tender may please be noted and complied with.

1.0 Salient Features of NIT

SL NO	ISSUE	DESCRIPTION	
i	TENDER NUMBER	BHE/PW/PUR/SKT-BAL STG U#3/1236	
ii	Broad Scope of job	FOR RECEIPT OF MATERIALS FROM BHEL/ CUSTOMER STORES/ STORAGE YARD, SITE AND OTHER LOCATIONS, HANDLING AT STORES/ STORAGE YARD, SITE OF WORK, TRANSPORTATION BETWEEN STORES AND SITE OF WORK, ERECTION, TESTING, COMMISSIONING, FINAL PAINTING AND HANDING OVER OF STEAM TURBINE, TURBO-GENERATOR, CONDENSER, STG INTEGRAL PIPING, EXTERNAL/ REGENERATIVE ETC. WITH ASSOCIATED EQUIPMENTS/ TANKS/ VESSELS, FST, HP & LP HEATERS, DEAERATOR WITH ASSOCIATED PLATFORM, POWER CYCLE PUMPS & ASSOCIATED AUXILIARIES, R.E. JOINTS & B.F. VALVES ETC., LP BYPASS SYSTEM WITH ASSOCIATED AUX., BOUGHT OUT ITEMS AND PEM PACKAGES OF UNIT-3 OF 250 MW AT 2 x 250 MW SIKKA THERMAL POWER STATION GUJARAT STATE ELECTRICITY COORPORATION LIMITED DIST- JAMNAGAR GUJARAT	
iii	DETAILS OF TENDER DOCUMENT		
a	Volume-IA	<i>Technical Conditions of Contract (TCC) consisting of Scope of work, Technical Specification, Drawings, Procedures, Bill of Quantities, Terms of payment, etc</i>	<i>Applicable</i>
b	Volume-IB	<i>Special Conditions of Contract (SCC)</i>	<i>Applicable</i>
c	Volume-IC	<i>General Conditions of Contract (GCC)</i>	<i>Applicable</i>
d	Volume-ID	<i>Forms and Procedures</i>	
e	Volume-II	<i>Price Schedule (Absolute value).</i>	<i>Applicable</i>
iv	Issue of Tender Documents	1. <u>Sale from BHEL PS Regional office at :</u> Start : 18/02/2014, Time : Closes: 26/02/2014 , Time :16:00 Hrs 2. From BHEL website (www.bhel.com) Tender documents will be available for downloading from website till due date of submission	<i>Applicable</i>
v	DUE DATE & TIME OF OFFER	Date : 27/02/2014 , Time : 15:00 Hrs Place : <u>BHEL PS Regional office at :Nagpur</u>	<i>Applicable</i>

**BHEL PSWR
Notice Inviting Tender**

Tender Specification No: BHE/PW/PUR/SKT-BAL STG U#3/1236

Page 6 of 113

	SUBMISSION	Tenders being submitted through representative shall be submitted at dispatch section of of PSWR HQ Office after making entry/registration at the reception. For any assistance on the matter kindly contact following officials: <ul style="list-style-type: none"> Pratish Gee Varghese/Sr Engineer(Purchase) Shivkesh Meena / Engineer (Purchase) 	
vi	OPENING OF TENDER	1 hours after the latest due date and time of Offer submission Notes: (1) In case the due date of opening of tender becomes a non-working day, then the due date & time of offer submission and opening of tenders get extended to the next working day. (2) Bidder may depute representative to witness the opening of tender	Applicable
vii	EMD AMOUNT	Rs 2.00 Lakhs (Rupees Two Lakhs Only)	Applicable
viii	COST OF TENDER	Rs 2000/-.	Applicable
ix	LAST DATE FOR SEEKING CLARIFICATION	Atleast 5 days before the due date of offer submission Along with soft version also, addressing to undersigned & to others as per contact address given below	Applicable
x	SCHEDULE OF Pre Bid Discussion (PBD)	Date :	Not applicable.
xi	INTEGRITY PACT & DETAILS OF INDEPENDENT EXTERNAL MONITOR (IEM)		Not Applicable
xii	Latest updates	Latest updates on the important dates, Amendments, Correspondences, Corrigenda, Clarifications, Changes, Errata, Modifications, Revisions, etc to Tender Specifications will be hosted in BHEL webpage (www.bhel.com -->Tender Notifications →View Corrigendums) and not in the newspapers . Bidders to keep themselves updated with all such information	

- 2.0 The offer shall be submitted as per the instructions of tender document and as detailed in this NIT. Bidders to note specifically that all pages of tender document, including these NIT pages of this particular tender together with subsequent correspondences shall be submitted by them, duly signed & stamped on each page, as part of offer. **Rates/Price including discounts/rebates, if any, mentioned anywhere/in any form in the techno-commercial offer other than the Price Bid, shall not be entertained.**
- 3.0 Unless specifically stated otherwise, bidder shall remit cost of tender and courier charges if applicable, in the form of Demand Draft drawn in favour of Bharat Heavy Electricals Ltd, payable at Power Sector Regional HQ at Nagpur issuing the Tender, along with techno-commercial offer. Bidder may also choose to deposit the Tender document cost by cash at the Cash Office as stated above against sl no iv of 1, on any working day; and in such case copy of Cash receipt is to be enclosed with the Techno Commercial offer. Sale of tender Documents shall not take place on National Holidays, holidays declared by Central or State Governments and BHEL PS HQ at Nagpur, Sundays and second/ last Saturdays
- 4.0 Unless specifically stated otherwise, bidder shall deposit EMD through Demand Draft/Pay Order in favour of Bharat Heavy Electricals Ltd, payable at Nagpur. For other details and for 'One Time EMD' please refer General Conditions of Contract.
- 5.0 **Procedure for Submission of Tenders:** The Tenderers must submit their Tenders to Officer inviting Tender, as detailed below:

**BHEL PSWR
Notice Inviting Tender**

Tender Specification No: BHE/PW/PUR/SKT-BAL STG U#3/1236

Page 7 of 113

- PART-I consisting of 'PART-I A (Techno Commercial Bid)' & 'PART-I B (EMD/COST of TENDER)' in two separate sealed and superscribed envelopes (ENVELOPE-I & ENVELOPE-II)
- PART-II (Price Bid) – in sealed and superscribed envelope (ENVELOPE-III)
- One set of tender documents shall be retained by the bidder for their reference

6.0 The contents for ENVELOPES and the superscription for each sealed cover/Envelope are as given below. **(All pages to be signed and stamped)**

Sl no	Description	Remarks
	Part-I A	
	<p>ENVELOPE – I superscribed as : PART-I (TECHNO COMMERCIAL BID) TENDER NO : NAME OF WORK : PROJECT: DUE DATE OF SUBMISSION:</p> <p>CONTAINING THE FOLLOWING:-</p>	
i.	Covering letter/Offer forwarding letter of Tenderer.	
ii.	Duly filled-in 'No Deviation Certificate' as per prescribed format to be placed after document under sl no (i) above. Note: <ol style="list-style-type: none"> a. In case of any deviation, the same should be submitted separately for technical & commercial parts, indicating respective clauses of tender against which deviation is taken by bidder. The list of such deviation shall be placed after document under sl no (i) above. It shall be specifically noted that deviation recorded elsewhere shall not be entertained. b. BHEL reserves the right to accept/reject the deviations without assigning any reasons, and BHEL decision is final and binding. <ol style="list-style-type: none"> i). In case of acceptance of the deviations, appropriate loading shall be done by BHEL ii). In case of unacceptable deviations, BHEL reserves the right to reject the tender 	
iii.	Supporting documents/ annexure/ schedules/ drawing etc as required in line with Pre-Qualification criteria. It shall be specifically noted that all documents as per above shall be indexed properly and credential certificates issued by clients shall distinctly bear the name of organization, contact ph no, FAX no, etc.	
iv.	All Amendments/Correspondences/Corrigenda/Clarifications/Changes/ Errata etc pertinent to this NIT.	
v.	Integrity Pact Agreement (Duly signed by the authorized signatory)	If applicable
vi.	Duly filled-in annexures, formats etc as required under this Tender Specification/NIT	
vii.	Notice inviting Tender (NIT)	
viii.	Volume – I A : <u>Technical</u> Conditions of Contract (TCC) consisting of Scope of work, Technical Specification, Drawings, Procedures, Bill of Quantities, Terms of payment, etc	
ix.	Volume – I B : Special Conditions of Contract (SCC)	
x.	Volume – I C : General Conditions of Contract (GCC)	
xi.	Volume – I D : Forms & Procedures	
xii.	Volume – II (UNPRICED – without disclosing rates/price, but mentioning only 'QUOTED' or 'UNQUOTED' against each item	
xiii.	Any other details preferred by bidder with proper indexing.	

	PART-I B	
	ENVELOPE – II superscribed as:	

**BHEL PSWR
Notice Inviting Tender**

Tender Specification No: BHE/PW/PUR/SKT-BAL STG U#3/1236

Page 8 of 113

	<p>PART-I (EMD/COST of TENDER) TENDER NO : NAME OF WORK : PROJECT: DUE DATE OF SUBMISSION:</p> <p>CONTAINING THE FOLLOWING:-</p>	
i.	<p>1. Earnest Money Deposit (EMD) in the form as indicated in this Tender OR Documentary evidence for 'One Time EMD' with the Power Sector Region of BHEL floating the Tender</p> <p>2. Cost of Tender (Demand Draft or copy of Cash Receipt as the case may be)</p>	

	PART-II	
	PRICE BID consisting of the following shall be enclosed	
	<p>ENVELOPE-III superscribed as: PART-II (PRICE BID) TENDER NO : NAME OF WORK : PROJECT: DUE DATE OF SUBMISSION:</p> <p>CONTAINING THE FOLLOWING</p>	
i	Covering letter/Offer forwarding letter of Tenderer enclosed in Part-I	
ii	Volume II – PRICE BID (Duly Filled in Schedule of Rates – rate/price to be entered in words as well as figures)	

	OUTER COVER	
	<p>ENVELOPE-IV (MAIN ENVELOPE / OUTER ENVELOPE) superscribed as: TECHNO-COMMERCIAL BID, PRICE BID & EMD TENDER NO: NAME OF WORK: PROJECT: DUE DATE OF SUBMISSION:</p> <p>CONTAINING THE FOLLOWING:</p>	
i	<ul style="list-style-type: none"> o Envelopes I o Envelopes II o Envelopes III 	

SPECIAL NOTE : All documents/ annexures submitted with the offer shall be properly annexed and placed in respective places of the offer as per enclosure list mentioned in the covering letter. BHEL shall not be responsible for any missing documents.

7.0 Deviation with respect to tender clauses and additional clauses/suggestions in Techno-commercial bid / Price bid shall NOT be considered by BHEL. Bidders are requested to positively comply with the same.

8.0 BHEL reserves the right to accept or reject any or all Offers without assigning any reasons thereof. BHEL also reserves the right to cancel the Tender wholly or partly without assigning any reason thereof. Also BHEL shall not entertain any correspondence from bidders in this matter (except for the refund of EMD).

9.0 **Assessment of Capacity of Bidders:**

<p>Registered Office : BHEL House, Siri Fort, New Delhi – 110 049, India Website : www.bhel.com</p>

Bidders capacity for executing the job under tender shall be assessed 'LOAD' wise and 'PERFORMANCE' wise as per the following:

- I. **LOAD:** Load takes into consideration **ALL** the contracts of the Bidder under execution with BHEL Regions, irrespective of whether they are similar to the tendered scope or not. The 'Load' is the sum of the unit wise identified packages (refer Table-1) for contracts with BHEL Regions. The cut off month for reckoning 'Load' shall be the month, two (2) months preceding the month corresponding to the 'latest date of bid submission', in the following manner:

(Note: For example if latest bid submission is in Aug 2011, then the 'load' shall be calculated upto and inclusive of June 2011)

- i). **Total number of Packages**
Total number of Packages in hand = P
Where
- 'P' is the sum of all unit wise identified packages under execution with BHEL Regions as of the cut off month defined above, including packages yet to be commenced, excepting packages which are on HOLD due to reasons not attributable to Bidder..

- II. **PERFORMANCE:** Here 'Monthly Performance' of the bidder for all the packages (**under execution/** executed during the 'Period of Assessment' in all the Power Sector Regions of BHEL) **SIMILAR** to the packages covered under the tendered scope, excepting packages not commenced shall be taken into consideration. The 'Period of Assessment' shall be 6 months preceding the cut off month. The cut off month for reckoning 'Period of Assessment' shall be the month two (2) months preceding the month corresponding to the 'latest date of bid submission', in the following manner:

(Note: For example if 'latest date of bid submission' is in Aug 2011, then the 'performance' shall be assessed for a 6 month period upto and inclusive of June 2011, for all the unit wise identified packages (refer Table I)

- i). **Calculation of Overall 'Performance Rating' for 'similar Package/Packages' for the tendered scope under execution at Power Sector Regions for the 'Period of Assessment':**
This shall be obtained by summing up the 'Monthly Performance Evaluation' scores obtained by the bidder in all Regions for all the similar Package/packages', divided by the total number of Package months for which evaluation should have been done, as per procedure below:
- a) $P_1, P_2, P_3, P_4, P_5, \dots, P_N$ etc be the packages (**under execution/** executed during the 'Period of Assessment' in all Regions) **SIMILAR** to the packages covered under the tendered scope, excepting packages not commenced. Total number of similar packages for all Regions = P_T (i.e $P_T = P_1 + P_2 + P_3 + P_4 + \dots + P_N$)
- b) Number of Months ' T_1 ' for which 'Monthly Performance Evaluation' as per relevant formats, should have been done in the 'Period of Assessment' for the corresponding similar package P_1 . Similarly T_2 for package P_2 , T_3 for package P_3 , etc for the tendered scope. Now calculate cumulative total months ' T_T ' for total similar Packages ' P_T ' for all Regions (i.e $T_T = T_1 + T_2 + T_3 + T_4 + \dots + T_N$)
- c) Sum ' S_1 ' of 'Monthly Performance Evaluation' Scores ($S_{1-1}, S_{1-2}, S_{1-3}, S_{1-4}, S_{1-5}, \dots, S_{1-N}$) for similar package P_1 , for the 'period of assessment' ' T_1 ' (i.e $S_1 = S_{1-1} + S_{1-2} + S_{1-3} + S_{1-4} + S_{1-5} + \dots + S_{1-N}$). Similarly S_2 for package P_2 for period T_2 , S_3 for package P_3 for period T_3 , etc for the tendered scope for all Regions. Now calculate cumulative sum ' S_T ' of 'Monthly Performance Evaluation' Scores for total similar Packages ' P_T ' for all Regions (i.e ' $S_T = S_1 + S_2 + S_3 + S_4 + S_5 + \dots + S_N$.)
- d) **Overall Performance Rating ' R_{BHEL} ' for the similar Package/Packages (under execution/** executed during the 'Period of Assessment') in all the Power Sector Regions of BHEL):

$$= \frac{\text{Aggregate of Performance scores for all similar packages in all the Regions}}{\text{Aggregate of months for each of the similar package for which performance should have been evaluated in all the Regions}}$$

$$= \frac{S_T}{T_T}$$

e) Bidders to note that the risk of non evaluation or non availability of the 'Monthly Performance Evaluation' reports as per relevant formats is to be borne by the Bidder

f) Table showing methodology for calculating 'a', 'b' and 'c' above

Sl no	Item Description	Details for all Regions							Total
		(i)	(ii)	(iii)	(iv)	(v)	(vi)	(vii)	
1	Similar Packages for all Regions → (under execution/ executed during period of assessment)	P ₁	P ₂	P ₃	P ₄	P ₅	...	P _N	Total No of similar packages for all Regions = P _T ie Sum (Σ) of columns (iii) to (ix)
2	Number of Months for which 'Monthly Performance Evaluation' as per relevant formats should have been done in the 'period of assessment for corresponding similar Package (as in row 1)	T ₁	T ₂	T ₃	T ₄	T ₅	...	T _N	Sum (Σ) of columns (iii) to (ix) = T _T
3	Monthly performance scores for the corresponding period (as in Row 2)	S _{1-1,} S _{1-2,} S _{1-3,} S _{1-4,} ... S _{1-T1}	S _{2-1,} S _{2-2,} S _{2-3,} S _{2-4,} ... S _{2-T2}	S _{3-1,} S _{3-2,} S _{3-3,} S _{3-4,} ... S _{3-T3}	S _{4-1,} S _{4-2,} S _{4-3,} S _{4-4,} ... S _{4-T4}	S _{5-1,} S _{5-2,} S _{5-3,} S _{5-4,} ... S _{5-T5}	S _{N-1,} S _{N-2,} S _{N-3,} S _{N-4,} ... S _{N-TN}	-----
4	Sum of Monthly Performance scores of the corresponding Package for the corresponding period (as in row-3)	S ₁	S ₂	S ₃	S ₄	S ₅	...	S _N	Sum (Σ) of columns (iii) to (ix) = S _T

ii) Calculation of Overall 'Performance Rating' (R_{BHEL}) in case 'similar Package/Packages' for the tendered scope ARE NOT AVAILABLE, during the 'Period of Assessment':

This shall be obtained by summing up the 'Monthly Performance Evaluation' scores obtained by the bidder in all Regions for ALL the packages, divided by the total number of Package months for which evaluation should have been done. 'R_{BHEL}' shall be calculated subject to availability of 'performance scores' for at least.6 'package months' in the order of precedence below:

- a) 'Period of Assessment.
- b) 12 months preceding the cut-off month
- c) 24 months preceding the cut-off month

**BHEL PSWR
Notice Inviting Tender**

Tender Specification No: BHE/PW/PUR/SKT-BAL STG U#3/1236

Page 11 of 113

d) 36 months preceding the cut-off month

In case, R_{BHEL} cannot be calculated as above, then Bidder shall be treated as 'NEW VENDOR'. Further eligibility and qualification of this bidder shall be as per definition of 'NEW VENDOR' described in 'Explanatory Notes'

iii) Factor "L" assigned based on Overall Performance Rating (R_{BHEL}) at Power Sector Regions.:

Sl no	Overall Performance Rating (R_{BHEL})	Corresponding value of 'L'
1	=60	NA
2	> 60 and \leq 65	0.4
3	> 65 and \leq 70	0.35
4	> 70 and \leq 75	0.25
5	> 75 and < 80	0.2
6	\geq 80	NA

III. 'Assessment of Capacity of Bidder':

'Assessment of Capacity of Bidder' is based on the Maximum number of packages for which a vendor is eligible, considering the performance scores of similar packages, as below:

Max number of packages $P_{Max} = (R_{BHEL} - 60)$ divided by corresponding value of 'L'
i.e. $(R_{BHEL} - 60)/L$

Note:

- i. In case the value of P_{Max} results in a fraction, the value of P_{Max} is to be rounded off to next whole number
- ii. For $R_{BHEL} = 60$, $P_{Max} = '1'$
- iii. For $R_{BHEL} \geq 80$, there will be no upper limit on P_{Max}

The Bidder shall be considered 'Qualified' as per 'Assessment of Capacity of Bidder' for the subject Tender if $P \leq P_{Max}$
(where P is calculated as per clause 9.I)

IV. Explanatory note:

- a) Similar package means Boiler or ESP or Piping or Turbine or Civil or Structure or Electrical or CI, etc at the individual level irrespective of rating of Plant, and irrespective of whether the subject tender is a single package or as part of combined/composite packages. Normally Boiler, ESP, Piping, Turbine, Electrical, CI, Civil, Structure, etc is considered individual level of package. For example in case the tendered scope is a Boiler Vertical Package comprising of Boiler, ESP and Power Cycle Piping (i.e the 'identified packages as per Table-1 below), the 'PERFORMANCE' part against sl no II above, needs to be evaluated considering all the identified packages (ie Boiler, ESP and Power Cycle Piping) and finally the Bidder's capacity to execute the tendered scope is assessed in line with III above
- b) Identified Packages (Unit wise)

Table-1

Civil	Electrical & CI	Mechanical
i). Enabling works	i). Electrical	i). Boiler & Aux (All types including CW Piping if applicable)
ii). Pile and Pile Caps	ii). CI	ii). Power Cycle Piping/Critical Piping
iii). Civil Works including foundations	iii). Others (Elec & CI)	iii). LP Piping
iv). Structural Steel Fabrication & Erection		iv). ESP
v). Chimney		v). Steam Turbine Generator set & Aux
vi). Cooling Tower		vi). Gas Turbine Generator set & Aux

**BHEL PSWR
Notice Inviting Tender**

Tender Specification No: BHE/PW/PUR/SKT-BAL STG U#3/1236

Page 12 of 113

	vii). Others (Civil)		vii). Hydro Turbine Generator set & Aux viii). Turbo Blower (including Steam Turbine) ix). Material Handling x). Material Management xi). Material Handling & Material Management xii). Others (Mechanical)
--	----------------------	--	--

c) Bidders who have not been evaluated for at least six package months in the last 36 months in the online BHEL system for contractor performance evaluation in BHEL PS Regions, wef July'2010 shall be considered "NEW VENDOR".

A 'NEW VENDOR' shall be considered qualified subject to satisfying all other tender conditions

A 'NEW VENDOR' if awarded a job (of package/packages identified under this clause) shall be tagged as "FIRST TIMER" on the date of first LOI from BHEL.

The "FIRST TIMER" tag shall remain till execution of work for a period of not less than 09 months, from the commencement of work of first package

A Bidder shall not be eligible for the next job as long as the Bidder is tagged as "FIRST TIMER" excepting for the Tenders which have been opened on or before the date of the bidder being tagged as 'FIRST TIMER'.

After removal of 'FIRST TIMER' tag, the Bidder shall be considered 'QUALIFIED' for the future tenders subject to satisfying all other tender conditions including 'Capacity Evaluation of Bidders'.

d) In the unlikely event of all bidders shortlisted against Technical and Financial Qualification criteria not meeting the criteria on 'Assessment of Capacity of Bidders' detailed above, OR leads to a single tender response on applying the criteria of 'Assessment of Capacity of Bidders' or due to non-approval by Customer, then BHEL at its discretion reserves the right to consider the further processing of the Tender based on the **Overall Performance Rating 'R_{BHEL}'** only, starting from the upper band.

e) 'Under execution' shall mean works in progress as per the following:

- i. up to Boiler Steam Blowing in case of Steam Generator and Auxiliaries
- ii. upto Synchronisation in case of all other works excepting sl no (i) and (iii)
- iii. Upto execution of at least 90% of anticipated contract value in case of Civil & Structures (unit wise), Enabling works and upto 90% of material unloading (in tonnage) as per the original contract in case of MM Package.

Note : BHEL at its discretion can extend (or reduce in exceptional cases in line with Contract conditions) the period defined against (i), (ii) and (iii) above, depending upon the balance scope of work to be completed.

f) Performance evaluation in CL 9 above is applicable to Prime bidder and consortium partner (or Technical tie up partner) for their respective scope of work

10.0 Since the job shall be executed at site, bidders must visit site/ work area and study the job content, facilities available, availability of materials, prevailing site conditions including law & order situation, applicable wage structure, wage rules,

**BHEL PSWR
Notice Inviting Tender**

Tender Specification No: BHE/PW/PUR/SKT-BAL STG U#3/1236

Page 13 of 113

.....
etc before quoting for this tender. They may also consult this office before submitting their offers, for any clarifications regarding scope of work, facilities available at sites or on terms and conditions.

- 11.0 For any clarification on the tender document, the bidder may seek the same in writing or through e-mail, as per specified format, within the scheduled date for seeking clarification, from the office of the undersigned. BHEL shall not be responsible for receipt of queries after due date of seeking clarification due to postal delay or any other delays. Any clarification / query received after last date for seeking clarification may not be normally entertained by BHEL and no time extension will be given.
- 12.0 BHEL may decide holding of pre-bid discussion [PBD] with all intending bidders as per date indicated in the NIT. The bidder shall ensure participation for the same at the appointed time, date and place as may be decided by BHEL. Bidders shall plan their visit accordingly. The outcome of pre-bid discussion (PBD) shall also form part of tender.
- 13.0 In the event of any conflict between requirement of any clause of this specification/ documents/drawings/data sheets etc or requirements of different codes/standards specified, the same to be brought to the knowledge of BHEL in writing for clarification before due date of seeking clarification (whichever is applicable), otherwise, interpretation by BHEL shall prevail. Any typing error/missing pages/ other clerical errors in the tender documents, noticed must be pointed out before pre-bid meeting/submission of offer, else BHEL's interpretation shall prevail.
- 14.0 Unless specifically mentioned otherwise, bidder's quoted price shall deemed to be in compliance with tender including PBD.
- 15.0 Bidders shall submit Integrity Pact Agreement (Duly signed by authorized signatory who signs in the offer), **if applicable**, along with techno-commercial bid. This pact shall be considered as a preliminary qualification for further participation. **The names and other details of Independent External Monitor (IEM) for the subject tender is as given at point (1) above.**
- 16.0 The Bidder has to satisfy the Pre Qualifying Requirements stipulated for this Tender in order to be qualified. The Price Bids of only those bidders will be opened who will be qualified for the subject job on the basis of satisfying the Pre Qualification Criteria specified in this NIT as per Annexure-I (as applicable), past performance etc. and date of opening of price bids shall be intimated to only such bidders. BHEL reserves the right not to consider offers of parties under HOLD.
- 17.0 In case BHEL decides on a 'Public Opening', the date & time of opening of the sealed PRICE BID shall be intimated to the qualified bidders and in such a case, bidder may depute one authorised representative to witness the price bid opening. BHEL reserves the right to open 'in-camera' the 'PRICE BID' of any or all Unsuccessful/Disqualified bidders under intimation to the respective bidders.
- 18.0 Validity of the offer shall be for **six months** from the latest due date of offer submission (including extension, if any) unless specified otherwise.
- 19.0 BHEL reserves the right to decide the successful bidder on the basis of Reverse Auction process. In such case all qualified bidders will be intimated regarding procedure/ modality for Reverse Auction process prior to Reverse Auction and price will be decided as per the rules for Reverse Auction. .

However, if reverse auction process is unsuccessful as defined in the RA rules/procedures, or for whatsoever reason, then the sealed 'PRICE BIDS' will be opened for deciding the successful bidder. BHEL's decision in this regard will be final and binding on bidder.
- 20.0 On submission of offer, further consideration will be subject to compliance to tender & qualifying requirement and customer's acceptance, as applicable.
- 21.0 In case the bidder is an "Indian Agent of Foreign Principals", 'Agency agreement has to be submitted along with Bid, detailing the role of the agent along with the terms of payment for agency commission in INR, along with supporting documents.
- 22.0 The bidders shall not enter into any undisclosed M.O.U. or any understanding amongst themselves with respect to tender.
- 23.0 Consortium Bidding (or Technical Tie up) shall be allowed only if specified in Pre Qualifying Requirement (PQR) criteria, and in such a case the following shall be complied with:

-
- 23.1 Prime Bidder and Consortium Partner or partners are required to enter into a consortium agreement with a validity period of six months initially. In case the consortium is awarded the contract, then the Consortium Agreement between the Prime Bidder and Consortium Partner or partners shall be extended till contractual completion period including extension periods if any applicable.
- 23.2 'Stand alone' bidder cannot become a **'Prime Bidder' or a 'Consortium bidder' or 'Technical Tie up bidder' in a consortium (or Technical Tie up) bidding**. Prime bidder shall neither be a consortium partner to other prime bidder nor take any other consortium partners. However, consortium partner may enter into consortium agreement with other prime bidders. In case of non compliance, consortium bids of such Prime bidders will be rejected.
- 23.3 Number of partners for a consortium Bidding (or Technical Tie up) shall be as specified in the PQR
- 23.4 Prime Bidder shall be as specified in the Pre Qualification Requirement, else the bidder who has the major share of work
- 23.5 In order to be qualified for the tender, Prime Bidder and Consortium partner or partners shall satisfy (i) the Technical 'Pre Qualifying Requirements' specified for the respective package, (ii) "Assessment of Capacity of Bidder" as specified in clause 9.0
- 23.6 Prime Bidder shall comply with additional 'Technical' criteria of PQR as defined in 'Explanatory Notes for the PQR'
- 23.7 Prime Bidder shall comply with all other Pre Qualifying criteria for the Tender unless otherwise specified
- 23.8 In case customer approval is required, then Prime Bidder and Consortium Partner or partners shall have to be individually approved by Customer for being considered for the tender.
- 23.9 Prime Bidder shall be responsible for the overall execution of the contract
- 23.10 In case of award of job, Performance shall be evaluated for Prime Bidder and Consortium Partner or partners for their respective scope of work(s) as per prescribed formats
- 23.11 In case the Consortium partner or partners back out, their SDs shall be encashed by BHEL. In such a case, other consortium partner or partners meeting the PQR have to be engaged by the Prime Bidder, and if not, the respective work will be withdrawn and executed on risk and cost basis of the Prime Bidder. The new consortium partner or partners shall submit fresh SDs as applicable.
- 23.12 In case the prime Bidder withdraws, the whole contract shall be considered cancelled and short closed.
- 23.13 After execution of work, the work experience shall be assigned to the Prime Bidder and the consortium partner or partners for their respective scope of work. After successful execution of two similar works with the same consortium partner or partners under direct orders of BHEL, the Prime Bidder shall be eligible for becoming a 'stand alone' bidder for similar works, subject to certification from BHEL about the active involvement of the Prime Bidder for satisfactory execution of the works.
- 23.14 The consortium partner shall submit SD equivalent to 2% of the total contract value in addition to the SD to be submitted by the prime Bidder for the total contract value. In case there are two consortium partners, then each partner shall submit SD equivalent to 1% of the total contract value in addition to the SD to be submitted by the prime Bidder for the total contract value.
- 23.15 In case of a Technical Tie up, all the clauses applicable for the Consortium partner shall be applicable for the Technical Tie up partner also
- 24.0 The bidder shall submit documents in support of possession of 'Qualifying Requirements' duly self certified and stamped by the authorized signatory, indexed and properly linked in the format for PQR. In case BHEL requires any other documents/proofs, these shall be submitted immediately.
- 25.0 The bidder may have to produce original document for verification if so decided by BHEL.

26.0 Order of Precedence

In the event of any ambiguity or conflict between the Tender Documents, the order of precedence shall be in the order below:

- a. Amendments/Clarifications/Corrigenda/Errata etc issued in respect of the tender documents by BHEL
- b. Notice Inviting Tender (NIT)
- c. Price Bid
- d. Technical Conditions of Contract (TCC)—Volume-1A
- e. Special Conditions of Contract (SCC) —Volume-1B
- f. General Conditions of Contract (GCC) —Volume-1C
- g. Forms and Procedures —Volume-1D

It may please be noted that guidelines/rules in respect of suspension of business dealings, 'Vendor evaluation format', 'Quality, Safety & HSE guidelines', etc may undergo change from time to time and the latest one shall be followed

for BHARAT HEAVY ELECTRICALS LTD

AGM Purchase

Enclosure

01. Annexure-1: Pre Qualifying criteria.
02. Annexure-2: Check List.
03. Annexure – 3 IMPORTANT INFORMATION
04. Other Tender documents as per this NIT.

PRE QUALIFYING REQUIREMENTS

JOB	FOR RECEIPT OF MATERIALS FROM BHEL/ CUSTOMER STORES/ STORAGE YARD, SITE AND OTHER LOCATIONS, HANDLING AT STORES/ STORAGE YARD, SITE OF WORK, TRANSPORTATION BETWEEN STORES AND SITE OF WORK, ERECTION, TESTING, COMMISSIONING, FINAL PAINTING AND HANDING OVER OF STEAM TURBINE, TURBO-GENERATOR, CONDENSER, STG INTEGRAL PIPING, EXTERNAL/ REGENERATIVE ETC. WITH ASSOCIATED EQUIPMENTS/ TANKS/ VESSELS, FST, HP & LP HEATERS, DEAERATOR WITH ASSOCIATED PLATFORM, POWER CYCLE PUMPS & ASSOCIATED AUXILIARIES, R.E. JOINTS & B.F. VALVES ETC., LP BYPASS SYSTEM WITH ASSOCIATED AUX., BOUGHT OUT ITEMS AND PEM PACKAGES OF UNIT-3 OF 250 MW AT 2 x 250 MW SIKKA THERMAL POWER STATION GUJARAT STATE ELECTRICITY COORPORATION LIMITED DIST- JAMNAGAR GUJARAT
TENDER NO	BHE/PW/PUR/SKT-BAL STG U#3/1236

SL NO	PRE QUALIFICATION CRITERIA	Bidders claim in respect of fulfilling the PQR Criteria	
		Name and Description of qualifying criteria	Page no of supporting document. Bidder must fill up this column as per applicability
A	Submission of Integrity Pact duly signed (if applicable) (Note: To be submitted by Prime Bidder & Consortium/Technical Tie up partner jointly in case Consortium bidding is permitted, otherwise by the sole bidder)	NOT APPLICABLE	
B	<p><u>Technical</u> Bidder must have, executed any one of the jobs listed below in the last seven (7) years as on latest date of bid submission (i.e. Bidder must meet B.1 OR B.2 OR B.3)</p> <p>B.1 Executed Erection Testing & Commissioning (E T & C) of One STG job of one unit of 100 MW or higher</p> <p style="text-align: center;">OR</p> <p>B.2 Executed Erection Testing & Commissioning (E T & C) of One GTG job of one unit of 190 MW or higher</p> <p style="text-align: center;">OR</p> <p>B.3 Executed E T & C of Atleast One Boiler (With Rotating Machines upto</p>	APPLICABLE	

**BHEL PSWR
Notice Inviting Tender**

Tender Specification No: BHE/PW/PUR/SKT-BAL STG U#3/1236

Page 17 of 113

	<p>synchronization) of 400 MW or higher, under direct order of BHEL subject to:-</p> <p>a) Experience of (Executed) E T & C of STG of atleast 60 MW OR</p> <p>b) Entering into a technical tie up with an agency who has experience of (Executed) E T & C of STG of 60 MW or above</p>		
C-1	<p><u>Financial TURNOVER</u> Bidders must have achieved an average annual financial turnover (Audited) of Rs 125 Lakhs or more over last three Financial Years (FY) i.e. 2010-2011, 2011-12 & 2012-13</p>	APPLICABLE	
C-2	<p><u>NETWORTH</u> (only in case of Companies) Net worth of the Bidder based on the latest Audited Accounts as furnished for 'C-1' above should be positive</p>	APPLICABLE	
C-3	<p><u>PROFIT</u> Bidder must have earned cash profit in any one of the three Financial Years as applicable in the last three Financial Years defined in 'C-1' above based on latest Audited Accounts.</p>	APPLICABLE	
D	<p>Assessment of Capacity of Bidder to execute the work as per sl no 9 of NIT (if applicable)</p>	APPLICABLE	By BHEL
E	<p>Approval of Customer (if applicable)</p> <p>Note: Names of bidders (including consortium/Technical Tie up partners in case consortium bidding is permitted) who stand qualified after compliance of criteria A to D shall be forwarded to customer for their approval.</p>	APPLICABLE	BY BHEL
F	<p>Price Bid Opening</p> <p>Note: Price Bids of only those bidders shall be opened who stand qualified after compliance of criteria A to E</p>		BY BHEL
G	<p>Technical Tie up criteria (if applicable)</p>	APPLICABLE FOR SL No B.3.b	
	<p><u>Explanatory Notes for the PQR (unless otherwise specified in the PQR):</u></p> <ol style="list-style-type: none"> Bidder to submit Audited Balance Sheet and Profit and Loss Account for the respective years as indicated against C-1 above along with all annexures In case audited Financial statements have not been submitted for all the three years as indicated against C-1 above, then the applicable audited statements submitted by the bidders against the requisite three years, will be averaged for three years i.e total divided by three. 		

3. C-2:-NETWORTH : Shall be calculated based on the latest Audited Accounts as furnished for C-1 above. Net worth = Paid up share capital + Reserves. (Net worth is required to be evaluated in case of companies)
4. C-3:- PROFIT : shall be NET profit (PAT + Non cash expenditure viz depreciation) earned during any one of the three financial years as in C-1 above
5. ~~'Additional' Criteria in respect of 'Technical' criteria of PQR (as in 'B' above) for Civil, Electrical, CI, unless otherwise specified :~~
 1. ~~Bidder should have executed similar work of any one of the following:~~
 - a. ~~One (1) work of value not less than Rs XXX~~
~~OR~~
 - b. ~~Two (2) works of not less than Rs YYY~~
~~OR~~
 - c. ~~Three (3) works of not less than Rs ZZZ~~
(Value XXX, YYY, ZZZ shall be as indicated by BHEL)
 2. ~~'Similar' work for criteria 5 above means~~
 - a. ~~Civil or Structures or Civil & Structures or Chimney respectively as applicable to the tendered scope in respect of 'CIVIL' Works~~
 - b. ~~Electrical works in respect of 'ELECTRICAL'~~
 - c. ~~CI works in respect of 'CI' Works~~
 - d. ~~Material Handling and/or Management works in respect of 'MM' works~~
6. Time period for achievement of the 'Technical' criteria of PQR (as in 'B' above) will be the last 7 years ending on the 'latest date' of Bid submission
7. 'EXECUTED' means the Vendor should have achieved the criteria specified in the Technical criteria of PQR (as in 'B' above) even if the Contract has not been completed or closed
8. Unless otherwise specified, for the purpose of 'Technical' criteria of PQR (as in 'B' above), the word 'EXECUTED' means:
 1. "BOILER LIGHT UP" in respect of Boiler & Aux and ESP
 2. "SYNCHRONISATION" in respect of STG/GTG and 'SPINNING' in case of HTG
 3. "STEAM BLOWING COMPLETION" in respect of at least Main Steam Line of Power Cycle Piping
 4. "HYDRAULIC TEST" of the system in respect of Structures, Pressure parts/IBR Piping
 5. "CHARGING" in respect of power Transformers, Bus ducts, HT/LT switchgears
 6. "Completion of RCC Shell and liner (steel or brick as per tendered scope) up to the HEIGHT specified using slip form" in case of RCC Chimney.
 7. Achievement of physical Quantities as per respective PQRs in respect of Civil & Structures and Piling Works
 8. "Readiness for coal Filling" in respect of Bunker Structure Work.
9. Boiler means HRSG or WHRB or any other types of Steam Generator
10. ~~Critical/Power Cycle piping means Main Steam, Hot Reheat, Cold Reheat, HP Bypass, LP Bypass lines~~
11. For the purpose of evaluation of the PQR, one MW shall be considered equivalent to 3.5TPH where ever rating of HRSG/BOILER is mentioned in MW. Similarly, where ever rating of Gas Turbine is mentioned in terms of Frame size, ISO rating in terms of MW shall be considered for evaluation.
12. ~~In case the experience/POAWO certificate enclosed by bidders do not have separate break up prices for the E&C portion of Electrical and CI Works, (i.e. the certificates enclosed are for composite order for supply and erection of Electrical & CI and other works if any), then value of Erection and Commissioning for the Electrical & CI portion shall be considered as 15% of the supply & erection of Electrical & CI, unless otherwise specifically indicated in the PQR.~~

13. ~~Scope for capital overhaul of STG shall cover Bearing Inspection work and overhauling of all cylinders of the Turbine unless otherwise specifically indicated in the PQR.~~
14. In case the tendered scope is not a Pulverised Fuel Boiler, experience of Oil/Gas Fired Boilers also can be considered unless otherwise specifically indicated in the PQR
15. The value of work (Experience submitted against PQR B) shall be updated as per the PVC indices for "All India Avg. Consumer Price Index for Industrial Workers" with base month as date of execution (completion of contract/work) and indexed upto two months prior to bid opening month.

16. Explanatory Notes for PQR 'B.3.b'

- a. Agency with BOILER Experience shall be called as 'Prime Bidder' and the agency satisfying B.3.b shall be called as 'Tie-up Partner'
- b. Prime bidder and Tie-up Partner shall meet their respective technical Pre qualifying Criteria.
- c. Prime bidder shall meet all other Pre-Qualifying Criteria of the Tender
- d. Prime Bidder shall be responsible for overall execution of the Contract.
- e. Tie-up partner shall provide Technical Supervision and support to the Prime Bidder for execution of job.
- f. Tie-up Partner shall submit Security Deposit (SD) equivalent to 2 % of Total contract value in addition to the SD to be submitted by the Prime Bidder for the Contract Value.
- g. Prime bidder and the Tie-up partner are required to enter into a Tie-up Agreement with a validity period of Six months initially (During submission of tender). Thereafter both the agencies shall extend the validity of the agreement for the entire contract period, if the work is awarded.
- h. In case Tie-up partner backs out, another Tie-up partner meeting the QR shall be engaged by the Prime Bidder.
- i. In case Prime bidder backs out, the whole contract shall be considered cancelled and short closed

BIDDER SHALL SUBMIT ABOVE PRE-QUALIFICATION CRITERIA FORMAT, DULY FILLED-IN, SPECIFYING RESPECTIVE ANNEXURE NUMBER AGAINST EACH CRITERIA AND FURNISH RELEVANT DOCUMENT IN THE RESPECTIVE ANNEXURES IN THEIR OFFER.

**BHEL PSWR
Notice Inviting Tender**

Tender Specification No: BHE/PW/PUR/SKT-BAL STG U#3/1236

Page 20 of 113

ANNEXURE - 2

CHECK LIST

NOTE:- Tenderers are required to fill in the following details and no column should be left blank

1	Name and Address of the Tenderer		
2	Details about type of the Firm/Company		
3.a	Details of Contact person for this Tender	Name : Mr/Ms Designation: Telephone No: Mobile No: Email ID: Fax No:	
3.b	Details of alternate Contact person for this Tender	Name : Mr/Ms Designation: Telephone No: Mobile No: Email ID: Fax No:	
4	EMD DETAILS	DD No: Date : Bank : Amount: <u>Please tick (✓) whichever applicable:-</u> ONE TIME EMD / ONLY FOR THIS TENDER	
5	Validity of Offer	TO BE VALID FOR SIX MONTHS FROM DUE DATE	
		APPLICABILITY (BY BHEL)	ENCLOSED BY BIDDER
6	Whether the format for compliance with PRE QUALIFICATION CRITERIA (ANNEXURE-I) is understood and filled with proper supporting documents referenced in the specified format	Applicable	YES / NO
7	Audited profit and Loss Account for the last three years	Applicable/Not Applicable	YES/NO
8	Copy of PAN Card	Applicable/Not Applicable	YES/NO
9	Whether all pages of the Tender documents including annexures, appendices etc are read understood and signed	Applicable/Not Applicable	YES/NO
10	Integrity Pact	Applicable/Not Applicable	NO
11	Declaration by Authorised Signatory	Applicable/Not Applicable	YES/NO
12	No Deviation Certificate	Applicable/Not Applicable	YES/NO
13	Declaration confirming knowledge about Site Conditions	Applicable/Not Applicable	YES/NO
14	Declaration for relation in BHEL	Applicable/Not Applicable	YES/NO

<p>Registered Office : BHEL House, Siri Fort, New Delhi – 110 049, India Website : www.bhel.com</p>

**BHEL PSWR
Notice Inviting Tender**

Tender Specification No: BHE/PW/PUR/SKT-BAL STG U#3/1236

Page 21 of 113

15	Non Disclosure Certificate	Applicable/ Not Applicable	YES/NO
16	Bank Account Details for E-Payment	Applicable/ Not Applicable	YES/NO
17	Capacity Evaluation of Bidder for current Tender	Applicable/ Not Applicable	YES/NO
18	Tie Ups/Consortium Agreement are submitted as per format	Applicable/ Not Applicable	YES/NO
19	Power of Attorney for Submission of Tender/Signing Contract Agreement	Applicable/ Not Applicable	YES/NO
20	Analysis of Unit rates	Applicable/ Not Applicable	YES/NO

NOTE : STRIKE OFF 'YES' OR 'NO', AS APPLICABLE. TENDER NOT ACCOMPANIED BY THE PRESCRIBED **ABOVE APPLICABLE DOCUMENTS** ARE LIABLE TO BE SUMMARILY REJECTED.

DATE :

**AUTHORISED SIGNATORY
(With Name, Designation and Company seal)**

ANNEXURE 3

Registered Office : BHEL House, Siri Fort, New Delhi – 110 049, India Website : www.bhel.com

IMPORTANT INFORMATION

a. **TENDER SCOPE**

THIS SPECIFICATION IS FOR THE BALANCE LEFT OVER JOB OF UNIT # 3 STG E&C AND REGENERATIVE PIPING. ANNEXURE I 'WEIGHT DETAILS' OF THIS SPECIFICATION INDICATES ENTIRE WEIGHT OF THE COMPLETE SYSTEM. HOWEVER CHAPTER VII 'TERMS OF PAYMENT' OF THIS SPECIFICATION INDICATES THE QUANTUM OF WORK IN % WHICH IS ALREADY COMPLETED AND THE QUANTUM OF BALANCE WORKS. BIDDER HAS TO SUBMIT THEIR RATES ONLY FOR THE BALANCE LEFTOVER JOB

- b. All Bidders shall make site visits on working day to familiarize with the site conditions and to get exact details of extent of work completed.
- c. Any clause in this specification which is not pertaining to the balance works of these specification shall be treated as deleted at the sole discretion
- d. There is a BHEL Store located outside the Project Premises at about 4 KM distance from erection site.
- e. The offers of the bidders who are on the banned list as also the offer of the bidders, who engage the services of the banned firms, shall be rejected. The list of banned firms is available on BHEL web site (www.bhel.com ---> Tender Notification -> List of Banned Firms)
- f. All Statutory Requirements as applicable for this project shall be complied with.
- g. Please take note of following Revised Tender Clauses:
 - i. Notice Inviting Tender: SI No 9
 - ii. General conditions of Contract: Clause No 1.15.13 (New), Clause No 2.8.3, 2.8.4 and 2.8.5
- h. Following Notes are added to Form F- 15 of Volume I D 'Forms & procedures'
 - i. It is only indicative and shall be as per the online format issued by BHEL time to time.
 - ii. No request will be entertained after specified date of the current month w.r.t the changes requested in the scores of immediate previous month.

i. PRICE VARIATION CLAUSE

Price Variation Compensation Clause no. 2.17 of Vol I C GCC shall not be Applicable:

j. OVER RUN COMPENSATION

Over Run Compensation Clause no. 2.12 of Vol I C GCC shall not be Applicable

k. Broad Terms & Conditions of Reverse Auction

In continuation to Clause 19.0 of NIT (Notice Inviting Tender) following are the broad terms and conditions of Reverse Auction is given in Annexure V of NIT:

- I. Against this enquiry for the subject item/ system with detailed scope of supply as per enquiry specifications, BHEL may resort to "REVERSE AUCTION PROCEDURE" i.e., ON LINE BIDDING (THROUGH A SERVICE PROVIDER). The philosophy followed for reverse auction shall be English Reverse (No ties).
- II. BHEL reserves the right to go for Reverse Auction (RA) instead of opening the sealed envelope price bid, submitted by the bidder. This will be decided after techno-commercial evaluation. All bidders to give their acceptance for participation in RA. Non-acceptance to participate in RA may result in non-consideration of their bids. In case BHEL decides to go for Reverse Auction, only those bidders who have given their acceptance to participate in RA will be allowed to participate in the Reverse Auction. Those bidders who have given their acceptance to participate in Reverse Auction will have to necessarily submit „online sealed bid“ in the Reverse Auction. Non-submission of „online sealed bid“ by the bidder will be considered as tampering of the tender process and will invite action by BHEL as per extant guidelines in vogue.
- III. For the proposed reverse auction, technically and commercially acceptable bidders only shall be eligible to participate.
- IV. Those bidders who have given their acceptance for Reverse Auction (quoted against this tender enquiry) will have to necessarily submit 'online sealed bid' in the Reverse Auction. Non-submission of 'online sealed bid' by the bidder for any of the eligible items for which techno-commercially qualified, will be considered as tampering of the tender process and will invite action by BHEL as per extant guidelines in vogue.
- V. BHEL will engage the services of a service provider who will provide all necessary training and assistance before commencement of on line bidding on internet.
- VI. In case of reverse auction, BHEL will inform the bidders the details of Service Provider to enable them to contact & get trained.
- VII. Business rules like event date, time, bid decrement, extension etc. also will be communicated through service provider for compliance.

**BHEL PSWR
Notice Inviting Tender**

Tender Specification No: BHE/PW/PUR/SKT-BAL STG U#3/1236

Page 24 of 113

-
- VIII. Bidders have to fax the Compliance form (annexure IV) before start of Reverse auction. Without this, the bidder will not be eligible to participate in the event.
- IX. In line with the NIT terms, BHEL will provide the calculation sheet (e.g., EXCEL sheet) which will help to arrive at "Total Cost to BHEL" like Packing & forwarding charges, Taxes and Duties, Freight charges, Insurance, Service Tax for Services and loading factors (for noncompliance to BHEL standard Commercial terms & conditions) for each of the bidder to enable them to fill-in the price and keep it ready for keying in during the Auction.
- X. Reverse auction will be conducted on scheduled date & time.
- XI. At the end of Reverse Auction event, the lowest bidder value will be known on auction portal.
- XII. The lowest bidder has to fax/e-mail the duly signed and filled-in prescribed format for price breakup including that of line items, if required, (Annexure VII) as provided on case-to-case basis to Service provider within two working days of Auction without fail.
- XIII. In case BHEL decides not to go for Reverse Auction procedure for this tender enquiry, the Price bids and price impacts, if any, already submitted and available with BHEL shall be opened as per BHEL's standard practice.
- XIV. Bidders shall be required to read the "Terms and Conditions" section of the auctions site of Service provider, using the Login IDs and passwords given to them by the service provider before reverse auction event. Bidders should acquaint themselves of the "Business Rules of Reverse Auction", which will be communicated before the Reverse Auction.
- XV. If the Bidder or any of his representatives are found to be involved in Price manipulation/ cartel formation of any kind, directly or indirectly by communicating with other bidders, action as per extant BHEL guidelines, shall be initiated by BHEL and the results of the RA scrapped/ aborted.
- XVI. The Bidder shall not divulge either his Bids or any other exclusive details of BHEL to any other party.
- XVII. In case BHEL decides to go for reverse auction, the H1 bidder (whose quote is highest in online sealed bid) may not be allowed to participate in further RA process.

1236

TECHNICAL CONDITIONS OF CONTRACT (TCC)

BHARAT HEAVY ELECTRICALS LIMITED



TECHNICAL CONDITIONS OF CONTRACT (TCC) CONTENTS

SI No	DESCRIPTION	Chapter	No. OF PAGES
Volume-IA	Part-I: Contract specific details		
1	Project Information	Chapter-I	2
2	Scope of Works	Chapter-II	1
3	Facilities in the scope of Contractor/BHEL	Chapter-III	7
4	T&Ps and MMDs to be deployed by Contractor	Chapter-IV	2
5	T&Ps to be deployed by BHEL free of hire charges on sharing basis	Chapter-V	1
6	Time Schedule	Chapter-VI	2
7	Terms of Payment	Chapter-VII	6
8	Taxes and other Duties	Chapter-VIII	2
9	Specific Inclusion	Chapter-IX	3
10	Specific Exclusion	Chapter-X	1
	Annexures		
	Weight Details	Annexure I	23
Volume-IA	Part-II : Technical Specifications		
11	General	Chapter-XI	5
12	Civil Works, Foundation, Grouting	Chapter-XII	2
13	Equipments Installation	Chapter-XIII	1
14	Piping Installation	Chapter-XIV	2
15	Condenser Installation	Chapter-XV	1
16	Generator & Handling Heavier equipments	Chapter-XVI	2

TECHNICAL CONDITIONS OF CONTRACT (TCC) CONTENTS

17	Hydrostatic Testing Preservation & other tests	Chapter-XVII	2
18	Pre Commissioning Tests, Commissioning, Post Commissioning	Chapter-XVIII	4
19	Welding, Heat Treatment, Radiography	Chapter-XIX	4
20	Acid cleaning/alkali flushing/steam blowing/oil flushing	Chapter-XX	2
21	Tools and tackles, measuring and monitoring devices	Chapter-XXI	3
22	Preservative Painting	Chapter-XXII	1
23	Lining and Insulation	Chapter-XXIII	3
24	Final painting	Chapter-XXIV	3

3 Nos Drawings are uploaded as a part of Corrigendum 01:

TECHNICAL CONDITIONS OF CONTRACT (TCC)

Chapter - I : Project Information

	Project Information
1.1	INTRODUCTION Sikka Thermal Power Station is presently having two sets (units) of 120 MW units in operating condition. The plant owner M/s Gujarat State Electricity Corporation Limited (GSECL) has undertaken expansion of this power plant by installing two units of 250 MW each (name plate rating) in the same premises. Though both the new units are of 250 MW name plate rating, they are guaranteed to produce an output of 270 MW each. Both Units are at about Boiler Light and Turbine Box up Stage. This Tender is applicable only for UNIT-3 ALONE for Balance works from a midway terminated contract. The Bidder shall acquaint himself by a visit to the site, if felt necessary, with the conditions prevailing at site before submission of the bid. The information given here in under is for general guidance and shall not be contractually binding on BHEL/ Owner. All relevant site data/information as may be necessary shall have to be obtained /collected by the Bidder.
1.2	LOCATION AND APPROACH In Sikka, Jamnagar district, Latitude 22 ^o 26' N & Longitude 69 ^o 49' E. The site is surrounded by villages Mungai, Sikka, Gagva & Nanikkhavri of Jamnagar district of Gujarat state. Access by Road: It is connected to State Highway (SH-25) by a 5 km long road through Sikka village. Access by Railways: Jamnagar – Okha broad-gauge section is passing at a distance of 12 km from Sikka. Nearest Airport: Jamnagar Nearest Seaport: Okha & Navalakhinare located 140 Km & 130 Km respectively from the site.
1.3	Other Salient Information: 1. Owner M/s GSECL 2. Owner's Consultant M/s TCE, Bangalore 3. Project Title 2x250 MW Sikka TPS Extension Units # 3 & 4 4. Location 12 km from Sikka, District – Jamnagar, Gujarat 5. Nearest Railway Stn. Jamnagar
1.4	CLIMATIC CONDITIONS 1.Ambient Air Temperature

TECHNICAL CONDITIONS OF CONTRACT (TCC)
Chapter - I : Project Information

	a. Maximum	42 Deg. C
	b. Minimum	8 Deg. C
	2. Relative Humidity	
	c. Maximum	100%
	d. Minimum	21%
	3. Rainfall	
	e. Average annual	650 mm
	f. Maximum	900 mm
	g. Minimum	400 mm
	4. Wind Data	
	h. Basic wind speed at 10m height	50 m/sec
	i. Wind pressure	As per IS: 875 Part III
	5. Seismic Zone	
		Zone IV as per IS: 1893-2002

THE BIDDER IS ADVISED TO VISIT AND EXAMINE THE SITE OF WORKS AND ITS SURROUNDINGS AND OBTAIN FOR HIMSELF ON HIS OWN RESPONSIBILITY ALL INFORMATION THAT MAY BE NECESSARY FOR PREPARING THE BID AND ENTERING INTO THE CONTRACT. ALL COSTS FOR ASSOCIATED WITH SITE VISITS SHALL BE BORNE BY THE BIDDER.

TECHNICAL CONDITIONS OF CONTRACT (TCC)

Chapter - II : Scope of Works

2.0 SCOPE OF WORK

The work to be carried out under the scope of these specifications is broadly as under:

Collection of materials from BHEL/client's stores/storage yard; transportation to site; erection, testing & assistance for commissioning, trial operation, PG Test and handing over of the **Balance works of Unit-3 ONLY** at GSECL Sikka 2 x250 MW unit#3 & 4

:-

BALANCE WORKS IN UNIT-3

1. Steam Turbines & Turbo Generators along with associated equipment.
2. Condensate system comprising of Surface condenser, Gland steam Condenser, Vacuum Pumps for each Steam Turbine Unit.
3. Regenerative cycle auxiliaries comprising of CEP, LP Heaters, MDBFP, HP Heaters along with associated piping for Steam Turbine.
4. Hot well make up Pump and associated piping & control valves.
5. Central Lube oil storage & transfer system.
6. Thermal insulation refractory & cladding of piping & equipments.
7. Condenser On load Tube cleaning system.
8. Provision of Wet Steam Washing System.
9. Special grouts like Pagal VI for grouting for TG.
10. Special embedment and foundation bolts, O & M platform required for BHEL supplied equipment. Other embedment for piping etc. shall be in EPIL's scope.
11. Empty H2 & CO2 cylinder.
12. Generator Hydrogen gas purity analyser including all accessories like piping, valves, flanges etc.
13. Acoustic Enclosure for STG.
14. Painting of all erected equipments and structures.
15. TG Integral piping.
16. Operating platform around the , gsc, flash tanks, lube oil / control oil tanks, HP/LP by pass valves, ESVS / IVS, local platforms for various inaccessible valves and equipment etc.
17. Etc.

TECHNICAL CONDITIONS OF CONTRACT (TCC)
Chapter – III: Facilities in the scope of Contractor/BHEL

Sl.No	Description	Scope / to be taken care by		Remarks
		BHEL	Bidder	
3.1	ESTABLISHMENT			
3.1.1	FOR CONSTRUCTION PURPOSE:			
a	Open space for office (as per availability)	Yes		Location will be finalized after joint survey with owner
b	Open space for storage (as per availability)	Yes		Location will be finalized after joint survey with owner
c	Construction of bidder's office, canteen and storage building including supply of materials and other services		Yes	
d	Bidder's all office equipments, office / store / canteen consumables		Yes	
e	Canteen facilities for the bidder's staff, supervisors and engineers etc		Yes	
f	Fire fighting equipments like buckets, extinguishers etc		Yes	
g	Fencing of storage area, office, canteen etc of the bidder		Yes	
3.1.2	FOR LIVING PURPOSES OF THE BIDDER			
a	Open space for labour colony (as per availability)		Yes	Electricity, Water etc for Labour colony is also in the scope of Contractor

TECHNICAL CONDITIONS OF CONTRACT (TCC)
Chapter – III: Facilities in the scope of Contractor/BHEL

Sl.No	Description PART I	Scope / to be taken care by		Remarks
		BHEL	Bidder	
b	Labour Colony with internal roads, sanitation, complying with statutory requirements		Yes	
3.2.0	ELECTRICITY			
3.2.1	Electricity For construction purposes 3 Phase of Voltage 415/440 V			FREE
a	Single point source	Yes		at one point near the erection site
b	Further distribution including all materials, Energy Meter, Protection devices and its service		Yes	
c	Duties and deposits including statutory clearances if applicable		Yes	
3.2.2	Electricity for the office, stores, canteen etc of the bidder			FREE
a	Single point source	Yes		
b	Further distribution including all materials, Energy Meter, Protection devices and its service		Yes	
c	Duties and deposits including statutory clearances if applicable		Yes	

TECHNICAL CONDITIONS OF CONTRACT (TCC)
Chapter – III: Facilities in the scope of Contractor/BHEL

Sl.No	Description PART I	Scope / to be taken care by		Remarks
		BHEL	Bidder	
3.2.3	Electricity for living accommodation of the bidder's staff, engineers, supervisors etc		Yes	Bidder to make his own arrangement
a	Single point source		Yes	
b	Further distribution including all materials, Energy Meter, Protection devices and its service		Yes	
c	Duties and deposits including statutory clearances if applicable		Yes	
3.3.0	WATER SUPPLY			
3.3.1	For construction purposes: (to be specified whether chargeable or free)			FREE
a	Making the water available at single point	Yes		
b	Further distribution as per the requirement of work including supply of materials and execution		Yes	
3.3.2	<u>Water supply for bidder's office, stores, canteen etc</u>			FREE
a	Making the water available at single point	Yes		

TECHNICAL CONDITIONS OF CONTRACT (TCC)
Chapter – III: Facilities in the scope of Contractor/BHEL

Sl.No	Description PART I	Scope / to be taken care by		Remarks
		BHEL	Bidder	
b	Further distribution as per the requirement of work including supply of materials and execution		Yes	
3.3.3	<u>Water supply for Living Purpose</u>		yes	Bidder to make his own arrangement
a	Making the water available at single point		Yes	
b	Further distribution as per the requirement of work including supply of materials and execution		Yes	
3.4.0	LIGHTING			
a	For construction work (supply of all the necessary materials) 1. At office/storage area 2. At the preassembly area 3. At the construction site /area		Yes	
b	For construction work (execution of the lighting work/ arrangements) 1. At office/storage area 2. At the preassembly area 3. At the construction site /area		Yes	
c	Providing the necessary consumables like bulbs, switches, etc during the course of project work		Yes	
d	Lighting for the living purposes of the bidder at the colony / quarters		Yes	

TECHNICAL CONDITIONS OF CONTRACT (TCC)
Chapter – III: Facilities in the scope of Contractor/BHEL

Sl.No	Description PART I	Scope / to be taken care by		Remarks
		BHEL	Bidder	
3.5.0	COMMUNICATION FACILITIES FOR SITE OPERATIONS OF THE BIDDER			
a	Telephone, fax, internet, intranet, e-mail etc		Yes	
3.6.0	COMPRESSED AIR wherever required for the work		Yes	
3.7.0	Demobilization of all the above facilities		YES	
3.8.0	TRANSPORTATION			
a	For site personnel of the bidder		Yes	
B	For bidder's equipments and consumables (T&P, Consumables etc)		Yes	

TECHNICAL CONDITIONS OF CONTRACT (TCC)
Chapter – III: Facilities in the scope of Contractor/BHEL

Sl. No	Description PART II 3.9.0 ERECTION FACILITIES	Scope / to be taken care by		Remarks
		BHEL	Bidder	
3.9.1	Engineering works for construction:			
a	Providing the erection drawings for all the equipments covered under this scope	Yes		
b	Drawings for construction methods	Yes		
c	As-built drawings – where ever deviations observed and executed and also based on the decisions taken at site- example – routing of small bore pipes		Yes	In consultation with BHEL
d	Shipping lists etc for reference and planning the activities	Yes		
e	Preparation of site erection schedules and other input requirements		Yes	In consultation with BHEL
f	Review of performance and revision of site erection schedules in order to achieve the end dates and other commitments	Yes	Yes	In consultation with BHEL
g	Weekly erection schedules based on Sl No. e		Yes	In consultation with BHEL
h	Daily erection / work plan based on Sl No. g		Yes	In consultation with BHEL

TECHNICAL CONDITIONS OF CONTRACT (TCC)
Chapter – III: Facilities in the scope of Contractor/BHEL

Sl. No	Description	Scope / to be taken care by		<i>Remarks</i>
		BHEL	Bidder	
	PART II 3.9.0 ERECTION FACILITIES			
i	Periodic visit of the senior official of the bidder to site to review the progress so that works are completed as per schedule. It is suggested this review by the senior official of the bidder should be done once in every two months.		Yes	
j	Preparation of preassembly bay		Yes	
k	Laying of racks for gantry crane if provided by BHEL or brought by the contractor/bidder himself		Yes	
L	Arranging the materials required for preassembly		Yes	

TECHNICAL CONDITIONS OF CONTRACT (TCC)
Chapter – IV: T&Ps to be deployed by Contractor for each unit

MAJOR TOOLS AND PLANTS & MMDs TO BE DEPLOYED BY THE CONTRACTOR FOR EACH UNIT

S.N.	DESCRIPTION	CAPACITY	QUANTITY
1	TYRE MOUNTED HYDRAULIC CRANES	14 MT	2 NOs
2	TRAILER WITH HORSE	30 TON	1 NO
3	TRAILER TROLLEY	20 TON	1 NO
4	WELDING GENERATOR SETS (ELECTRIC AS WELL AS DIESEL)		AS PER REQUIREMENT
5	3- PHASE COMPLETE SET UP FOR DRAWAL OF POWER		-DO-
6	RADIOGRAPHY ARRANGEMENT INCLUDING THE SOURCE AND FILM VIEWER		-DO-
7	TIG WELDING SET		-DO-
8	STRESS RELIEVING EQUIPMENT WITH TEMPERATURE RECORDERS		-DO-
9	ELECTRICAL BAKING OVEN - BIG		-DO-
10	ELECTRODE BAKING OVEN - PORTABLE		-DO-
11	MIXER FOR GROUTING OF EQUIPMENT FOUNDATIONS		-DO-
12	VACUUM CLEANER (INDUSTRIAL)		-DO-
13	PIPE CUTTING AND BEVELLING MACHINE		-DO-
14	PIPE BENDING M/C	ELECTRIC/ ELECTRO - HYDRAULIC - UPTO 4" SIZE	-DO-
15	AIR COMPRESSOR	120 CFM	01 NO
16	STEP DOWN TRANSFORMER	230V/24V	AS PER REQUIREMENT
17	CONDENSER TUBE EXPANDER SET		DO
18	ELECTRICALLY OPERATED WINCHES	3T/5T	DO
19	JACKING BOLTS / PRESSOUT BOLTS OF ALL SIZES (FOR ST. TURBINE ROLL CHECKS ETC.)		DO
20	HYDRAULIC JACKS OF VARIOUS CAPACITIES FOR ST. TURBINE AND GENERATOR :		
21	A) - JACKS (WITH HAND OPERATED PUMPS)	100 MT	04 NOS.
	B) - JACKS (WITH HAND OPERATED PUMPS)	50 MT	04 NOS.
	GANG OPERATED JACKS CONSISTING OF THE FOLLOWING :		
	A) - JACKS (HAVING BROAD BASE ONE INCH LIFT)	100 MT	04 NOS.
	B) - JACKS (WITH 4-6 INCH LIFT , FOR GEN. END SHIELDS)	63 MT	04 NOS.
	C) - LONG HIGH PRESSURE HOSES (FOR GENERATOR ALIGNMENT)		08 NOS.

TECHNICAL CONDITIONS OF CONTRACT (TCC)

Chapter – IV: T&Ps to be deployed by Contractor for each unit

	C) - LONG HIGH PRESSURE HOSES (FOR GENERATOR ALIGNMENT)		08 NOS.
ABOVE JACKS FOR GENERATOR ALIGNMENT SHOULD HAVE SUITABLE COUPLING FOR JOINING THE TWO OR MORE HOSES TOGETHER TO GET DESIRED LENGTH OF HOSES, SHOULD HAVE HAND OPERATED PUMPS & ALSO SHOULD BE ABLE TO FIT WITH HYDRAULIC UNIT.			
22	TORQUE WRENCH	UPTO 2000 N-M	01 NO.
23	SLINGS FOR LP TURBINE ROTOR		02SET
24	SLINGS FOR HP TURBINE MODULE		02SET
25	SLINGS FOR GENERATOR ROTOR		02SET
26	BOLT STRETCHING DEVICE (FOR TURBINE & GENERATOR FOUNDATION BOLTS)		AS PER REQUIREMENT
27	LONG FEELER GAUGE SET		AS PER REQUIREMENT
28	SPANNERS / EYE BOLTS (OF ALL SIZES)		AS PER REQUIREMENT
29	HYDRAULIC TEST PUMPS AND FILL PUMPS		AS PER REQUIREMENT
30			

TORQUE WRENCH

B: MEASURING AND MONITORING DEVICES (MMD):

To be finalized at site as per requirement.

NOTE:

1.

The above list at A & B is only indicative and neither exhaustive nor limiting. Quantities indicated above are only the minimum required. Contractor shall deploy all necessary T&P to meet the schedules & as prescribed by BHEL engineer and required for completion of work.

TECHNICAL CONDITIONS OF CONTRACT (TCC)
Chapter – V: T&Ps to be deployed by BHEL free of hire charges on sharing basis

A:

SN	DESCRIPTION & CAPACITY OF T&P	QUANTITY	PURPOSE
01	EOT CRANE IN TG HALL	1 No. (ON SHARING BASIS WITH OTHER AGENCY)	FOR HANDLING AND ERECTION WITHIN TG HALL ON SHARING BASIS AS AVAILABLE AND SUBJECT TO THEIR ACCESSIBILITY AND APPROACHABILITY.

NOTE:

1. **Operator** for EOT crane will be provided **by the contractor**.
2. EOT crane will be used on sharing basis by other agencies working within the TG hall under the instruction of BHEL. The contractor shall extend the services of his operator to such other agencies as well on mutually agreed mode of cost sharing.
3. Above T&P will be provided on sharing basis only. Contractor has to plan his activities well in advance and inform BHEL Engineer in charge/ Construction Manager the date of actual use.

TECHNICAL CONDITIONS OF CONTRACT (TCC)

Chapter – VI: Time Schedule

6.1 MOBILIZATION, TIME SCHEDULE & CONTRACT PERIOD

6.1.1 INITIAL MOBILIZATION

Contractor shall reach site, make his site establishment and be ready to commence the erection work within one **WEEK** from the date of issue of Fax Letter of Intent or as per the directions of Construction Manager/ Project Manager of BHEL.

6.1.2 MOBILIZATION FOR ERECTION, TESTING, ASSISTANCE FOR COMMISSIONING ETC

The activities for erection, testing etc shall be started as per the directions of construction manager of BHEL. Contractor shall mobilize further resources **WITHIN ONE WEEK OF DATE OF LoI** (in addition to those required for activities under clause no. 6.1.1) as per the requirement to commence the work of erection as and where, testing etc of TG and auxiliaries and progressively augment the resources to match schedule of the project.

6.1.3 COMMENCEMENT OF CONTRACT PERIOD AND TENTATIVE SCHEDULE

Full mobilization of manpower, resources, submission of Organisation Chart, Action Plan, Material Reconciliation with respect to extent of work completed in a jointly signed Protocol, Taking Over of Completed/ unfinished/ Semi-finished work/ equipments/ fronts with proper jointly signed PROTOCOL and start of Erection/placement/ alignment of equipment covered in the scope of these specifications instructed by Construction Manager and issue of Certificate clearly indicating the specific compliance of these requirement with evidence, shall be recognized as “start of contract period of THIS contract”:-

Contractor is likely to mobilise fully and commence the work under scope of this contract in First Week of April, 2014.

During execution of contract, based on the availability of civil foundations from customer and materials from manufacturing units, contractor may have to advance the start of erection after getting clearance from construction manager, or the start of erection may get delayed due to site condition.

The contractor has to subsequently augment his resources in such a manner that following major milestones of erection & commission are achieved on specified schedules:

Milestones	SCHEDULE
Commencement of Contract Work	APRIL 2014
Condenser Hydro Test	JUN 2014
Turbine Box-Up	JUN 2014
Start of Turbine Oil flushing	JUN 2014
Barring Gear	JULY 2014
Hydro Test Blanking and Steam Blowing arrangements	JULY 2014
Rolling & Synchronization	SEP 2014
Capacity Addition	OCT 2014

TECHNICAL CONDITIONS OF CONTRACT (TCC)

Chapter – VI: Time Schedule

Trial Run

NOV 2014

In order to meet above schedule in general, and any other intermediate targets set, to meet customer/ project schedule requirements, contractor shall arrange & augment all necessary resources from time to time as per the instructions of BHEL.

DURATION

The total contract period for completion of entire work for This Balance work of Unit-3 shall be **07 (Seven) months** and **03 (Three) months' Grace Period** from the start of erection as specified earlier. The Contractor shall complete all milestones and physical works within 07 months and attend to final works including Final Billing, Punch Points, Material Reconciliation etc. in the Grace Period of 03 months. For operation of contract the Total contract period shall be reckoned at **10 months**.

However, the contractor shall have to mobilize his resources earlier than the start of contract period for the work as per instruction of Construction Manager or his Engineer.

The contractor shall complete all the works in the scope of this contract within the contract period. Pending points identified by the customer/BHEL during the execution of the contract are to be liquidated during the contract period itself. Contractor to carry out installation of impulse pipes, fittings, thermowells /thermo couples etc required for successful completion of Performance Guarantee test and provide in assistance for installation & removal of PG test instruments and conductance of test.

TECHNICAL CONDITIONS OF CONTRACT (TCC)

Chapter-VII: Terms of Payment

The progressive payment for erection, testing and commissioning on accepted price of contract value per unit of STG Package rates will be released as per the break up given hereinafter **in the last column of the table below. Weightages in column 2 of table below indicates portion of the work already completed. Bidder shall submit their Lumpsum price for STG E&C Balance works except Regenerative Piping and PMT rates for piping.**
FOR STG

TCCSL. NO.	PARTICULARS	Design Total for One Unit (%)	WEIGHTAGE COMPLETED (%)	Balance work for This Tender (%)	Terms of Payment for Thjs Tender (in %)
1	CONDENSER (WEIGHTAGE 20 %)				
1.1	PREPARATION OF FOUNDATION	2%	2.00%	0.00%	0
1.2	PLACEMENT ,ALIGNMENT,ASSEMBLY AND WELDING OF BOTTOM PLATE SEGMENTS,HOT WELL,NDT AND SPRING ELEMENTS PLACEMENT AND GROUTING	10%	9.0%	1.00%	2.38
1.3	ASSEMBLY AND POSITIONING OF WATER CHAMBER,SIDE PLATES,BOTTOM PLATES,WELDING AND NDT INCLUDING HINGE ASSY.	12%	10.0%	2.00%	4.76
1.4	ASSEMBLY ,ALIGNMENT AND WELDING & NDT OF TUBE SUPPORT PLATES AND INTERNALS LIKE BAFFLE PLATES,AIR EVACUATION PIPES ETC.	13%	12.0%	1.00%	2.38
1.5	ASSEMBLY,WELDING & NDT OF DOME WALLS AND DOME STIFFENERS,EXTRACTION PIPING AND STEAM THROW DEVICE ,LPH-1 SUPPORT ECT.	10%	5.0%	5.00%	11.9
1.6	INSERTION,EXPANSION,CUTTING ETC.. OF CONDENSER TUBES.	15%	7.0%	0.00%	0
1.9	HYDRO TEST OF STEAM AND WATER SIDE.	10%	0.0%	5.00%	11.9
1.10	WELDING OF CONDENSER NECK JOINT AND NDT & COMPLETION OF BAALCNE WORKS.	10%	0.0%	10.00%	23.81
1.11	ERECTION,COMMISSIONING,LOAD RESTING OF CONDENSER WATER BOX HANDLING SYSTEM	3%	0.0%	3.00%	7.14
5	OIL FLUSHING (TG)	1%	0.0%	1.00%	2.38
6	BARRING GEAR (TG)	1%	0.0%	1.00%	2.38
7	ROLLING AND SYNCHRONISATION	3%	0.0%	3.00%	7.17
9	FULL LOAD	2%	0.0%	2.00%	4.76
10	TRIAL OPERATION OF UNIT	2%	0.0%	2.00%	4.76
11	PAINTING (INCLUDING ARROW MAKING,NOMENCLATURE,ETC..)	2%	0.0%	2.00%	4.76
12	AREA CLEANING,TEMPORARY STRUCTURES CUTTING/REMOVAL AND RETURN OF SCRAP	1%	0.0%	1.00%	2.38

TECHNICAL CONDITIONS OF CONTRACT (TCC)

Chapter-VII: Terms of Payment

TCCSL. NO.	PARTICULARS	Design Total for One Unit (%)	WEIGHTAGE COMPLETED (%)	Balance work for This Tender (%)	Terms of Payment for Thjs Tender (in %)
13	PUNCH LIST POINTS/PENDING POINTS LIQUIDATION	1%	0.0%	1.00%	2.38
15	MATERIAL RECONCIALLATION	1%	0.0%	1.00%	2.38
16	COMPLETION OF CONTRACTUAL OBLIGATIONS	1%	0.0%	1.00%	2.38
		100%	45.0%	42.00%	100.00
2	TURBINE (WEIGHTAGE - 18 %)				
2.1	PREPARATION OF FOUNDATION,PLACEMENT,ALIGNMENT AND GROUTING OF BASE PLATES OF LPC AND BEARING PEDESTALES.	7%	7.0%	0.00%	0
2.2	PLACEMENT AND ALIGNMENT OF LP OUTER CASING BOTTOM PORTION AND CENTRE GUIDE KEYS.	5%	1.0%	3.00%	4.32
2.3	PLACEMENT OF LP ROTOR AND ALIGNMENT WITH INNER CASING AND CHECKING OF BLADE CLEARANCE	9%	0.0%	1.50%	2.16
2.4	ASSEMBLY ,ALIGNMENT & WELDING OF LP OUTER CASING UPPER HALF	9%	0.0%	9.00%	12.97
2.5	PLACEMENT AND ALIGNMENT OF IP TURBINE OUTER CASING AND INNER CASING (LOWER HALVES)	2%	1.3%	0.00%	0
2.6	PLACEMENT AND ALIGNMENT OF IP ROTOR WITH LOWER CASING AND BOXING UP OF INNER & OUTER CASING (UPPER HALVES) & ROLL CHECK.	5%	3.5%	1.50%	2.16
2.7	FINAL BOX UP OF IP TURBINE	0%	0.0%	0.00%	0
2.8	BOXING UP OF LP INNER-INNER & INNER-OUTER AND ROLL CHECK.	5%	0.0%	4.00%	5.76
2.9	PLACEMENT OF HP TURBINE , LOWERING OF HP ROTOR ON BEARINGS AND CHECKING OF CLEARANCES, COUPLING HP TURBINE SWING CHECKS ETC.	5%	3.5%	1.00%	1.44
2.10	ALIGNMENT OF ALL ROTORS INCLUDING REAMING, HONING AND FIXING OF COUPLING BOLTS.	9%	0.0%	9.00%	12.97
2.11	ASSEMBLY OF GOVERNING SYSTEM/EQUIPMENT	5%	0.0%	5.00%	7.2
2.12	INSTALLATION OF ESVS, IVS , LPBP VALVES, MS STRAINERS (INTERNALS), HRH STRAINERS (INTERNALS)	9%	0.0%	5.40%	7.78
2.13	ERECTION,ALIGNMENT AND WELDING OF CROSS AROUND PIPING	5%	0.0%	5.00%	7.2
2.14	FINAL BOX-UP OF LP TURBINE	5%	0.0%	5.00%	7.2

TECHNICAL CONDITIONS OF CONTRACT (TCC)

Chapter-VII: Terms of Payment

TCCSL. NO.	PARTICULARS	Design Total for One Unit (%)	WEIGHTAGE COMPLETED (%)	Balance work for This Tender (%)	Terms of Payment for Thjs Tender (in %)
2.15	ASSEMBLY AND PREPARATION OF HYDRO-TEST, STEAM BLOWING DEVICES AND NORMALISATION ETC.	0%	0.0%	0.00%	0
2.16	FINAL BOXING UP OF PEDESTALS AFTER OIL FLUSHING COMPLETION	5%	0.0%	5.00%	7.24
5	OIL FLUSHING (TG)	1%	0.0%	1.00%	1.44
6	BARRING GEAR (TG)	1%	0.0%	1.00%	1.44
7	ROLLING AND SYNCHRONISATION	3%	0.0%	3.00%	4.32
9	FULL LOAD	2%	0.0%	2.00%	2.88
10	TRIAL OPERATION OF UNIT	2%	0.0%	2.00%	2.88
11	PAINTING (INCLUDING ARROW MAKING,NOMENCLATURE,ETC..)	2%	0.0%	2.00%	2.88
12	AREA CLEANING,TEMPORARY STRUCTURES CUTTING/REMOVAL AND RETURN OF SCRAP	1%	0.0%	1.00%	1.44
13	PUNCH LIST POINTS/PENDING POINTS LIQUIDATION	1%	0.0%	1.00%	1.44
15	MATERIAL RECONCIALLATION	1%	0.0%	1.00%	1.44
16	COMPLETION OF CONTRACTUAL OBLIGATIONS	1%	0.0%	1.00%	1.44
		100%		69.40%	100
3	TURBO GENERATOR (WEIGHTAGE - 15 %)				
3.1	PREPARATION OF FOUNDATION , LEVELLING , MATCHING AND GROUTING OF FOUNDATION PLATES.	5%	5.00%	0.00%	0
3.2	LIFTING ,LEVELLING AND ALIGNMENT OF STATOR (INCLUDING ERECTION AND COMMISSIOING OF STRAND & JACK FOR STATOR LIFTING)	23%	10.00%	8.00%	11.19
3.3	FIXING OF END SHIELDS ON TO FOUNDATION BEAMS	6%	2.5%	3.50%	4.9
3.4	ROTOR INSERTION	6%	6.0%	0.00%	0
3.5	BOXING UP OF GENERATOR AND ASSEMBLY OF HYDROGEN SEALS.	11%	0.0%	11.00%	15.38
3.6	ALIGNMENT OF GENERATOR ROTOR ,RUN-OUT CHECKS AND REAMING ,HONING OF COUPLING HOLES AND FIXING OF COUPLING BOLTS	9%	0.0%	9.00%	12.57
3.7	ERECTION OF EXCITATION EQUIPMENTS & ALIGNMENT OF GEN-EXCITER ROTORS INCLUDING SWING CHECK AND COMPLETION OF BALANCE WORKS	10%	0.0%	10.00%	13.99

TECHNICAL CONDITIONS OF CONTRACT (TCC)

Chapter-VII: Terms of Payment

TCCSL. NO.	PARTICULARS	Design Total for One Unit (%)	WEIGHTAGE COMPLETED (%)	Balance work for This Tender (%)	Terms of Payment for Thjs Tender (in %)
3.8	INSTALLATION OF ENCLOSURES OF GENERATOR/EXCITER WITH ALL AUXILIARIES	5%	0.0%	5.00%	6.99
3.9	GROUTING OF GEN BARING PEDESTALS AND EXCITOR	5%	0.0%	5.00%	6.99
3.10	FINAL GAS TIGHTNESS TEST OF STATOR WITH COMPLETE SYSTEM	5%	0.0%	5.00%	6.99
5	OIL FLUSHING (TG)	1%	0.0%	1.00%	1.4
6	BARRING GEAR (TG)	1%	0.0%	1.00%	1.4
7	ROLLING AND SYNCHRONISATION	3%	0.0%	3.00%	4.2
9	FULL LOAD	2%	0.0%	2.00%	2.8
10	TRIAL OPERATION OF UNIT	2%	0.0%	2.00%	2.8
11	PAINTING (INCLUDING ARROW MAKING,NOMENCLATURE,ETC..)	2%	0.0%	2.00%	2.8
12	AREA CLEANING,TEMPORARY STRUCTURES CUTTING/REMOVAL AND RETURN OF SCRAP	1%	0.0%	1.00%	1.4
13	PUNCH LIST POINTS/PENDING POINTS LIQUIDATION	1%	0.0%	1.00%	1.4
15	MATERIAL RECONCIALLATION	1%	0.0%	1.00%	1.4
16	COMPLETION OF CONTRACTUAL OBLIGATIONS	1%	0.0%	1.00%	1.4
		100%		71.50%	100
4	PUMPS AND AUXILIARIES (WEIGHTAGE - 13%)				
4.1	ERECTION / TESTING AND COMMISSIONING OF MAIN OIL PUMP ,JOP,EOP, AOP,CENTRALISED LUBE OIL PURIFICATION SYSTEM, ALONG WITH ALL AUXILIARIES	18%	5.0%	13.00%	21.67
4.2	ERECTION, TESTING AND COMMISSIONING OF THREE MOTOR DRIVEN BFP, ALONG WITH ALL AUXILIARIES	44%	17.00%	24.00%	40
4.5	ERECTION, TESTING, GROUTNG ETC. OF DMCW (BOILER&TG) PUMPS	13%	8.0%	5.00%	8.32
4.6	ERECTION,TESTING, GROUTING ETC. OF CONDENSATE EXTRACTION PUMPS	10%	7.0%	3.00%	5
5	OIL FLUSHING (TG)	1%		1.00%	1.67
6	BARRING GEAR (TG)	1%		1.00%	1.67
7	ROLLING AND SYNCHRONISATION	3%		3.00%	5
9	FULL LOAD	2%		2.00%	3.33
10	TRIAL OPERATION OF UNIT	2%		2.00%	3.33
11	PAINTING (INCLUDING ARROW MAKING,NOMENCLATURE,ETC..)	2%		2.00%	3.33

TECHNICAL CONDITIONS OF CONTRACT (TCC)

Chapter-VII: Terms of Payment

TCCSL. NO.	PARTICULARS	Design Total for One Unit (%)	WEIGHTAGE COMPLETED (%)	Balance work for This Tender (%)	Terms of Payment for Thjs Tender (in %)
12	AREA CLEANING,TEMPORARY STRUCTURES CUTTING/REMOVAL AND RETURN OF SCRAP	1%		1.00%	1.67
13	PUNCH LIST POINTS/PENDING POINTS LIQUIDATION	1%		1.00%	1.67
15	MATERIAL RECONCIALLATION	1%		1.00%	1.67
16	COMPLETION OF CONTRACTUAL OBLIGATIONS	1%		1.00%	1.67
		100%	37.0%	60.00%	100
5	HEATERS (WEIGHTAGE - 05%)				
5.1	ERECTION, TESTING & COMMISSIOING OF HP&LP HEATERS	50%	38.00%	12.00%	26.09
5.2	ERECTION,TESTING & COMMISSIOING OF GLAND STEAM CONDENSER, DRAIN COOLERS	35%	16.0%	19.00%	41.32
5	OIL FLUSHING (TG)	1%		1.00%	2.17
6	BARRING GEAR (TG)	1%		1.00%	2.17
7	ROLLING AND SYNCHRONISATION	3%		3.00%	6.52
9	FULL LOAD	2%		2.00%	4.35
10	TRIAL OPERATION OF UNIT	2%		2.00%	4.35
11	PAINTING (INCLUDING ARROW MAKING,NOMENCLATURE,ETC..)	2%		2.00%	4.35
12	AREA CLEANING,TEMPORARY STRUCTURES CUTTING/REMOVAL AND RETURN OF SCRAP	1%		1.00%	2.17
13	PUNCH LIST POINTS/PENDING POINTS LIQUIDATION	1%		1.00%	2.17
15	MATERIAL RECONCIALLATION	1%		1.00%	2.17
16	COMPLETION OF CONTRACTUAL OBLIGATIONS	1%		1.00%	2.17
		100%		46.00%	100
6	MISCELLANEOUS ITEMS (WEIGHTAGE - 13%)				
6.1	DEBRIS FILTERS,RE JOINTS, ME BELLOWS, DIRTY, CLEAN OIL TANKS,ENCLOSURES, CO2/H2 CYLINDER RACKS ETC.	20%	0.0%	20.0%	27.4
6.2	ACW PUMPS,RELATED ITEMS/ BOILERS FILL PUMPS	10%	7.0%	3.0%	4.11
6.3	ERECTION , TESTING & COMMISSIONING OF CONTROL FLUID TANK,C.F COOLERS,.C.F PUMPS,PURIFICATION UNIT ETC.	9%	2.0%	7.0%	9.59
6.4	ERECTION , TESTING & COMMISSIONING OF FLASH TANKS & FLASH VESSELS	8%	5.0%	3.0%	4.11

TECHNICAL CONDITIONS OF CONTRACT (TCC)

Chapter-VII: Terms of Payment

TCCSL. NO.	PARTICULARS	Design Total for One Unit (%)	WEIGHTAGE COMPLETED (%)	Balance work for This Tender (%)	Terms of Payment for Thjs Tender (in %)
6.5	ERECTION,TESTING & COMMISSIONING OF PLATE HEAT EXCHANGER PACKAGE	10%	8.0%	2.0%	2.74
6.6	ERECTION ,TESTING & COMMISSIONING OF CONDENSER ON LOAD TUBE CLEANING PACKAGE/ CONENSATE TRANSFER PUMPS.	12%	0.0%	12.0%	16.44
6.7	ERECTION, TESTING & COMMISSIONING OF SELF CLEANING STRAINER PACKAGE	8%	5.0%	3.0%	4.1
6.8	ERECTION TESTING & COMMISSIONING OF MISC. HOISTS & CHAIN PULLEY BLOCKS	8%	0.0%	8.0%	10.96
5	OIL FLUSHING (TG)	1%		1.0%	1.37
6	BARRING GEAR (TG)	1%		1.0%	1.37
7	ROLLING AND SYNCHRONISATION	3%		3.0%	4.11
9	FULL LOAD	2%		2.0%	2.74
10	TRIAL OPERATION OF UNIT	2%		2.0%	2.74
11	PAINTING (INCLUDING ARROW MAKING,NOMENCLATURE,ETC..)	2%		2.0%	2.74
12	AREA CLEANING,TEMPORARY STRUCTURES CUTTING/REMOVAL AND RETURN OF SCRAP	1%		1.0%	1.37
13	PUNCH LIST POINTS/PENDING POINTS LIQUIDATION	1%		1.0%	1.37
15	MATERIAL RECONCIALLATION	1%		1.0%	1.37
16	COMPLETION OF CONTRACTUAL OBLIGATIONS	1%		1.0%	1.37
		100%		73	100
7	INTEGRAL PIPING (WEIGHTAGE-16%)				
7.1	TURBINE INTEGRAL PIPING AND GENERATOR INTEGRAL PIPING CONSISTING OF LUBE OIL,JACKING OIL,OIL VAPOUR EXTRACTION,SEAL OIL,CONTROL OIL,SEAL STEAM,CONDENSATE SPRAY/EXHAUST HOOD SPRAY ,TURBINE WATER DRAINAGE,GAS PIPING , PRIMARY STATOR WATER PIPING ETC.INCLUDING ALL ACCESSORIES LIKE THERMOWELLS,PROBES,ORIFICES ETC. AND HANGERS AND SUPPORTS (ERECTION AND COMMISSIONING ON PRORATA BASIS)	85%	4.00%	79.500%	84.11
5	OIL FLUSHING (TG)	1%		1.000%	1.06
6	BARRING GEAR (TG)	1%		1.000%	1.06
7	ROLLING AND SYNCHRONISATION	3%		3.000%	3.17
9	FULL LOAD	2%		2.000%	2.12
10	TRIAL OPERATION OF UNIT	2%		2.000%	2.12
11	PAINTING (INCLUDING ARROW MAKING,NOMENCLATURE,ETC..)	2%		2.000%	2.12
12	AREA CLEANING,TEMPORARY STRUCTURES CUTTING/REMOVAL AND	1%		1.000%	1.06

TECHNICAL CONDITIONS OF CONTRACT (TCC)

Chapter-VII: Terms of Payment

TCCSL. NO.	PARTICULARS	Design Total for One Unit (%)	WEIGHTAGE COMPLETED (%)	Balance work for This Tender (%)	Terms of Payment for Thjs Tender (in %)
	RETURN OF SCRAP				
13	PUNCH LIST POINTS/PENDING POINTS LIQUIDATION	1%		1.000%	1.06
15	MATERIAL RECONCIALLATION	1%		1.000%	1.06
16	COMPLETION OF CONTRACTUAL OBLIGATIONS	1%		1.000%	1.06
		100%		94.500%	100
9	PIPING				
8	ON PRE-ASSEMBLY WHEREEVER APPLIACABLE	15%	0.00	95.6	15%
8.1	PLACEMENT IN POSITION	20%	0.00	95.6	20%
8.2	ALIGNMENT	15%	0.00	95.6	15%
8.3	WELDING/BOLTING/FIXING	20%	0.00	95.6	20%
8.4	COMPLETION OF NON DESTRUCTIVE EXAMINATION & STRESS RELIEVING/HEAT TREATMENT)	5%	0.00	95.6	5%
8.5	HANGERS & SUPPORTS ETC WHEREEVER NECESSARY AS PER DRG.	5%	0.00	95.6	5%
8.6	HYDRAULIC TEST / PNEUMATIC TEST WHERE EVER APPLICABLE	5%	0.00	95.6	5%
8.7	OIL FLUSHING (TG)	1%	0.00	95.6	1%
5	BARRING GEAR (TG)	1%	0.00	95.6	1%
6	ROLLING AND SYNCHRONISATION	3%	0.00	95.6	3%
7	FULL LOAD	2%	0.00	95.6	2%
9	TRIAL OPERATION OF UNIT	2%	0.00	95.6	2%
10	PAINTING (INCLUDING ARROW MAKING,NOMENCLATURE,ETC..)	2%	0.00	95.6	2%
11	AREA CLEANING,TEMPORARY STRUCTURES CUTTING/REMOVAL AND RETURN OF SCRAP	1%	0.00	95.6	1%
12	PUNCH LIST POINTS/PENDING POINTS LIQUIDATION	1%	0.00	95.6	1%
13	MATERIAL RECONCIALLATION	1%	0.00	95.6	1%
15	COMPLETION OF CONTRACTUAL OBLIGATIONS	1%	0.00	95.6	1%
16		100%	0.00		100%

Note:

1. Wherever application of INSULATION is applicable, same shall be covered under the respective item/ equipment for 'Terms of Payment'.
2. The terms of payment is only for enabling release of payments through RABs and is not indicative of the actual quantum or value of work.

TECHNICAL CONDITIONS OF CONTRACT (TCC)

Chapter-VIII: Taxes and Other Duties

8.0 TAXES, DUTIES, LEVIES (Consolidated Rev 03 dated 09/04/2013)

8.1. For All types of works excepting works covered under sl no 8.2

8.1.1

The contractor shall pay all (save the specific exclusions as enumerated in this contract) taxes, fees, license charges, deposits, duties, tools, royalty, commissions or other charges which may be levied on the input goods & services consumed and output goods & services delivered in course of his operations in executing the contract. In case BHEL is forced to pay any of such taxes, BHEL shall have the right to recover the same from his bills or otherwise as deemed fit.

However, provisions regarding Service Tax and Value Added Tax (VAT) on output services and goods shall be as per following clauses.

8.1.2 Service Tax & Cess on Service Tax

Contractor's price/rates shall be exclusive of Service Tax and Cess on Services. In case, it becomes mandatory for the contractor under provisions of relevant act/law to collect the Service Tax & Cess from BHEL and pay the same to the concerned tax authorities, such applicable amount will be paid by BHEL at the prevailing Service Tax Rate (presently 12.36 %) on the admitted bill value.

Contractor shall submit to BHEL documentary evidence of Service Tax registration certificate specifying name of services covered under this contract. Contractor shall submit serially numbered Service Tax and Cess Invoice, signed by him or a person authorized by him in respect of taxable service provided, and shall contain the following, namely,

1. The name, address and the registration number of the contractor,
2. The name and address of the party receiving taxable service,
3. Description, classification and value of taxable service provided and,
4. The service tax payable thereon.

All the Four conditions shall be fulfilled in the invoice before release of service tax payment.

Wherever, more than one route/option are available for discharge of service tax liability under a particular service, (e.g. "works contract Service"), contractor shall obtain prior written consent from BHEL site before billing the amount towards Service Tax.

8.1.3 VAT (Sales Tax /WCT)

As regards Value Added Tax (VAT)/CST on transfer of property in goods involved in Works Contract (previously known as Works Contract Tax) applicable as per local laws, the price quoted by the contractor shall be inclusive of the same and in no case input or output VAT/CST will be reimbursed extra.

In any case the Contractor shall register himself with the respective Sales Tax authorities of the state and submit proof of such registration to BHEL along with the first RA bill. Contractor will submit all the details of VAT/CST paid for the contract in the prescribed format of the respective state VAT laws. Also, the

TECHNICAL CONDITIONS OF CONTRACT (TCC)

Chapter-VIII: Taxes and Other Duties

contractor will issue the tax Invoices to BHEL as per the Tax laws of respective state on monthly basis. Contractor shall also be required to furnish to BHEL necessary proof of VAT remittance on monthly basis.

Deduction of tax at source shall be made as per the provisions of law and is to be construed as an advance tax paid by the contractor and no reimbursement thereof will be made.

Further, if BHEL, at the instance of customer or otherwise adopts the specific route for discharging output VAT liability itself, benefit of the reduction in liability of the contractor will be passed on to BHEL.

In case, BHEL is forced to pay any VAT liability on behalf of contractor, the same will be recovered from contractor's bill or otherwise as deemed fit

8.2 'Enabling Works'

~~The contractor shall pay all (save the specific exclusions as enumerated in this contract) taxes, fees, license charges, deposits, duties, tools, royalty, commissions or other charges which may be levied on the input goods & services consumed and output goods & services delivered in course of his operations in executing the contract. In case BHEL is forced to pay any of such taxes, BHEL shall have the right to recover the same from his bills or otherwise as deemed fit. (i.e. rates quoted by bidder shall be inclusive of Service Tax, VAT/WCT and all other taxes and duties)~~

~~However, Since the proposed work is in the nature of 'Works Contract service' as per Service tax law, Hence, For non-corporate contractors being Individual, HUF, Proprietary Firm, Partnership Firm or Association of Persons (AOP), BHEL shall recover the applicable Service Tax under reverse charge mechanism from the contractor and remit the same with the Government as per the provisions of Law. Necessary advice/confirmation of remittance shall be issued to the contractor. The contractor shall not be eligible for any refund/reimbursement of such service tax from BHEL. It shall be the responsibility of the contractor to submit proper invoice giving all the requisite details as per Service Tax Law for the determination of the service tax liability of BHEL under reverse charge mechanism. BHEL reserves the right to determine such liability based on the invoice submitted by the contractor or otherwise independently and remittance of the same with the Government.~~

8.3 New Taxes/Levies

In case the Government imposes any new levy/tax on the output service/ goods/work after award of the contract, the same shall be reimbursed by BHEL at actual.

In case any new tax/levy/duty etc. becomes applicable after the date of Bidder's offer, the Bidder/Contractor must convey its impact on his price duly substantiated by documentary evidence in support of the same **before opening of Price Bid**. Claim for any such impact after opening the Price Bid will not be considered by BHEL for reimbursement of tax or reassessment of offer.

No reimbursement/recovery on account of increase/reduction in the rate of taxes, levies, duties etc. on input goods/services/work shall be made. Such impact shall be taken care of by the Price Variation/Adjustment Clause (PVC) if any. In case PVC is not applicable for the contract, Bidder has to make his own assessment of the impact of future variation if any, in rates of taxes/duties/ levies etc. in his price bid.

TECHNICAL CONDITIONS OF CONTRACT (TCC)

Chapter-IX : SPECIFIC INCLUSIONS

SPECIFIC INCLUSIONS

9.1

All terminal connections for equipment & piping covered in this specification.

9.2

Impulse/ pneumatic piping between customer's battery limit and equipments.

9.3

Servicing and assembly of control valves/regulating valves, fixing of filter elements/strainers & steam blowing & blanking devices in LP bypass, MS strainer, HRH strainer & and blanking of LP bypass, ESV & IV system, for hydro test, steam blowing etc is the part of scope of work.

9.4

It may be specifically noted that it should not be construed or claimed by the contractor that with the technical specification and "exclusions and/or inclusions" detailed in this tender specification, BHEL has covered the entire scope of work and/or the details thereof to be executed by the contractor.

9.5

Assembly and installation of strainer elements of MS and HRH system is within the scope of work. Cleaning of these strainer elements during trial operation of machine is also covered under this scope.

9.6

Chipping of foundation, placement, erection, alignment, commissioning, grouting, mounting of equipment mount instruments, panels and other fittings of BHEL (PEM bought out items) supplied pumps & packages are in scope of the work. Erection and commissioning of these equipments/pumps & packages will be required to complete and meet the commissioning schedule/ milestone activities of other areas like boiler, etc. Contractor shall plan and complete erection & commissioning of these equipments on priority as per decision of BHEL engineer/customer requirement. Details of such systems are furnished in relevant appendix.

9.7

Most of the Misc. Pumps with drive motors, base frame, fittings etc will be supplied in loose parts/ dismantled condition as skid mount. These pumps along with drive and fittings shall be assembled at site. The Delivery will be taken from BHEL stores/storage yard and will be assembled/ installed at different locations as per drawing and instruction of BHEL Engineer at site. The work involved is preservation, assembly, installation, erection, alignment, foundation grouting including providing non-shrink free flow grout mix material, fixing of loose items, filling of lubricants, greasing, commissioning, no load/ load trial run of motors & pumps. All the works shall be carried out as part of scope of work.

These Misc. pumps will be required for erection and commissioning of other systems, pipings, equipments which will be under scope of erection of other agencies. Contractor shall carry out

TECHNICAL CONDITIONS OF CONTRACT (TCC)

Chapter-IX : SPECIFIC INCLUSIONS

the installation, erection and alignment works etc. as per priority decided by BHEL Engineer at site to enable the other agencies to proceed with their work. Contractor shall carry out the welding of terminal point/interface/matching & connected flanges joints, pipe joints etc. of other system & other agencies as scope of work. The decision of BHEL Engineer shall be final and binding on contractor.

9.8

Electric wire rope hoists shall be erected tested and commissioned for vacuum pump motor handling and CW butterfly valves handling. Chain pulley blocks with trolley (manual operated) shall be erected, tested and commissioned for control fluid system, central lube oil system etc.

9.9

CONSUMABLES

The contractor shall provide all consumables required for carrying out the work covered under these specifications excepting those which are specifically indicated as BHEL scope.

TG special consumables like hylomar / golden hermetite / stag-b / molykote/ anabond compounds / rubber fixing compounds etc will have to be arranged by the contractor.

9.10

All consumables to be used for the work shall have prior approval of BHEL engineer with regard to brand and quality specifications. Test reports / certificates in respect of these consumables, wherever applicable, shall be submitted to BHEL engineer.

9.11

PRIMERS & PAINTS

BHEL will provide paint & primer for final painting only. Primers and paints for other requirements are in contractor's scope.

9.12

WELDING ELECTRODES, FILLER WIRES FOR TIG WELDING AND GASES

All welding consumables including filler wires are in the contractor's scope.

9.13

All the required welding electrodes as approved by BHEL shall be arranged by contractor at his cost. It shall be the responsibility of the contractor to obtain prior approval of BHEL, before procurement, regarding manufacturer, type of electrodes etc. on receipt of the electrodes at site, it shall be subject to inspection and approval by BHEL regarding type of electrodes, batch number, date of expiry etc. Batch test certificates shall be made available for verification & record before the actual use of the welding consumables.

BHEL reserves the right to reject the use of any electrodes, if found non-acceptable because of bad quality, deterioration in quality due to improper storage, shelf life expiry, unapproved type / brand etc.

9.14

TECHNICAL CONDITIONS OF CONTRACT (TCC)

Chapter-IX : SPECIFIC INCLUSIONS

The contractor shall provide all consumables required for carrying out the work covered under this scope of work including TIG wires for welding of piping joints.

9.15

All the required gases like argon, oxygen, and acetylene etc including required high purity nitrogen gas (for purging of generator stator water system) shall be arranged by the contractor at his cost.

TECHNICAL CONDITIONS OF CONTRACT (TCC)

Chapter-X : SPECIFIC EXCLUSIONS

10.0 EXCLUSIONS

The following are specific exclusions from the scope of work/ specification:-

- A) All cable connections, except those specified as scope of work.
- B) Measuring instruments, monitoring, relaying, protection and signaling equipments other than those supplied with the equipments by / on behalf of BHEL and which have been indicated as scope of work.
- C) Electrical testing of motors, turbo-generator. However erection of these items will be under the scope of this tender specification.
- D) Impulse piping and fittings from the tapping points of various equipments other than those specified as scope of work.
- E) Civil works to the extent not specifically provided for in this tender.
- F) Supply of materials for temporary piping (pipe, valve, structural steel etc.) required for hydraulic test, chemical cleaning, flushing or steam/air blowing of the pipelines.
- G) Supply of chemicals and lube oil for pre-commissioning and commissioning activities.
- H) Some sub-delivery items and electrical components such as push-buttons, junction boxes etc.
- I) E&C work of cable trays, cables and earthing etc
- J) All electrical and control & instrumentation items except those specified elsewhere in these specifications.
- K) Supply of primer and paints for final painting
- L) Pneumatic copper tubing and fittings thereof.

TECHNICAL CONDITIONS OF CONTRACT (TCC)
Annexure-I
WEIGHT DETAILS OF ONE UNIT

1	STEAM TURBINE & AUX.(Hardwar Supply)		
SN	DESCRIPTION	PACKAGE SIZE IN MM	Gr.WEIGHT(KG)
1	SOLE PLATE PEDESTAL ANCHOR	3400X1200X800	2510
2	BASE PLATE ASSEMBLY	4500X1400X1200	4500
3	BASE PLATE ASSEMBLY	2300X1250X600	2560
4	BASE PLATE L.P.CASING	2300X2075X981	2680
5	LP OUTER CASING PARTS	7060X1480X2760	8085
6	LP OUTER CASING PARTS	7060X1480X2760	8085
7	LPC OUTER CASING PARTS	4570X3230X980	2500
8	LPC OUTER CASING PARTS	4570X3230X980	2500
9	COMPONENTS OF LP CASING UPPERPART	3500X300X300	495
10	L.P OUTER CASING PARTS	3450X1000X1100	900
11	ASSEMBLY DEVICES	900X700X550	180
12	INSPECTION SHAFT FOR IPC	3300X700X700	775
13	VALVE SUPPORT FOR HP OVERHAUL	1000X1000X400	800
14	COMPONENTS OF ASSY.FIXTURE FOR HPT	3800X2500X1200	6864
15	COMPONENTS OF ASSEMBLY FIXTURE OF HPT	2200X1200X850	1800
16	COMPONENTS OF ASSY.FIXTURE FOR HPT	3300X1800X1210	3352
17	COMPONENTS OF ASSEMBLY FIXTURE FOR H.P.TURBINE	5010X4000X120	3356
18	HP-IP BREARING PEDESTAL ASSLY.	4080X2005X2126	13275
19	HP/IP BRG.PED.PARTS	1000X600X600	438

BHEL-PSWR

TECHNICAL CONDITIONS OF CONTRACT (TCC)

Annexure-I

WEIGHT DETAILS OF ONE UNIT

20	HP/IP BRG.PED.PARTS	500X200X150	37
21	AUXILIARIES OF LP TURBINE	3000X1300X1000	2100
22	AUXILIARIES OF LP TURBINE	2000X1000X1825	1142
23	AUXILIARIES OF LP TURBINE	2000X1000X1825	1142
24	LP JOINT COVERING	2300X1800X940	1041
25	ASSEMBLY TOOLS	1900X1000X890	560
26	CAP(SPRING SUPPORT)	825X500X400	400
27	CAP(SPRING SUPPORT)	825X500X400	400
28	CAP (COMPEN.ASSY)	3240X1740X1340	3316
29	CAP (COMPEN.ASSY)	3240X1740X1340	3512
30	CAP(OBLIQUE REDUCER ASSLY)	1400X1400X1200	590
31	CAP (MITRE BEND ASSY)	1550X1550X1300	670
32	CAP (COMPEN.ASSY)	3240X1740X1340	3512
33	CAP (MAN-HOLE ASSLY)	1500X1600X1100	750
34	CAP (MAN-HOLE ASSLY)	1500X1600X1100	750
35	CAP(MITRE BEND ASSY)	1550X1550X1300	670
36	CAP (MITRE BEND ASSY)	1550X1550X1300	670
37	CAP (PIPE ASSLY)	2000X1100X1200	645
38	CAP (MITRE BEND ASSY)	1550X1550X1300	670
39	LONGITUDINAL GIRDER (LEFT)	6800X1820X1570	15182
40	LONGITUDINAL GIRDER (RIGHT)	6800X1820X1570	15182
41	LP FRONT WALL (TS)	6820X3750X910	10053
42	LP FRONT WALL (GS)	6820X3750X910	10053
43	LP SHAFT SEALING FRONT	1800X1700X740	2260
44	LP SHAFT SEAL COMPENSATORASSLY.(TS)	1440X1420X520	1456

TECHNICAL CONDITIONS OF CONTRACT (TCC)

Annexure-I

WEIGHT DETAILS OF ONE UNIT

45	LP SHAFT SEALING (REAR)	1800X1700X740	2260
46	LP SHAFT SEAL COMPENSATOR ASSLY.(GS)	1440X1420X520	1456
47	LP CASING ASSEMBLY (FASTENERS)	1800X1700X740	2653
48	LP CASING ASSEMBLY (PARTS)	3760X2060X860	4900
49	LP CASING ASSEMBLY (PARTS)	450X450X250	340
50	EXTRACTION PIPE LINE (LPC)	1600X1000X750	520
51	EXTRACTION PIPE LINE (LPC)	2700X1350X750	670
52	EXTRACTION PIPE LINE (LPC)	2000X1200X600	1004
53	EXTRACTION PIPE LINE (LPC)	2900X1100X700	650
54	EXTRACTION PIPE LINE (LPC)	2900X1100X700	650
56	EXTRACTION PIPE LINE (LPC)	2700X1200X750	575
57	EXTRACTION PIPE LINE (LPC)	1100X850X850	307
58	EXTRACTION PIPE LINE (LPC)	2700X1750X1100	689
59	EXTRACTION PIPE LINE (LPC)	1550X1450X900	530
60	EXTRACTION PIPE LINE(LPC)	2000X600X600	366
61	L.P. EXTRACTION PIPE SHEATHING	2600X2000X1400	1290
62	INNER GUIDE PLATE OF DIFFUSER(TS)	2600X2400X1000	2118
63	INNER GUIDE PLATE OF DIFFUSER(GS)	2600X2400X1000	2118
64	DIFFUSER (TS)	4880X1730X2340	3640
65	DIFFUSER (GS)	4880X1730X2340	3640
66	AUXILIARIES OF I.P. TURBINE	1050X480X550	390

TECHNICAL CONDITIONS OF CONTRACT (TCC)

Annexure-I

WEIGHT DETAILS OF ONE UNIT

67	AUXILIARIES OF I.P. TURBINE	1100X500X650	204
68	AUXILIARIES OF I.P. TURBINE	1100X500X650	204
69	LP-GEN. PEDESTAL ASSEMBLY	3220X2285X2075	10200
70	IP-LP PEDESTAL ASSEMBLY	3700X1860X2100	14600
71	LP INNER OUTER CASING (U/H)	6720X3150X2325	21750
72	LP INNER OUTER CASING (L/H) & LP INNER INNER CASING (L/H)	6750X3500X2350	30907
73	LP INNER CASING ASSY.FASTENERS	1800X1700X740	1760
74	LP INNER-INNER CASING (U/H) PARTIAL	4000X1570X2000	11722
75	STEAM INLET PIPE (LPT)STEAM INLET PIPE (LPT)	2700X1300X900	840
76	L.P. ROTOR	7210X3300X3350	62049
77	BEARING PEDESTAL ARRANGT.PARTS	1800X900X800	1100
78	STUD HEATING DEVICE AND BREECH NUT HEATING DEVICE.	1500X1200X250	315
79	GROMMET SLINGS	1500X1500X350	280
80	IP TURBINE	4860X3753X3210	81679
81	HP TURBINE	5060X3100X2900	56100
82	HP INLET ASSEMBLY	450X450X200	45
83	H.P.EXHAUST ASSEMBLY	1625X1335X675	1378
84	HPT RELATED PARTS	1000X1000X500	190
85	HP FRONT BEARING PEDESTAL	3500X3000X2050	11939
86	HP FRONT BRG. PEDESTAL PARTS	1800X1700X1000	844
87	I.P TURBINE PARTS	700X700X500	285

TECHNICAL CONDITIONS OF CONTRACT (TCC)

Annexure-I

WEIGHT DETAILS OF ONE UNIT

88	RATING, COLLABORATION AND MONOGRAM PLATES	850X550X150	50
89	OIL FLUSHING AND PRESSURE TEST DEVICE	750X400X550	130
90	SUPPORT FOR IV VALVE	1500X1000X750	410
91	STEAM BLOWING & HYD. TEST DEV.	2900X2100X1140	2730
95	TOOLS AND PACKING DEVICES	1750X1200X980	684
96	ASSEMBLY DEVICE FOR VALVES	920X1000X450	213
97	ESV & CV CASING WITH VALVES ESV & CV CASING WITH VALVES	3000X3000X1900	9800
98	ESV & CV CASING WITH VALVES	3000X3000X1900	9800
105	IV & CV CASING WITH VALVES. IV & CV CASING WITH VALVES.	4500X3500X2600	21500
106	IV & CV CASING WITH VALVES. IV & CV CASING WITH VALVES.	4500X3500X2600	21500
110	IV & CV CASING WITH VALVES. IV & CV CASING WITH VALVES.	4500X3500X2600	21500
111	PARTS OF IV & CV CASING	1500X1000X200	100
112	PARTS OF IV & CV CASING	1500X1000X200	100
113	INJECTOR FOR SUC. PIPE NB350	3300X1750X1210	1029
114	MAIN OIL TANK & NOZZLE ARRGT.ASSY.	5180X3260X2650	9100
115	MAIN OIL TANK & NOZZLE ARRANGEMENT	4200X1100X800	550
118	OIL STRIPPER	600X600X850	133

TECHNICAL CONDITIONS OF CONTRACT (TCC)

Annexure-I

WEIGHT DETAILS OF ONE UNIT

119	OIL STRAINERS	2050X1200X1410	568
120	VARIABLE ORIFICES THROTTLE VALVES & FLUSHING PARTS	1000X500X250	115
121	HOUSING FOR MS STRAINER	1700X1025X900	2200
122	HOUSING FOR M.S STRAINER	1725X1250X730	2200
123	STEAM STRAINER ASSEMBLY DEVICE MS & HRH	2140X1400X500	652
124	HOUSING FOR HRH STEAM STRAINER	2200X1450X1100	3500
125	HOUSING FOR HRH STEAM STRAINER	2200X1450X1100	3500
126	STEAM STRAINER (MS)	1100X700X350	374
127	STEAM STRAINER (HRH)	1600X1450X750	485
128	BLANKING ARRANGEMENT FOR MS STRAINER HOUSING	1000X900X800	490
129	BLANKING ARRANGEMENT FOR HRH STEAM STRAINER HOUSING	1600X1200X1000	1090
130	BLANKING ARRANGEMENT FOR MS STRAINER HOUSING	1000X900X800	490
131	BLANKING ARRANGEMENT FOR HRH STEAM STRAINER HOUSING	1600X1200X1000	1090
132	STEAM STRAINER HOUSING GASKETS	700X700X300	50
133	COMPENSATOR	600X600X900	50
134	LEAKAGE OIL TANK	1000X1000X3000	515
135	WASTE OIL TANK	1000X1000X3000	515
136	INJECTOR FOR SUC. PIPE NB 400	3500X750X750	922

TECHNICAL CONDITIONS OF CONTRACT (TCC)

Annexure-I

WEIGHT DETAILS OF ONE UNIT

137	TURBINE INSTRUMENTS RACKS	2750X1000X800	2690
138	TURBINE INSTRUMENTS RACKS	2300X750X750	765
139	IMPULSE PIPES (CARBON STEEL)	6900X650X650	1585
140	PRESS.TRANSMITTERS,SWITCHES&GAUGES	2800X1250X1250	825
141	TRANSMITTERS & J.B.OF BEARINGS	500X300X200	110
142	IMPULSE PIPES (ALLOY STEEL)	6900X300X300	400
TOTAL(kg)			584585

2	TURBO GENERATOR & AUXILIARIES (HARDWAR SUPPLY)		
SN	DESCRIPTION	PACKAGE SIZE IN MM	Gr.WEIGHT(KG)
1	FOUNDATION ITEMS OF GENERATOR	3550X715X880	4656
2	FOUNDATION ITEMS OF GENERATOR	2240X940X1220	2880
3	CONSUMABLES FOR FOUNDATION	500X500X200	15
4	GENERATOR STATOR	7520X4200X4770	218000
5	GENERATOR ROTOR	10550X1560X1660	47742
6	END SHIELD (TE) LOWER HALF	3640X1140X2000	6020
7	END SHIELD (EE) LOWER HALF	3640X1140X2000	6020
8	H.V.BUSHING	2000X950X600	590
9	LOOSE ITEMS OF WOUND STATOR	1500X1200X1000	1010
10	GENERATOR ACCESSORIES	1800X1000X550	1546
11	GENERATOR ACCESSORIES(TERMINAL BUSHING BOX)	3500X1800X1250	4075
12	GAS BAFFLE RING, INSERT COVERETC.	3700X3500X1340	4364
13	BEARING SHELLS	1100X835X950	953

TECHNICAL CONDITIONS OF CONTRACT (TCC)

Annexure-I

WEIGHT DETAILS OF ONE UNIT

14	END SHIELD (EE) UPPER HALF	3640X1140X2000	5620
15	END SHIELD (TE) UPPER HALF	3640X1140X2000	5620
16	SEAL RINGS	600X600X200	73
17	DEVICE FOR ROTOR INSERTION INTO STATOR	2240X940X1220	1036
18	ERECTION DEVICES	2250X1180X1140	997
19	WIRE ROPES	1800X1450X200	201
20	DRY AIR BLOWER	1350X1250X800	190
21	TERMINAL CONNECTORS	1840X660X400	506
22	CONSUMABLES	500X600X300	45
23	SEAL OIL UNIT	6000X2500X3000	9160
24	SEAL OIL STORAGE TANK	3500X1300X1280	1460
25	GAS UNIT	2550X1790X2560	1150
26	HYDROGEN DISTRIBUTOR	3480X1540X440	333
27	CO2 DISTRIBUTOR	2770X1240X440	247
28	SEAL OIL UNIT-II	3610X2040X2350	3263
29	LIQUID DETECTOR RACK	1700X900X1800	450
30	LOOSE VALVES	2000X1000X1000	959
31	LOOSE INSTRUMENTS	500X500X300	80
32	CO2 VAPOURISER	1520X640X840	225
33	SLIP RING SHAFT ASSEMBLY	2540X1110X1200	2155
34	SLIP RING COVER & SEALING WALL	2540X2390X2750	3484
35	ACCESSORIES OF SLIP RING SHAFT	2600X2300X500	1435
36	BED PLATE, BEARING & BRUSH GEAR	2300X1550X1765	
37	GENERATOR PIPING	6500X1200X1000	6374
38	GENERATOR PIPING	6500X1000X800	1926
39	GENERATOR PIPING	1900X1500X800	1615
TOTAL			346475

TECHNICAL CONDITIONS OF CONTRACT (TCC)

Annexure-I

WEIGHT DETAILS OF ONE UNIT

3	CONDENSER & AUX.(HARDWAR SUPPLY)		
SN	DESCRIPTION	PACKAGE SIZE IN MM	Gr.WEIGHT(KG)
1	CONDENSER (HOTWELL)	11200X1900X1200	6913
2	BOTTOM PLATE	7150X3450X625	6793
3	BOTTOM PLATE	7150X3450X625	6793
4	BOTTOM PLATE	7150X3850X625	8296
5	BOTTOM PLATE	1900X700X300	271
6	CONDENSER SUPPORT	1750X1000X1250	3650
7	CONDENSER SUPPORT	1750X1000X1250	3650
8	CONDENSER SUPPORT	1750X1000X1250	3650
9	CONDENSER SUPPORT	1750X1000X1250	3650
10	LOOSE ITEM(COND. SUPPORT)	1600X950X950	4775
11	WATER CHAMBER (LHS)	5224X3610X360	6150
12	FRONT WATER BOX (GEN SIDE)	5950X3610X2485	15044
13	WATER CHAMBER(RHS)	5224X3610X360	6150
14	FRONT WATER BOX (TUR SIDE)	5950X3610X2485	15044
15	WATER CHAMBER (RHS)	5224X3610X360	6150
16	REAR WATER BOX (GEN SIDE)	4760X3610X2025	9122
17	WATER CHAMBER (LHS)	5224X3610X360	6150
18	REAR WATER BOX (TUR SIDE)	4760X3610X2025	9122
19	SIDE WALL(TUR.END)	5248X2480X80	7120
20	LOOSE ITEMS (SIDE WALL - TUR.END)	5850X350X250	782
21	SIDE WALL(GEN.END)	5248X2480X80	7120
22	LOOSE ITEMS (SIDE WALL - GEN.END)	5850X350X250	782
23	SHELL INTERNAL DETAILS	3650X850X625	4780
24	SHELL INTERNAL DETAILS	3650X850X625	4780
25	SHELL INTERNAL DETAILS	3650X850X625	4780
26	SHELL INTERNAL DETAILS	3650X850X625	4780
27	SHELL INTERNAL DETAILS	1000X750X350	600
28	SHELL INTERNAL DETAILS	3700X850X350	4600
29	AIR EXTRACTION PIPING	5460X990X410	1200

TECHNICAL CONDITIONS OF CONTRACT (TCC)

Annexure-I

WEIGHT DETAILS OF ONE UNIT

30	SHELL INTERNAL DETAILS	4700X3426X348	5400
31	SHELL INTERNAL DETAILS	4700X3426X348	5400
32	SHELL INTERNAL DETAILS	4700X3426X348	5400
33	SHELL INTERNAL DETAILS	4700X3426X348	5400
34	SHELL INTERNAL DETAILS	4700X3426X348	5400
35	SHELL INTERNAL DETAILS	4700X3426X348	5400
36	SHELL INTERNAL DETAILS	4700X3426X348	5400
37	LOOSE ITEMS (SHELL INTERNAL)	5500X940X630	7560
38	LOOSE ITEMS (SHELL INTERNAL)	4440X260X100	350
39	LOOSE ITEMS (SHELL INTERNAL)	3000X1500X500	4655
40	LOWER DOME WALL (TUR.END)	11000X3950X910	8767
41	LOWER DOME WALL (TUR.END)	4000X800X100	700
42	LOWER DOME WALL (TUR.END)	900X300X300	270
43	LOWER DOME WALL (GEN.SIDE)	11000X3950X910	7698
44	LOWER DOME WALL (GEN.END)	4000X800X100	700
45	LOWER DOME WALL (GEN.END)	900X300X300	270
46	LOWER DOME WALL (F.W/B SIDE)	7502X4046X545	6012
47	LOWER DOME WALL (F.W/B SIDE)	6238X934X1155	1444
48	LOWER DOME WALL (F.W/B SIDE)	1325X1150X500	550
49	LOWER DOME WALL (R.W/B SIDE)	7550X4000X1900	6727
50	LOWER DOME WALL (R.W/B SIDE)	6236X1134X1160	1427
51	LOWER DOME WALL (R.W/B SIDE) LOOSE ITEMS	1300X1065X305	215
52	LOWER DOME WALL (R.W/B SIDE)	6016X200X200	726
53	LOWER DOME WALL (R.W/B SIDE)	6016X200X200	726

BHEL-PSWR

TECHNICAL CONDITIONS OF CONTRACT (TCC)

Annexure-I

WEIGHT DETAILS OF ONE UNIT

54	DOME INTERNAL STIFFENING	6016X200X200	726
55	DOME INTERNAL STIFFENING	6016X200X200	726
56	DOME INTERNAL STIFFENING	3400X200X200	382
57	DOME INTERNAL STIFFENING	3400X200X200	382
58	DOME INTERNAL STIFFENING	1760X1480X1230	4300
59	DOME INTERNAL STIFFENING	2380X1310X1100	4295
60	UPPER DOME WALL,(TUR/GEN.SIDE)	6800X460X310	1083
61	UPPER DOME WALL,(TUR/GEN.SIDE)	6800X460X310	1083
62	UPPER DOME WALL,(F/W/BSIDE)	5880X1930X380	3635
63	UPPER DOME WALL (LOOSE ITEMS)	5400X350X32	475
64	UPPER DOME WALL (LOOSE ITEMS)	670X250X450	410
65	UPPER DOME WALL(RWB SIDE)	5880X1930X448	3270
66	W/BOX REMOVAL DEVICE	2500X1000X750	2600
67	W/B REMOVAL DEVICE (CONDENSER)	2000X1500X500	2135
68	FRAME	1850X840X230	650
69	FRAME	1840X840X230	650
70	STEAM THROW DEVICE	1450X900X700	1041
71	STEAM THROW DEVICE	1450X900X700	1041
72	CONDENSER (LOOSE ITEMS)	2100X650X700	600
73	CONDENSER (LOOSE ITEMS)	2900X956X406	380
74	CONDENSER LOOSE ITEMS	1000X500X500	275
75	FASTENERS (CONDENSER)	1000X800X800	1450
76	CONDENSER LOOSE ITEMS	600X320X200	6

TECHNICAL CONDITIONS OF CONTRACT (TCC)

Annexure-I

WEIGHT DETAILS OF ONE UNIT

77	CONDENSER LOOSE ITEMS	3300X250X200	200
78	TOOLS & TACKLES (CONDENSOR)	1000X500X500	600
79	STAND PIPE NO.1	2750X420X400	60
80	CONDENSER STAND PIPE	3150X350X330	300
81	STAND PIPE NO.2	2750X420X390	62
82	CONDENSER INSTRUMENTATION	1500X1100X1000	670
83	CONDENSER INSTRUMENTATION	1000X750X500	145
84	CONDENSER INSTRUMENTATION	1400X800X700	74
85	GLAND STEAM CONDENSER	1015X1180X1400	825
86	STAND PIPE/LOOSE ITEMS (GSC)	2100X500X400	200
87	LOOSE ITEMS OF GSC (FRAGILE)	600X800X400	100
88	LOOSE ITEMS GSC(NON FRAGILE)	1500X650X450	320
TOTAL(kg)			284445

4	ACG (HARDWAR SUPPLY)			
SL	PKG.NO	DESCRIPTION	PKG.SIZE(MM)	GR.WT IN KG.
1	10001/0	STARTER CABINET FOR DC S. OIL MOTOR	1230 X 1060 X 2550	675
2	10002/0	GENERATOR INSTRUMENTATION CABINET	1230 X 1060 X 2550	675
3	10003/0	LOOSE INST.	800 X800 X400	54
5	10005/0	STARTER CABINET FOR DC JOP MOTOR	1230 X 1060 X 2550	675
6	10006/0	STARTER CABINET FOR DC EOP MOTOR	1230 X 1060 X 2550	675
TOTAL (Kg)				2754

5	LP HEATERS & COOLERS(HYDERABAD SUPPLY)		
SN	DESCRIPTION	PACKAGE SIZE IN MM	Gr.WEIGHT(KG)
1	DRAIN COOLER	4650X1000X1250	3500

TECHNICAL CONDITIONS OF CONTRACT (TCC)

Annexure-I

WEIGHT DETAILS OF ONE UNIT

2	LOOSE ITEMS(DRAIN COOLER)	800X500X300	101
3	DRAIN COOLER	500X300X300	24
4	DRAIN COOLER	400X400X60	6
5	LP HEATER NO. 1	11520X1400X1550	11880
7	LP HEATER NO.1 STAND PIPE	2700X500X400	150
8	LP HEATER NO.1 STAND PIPE	2200X700X500	50
9	LOOSE ITEMS LP HEATER NO. 1	700X500X500	150
11	LP HEATER NO. 2	9600X1350X1735	9950
12	LP HEATER NO. 2, INSTRUMENTS	700X500X400	130
13	LP HEATER NO. 2, LOOSE ITEMS	2700X500X400	140
14	LP HEATER NO.2, STAND PIPES	2200X700X500	100
15	LOOSE ITEMS, LP HEATER NO.2	2600X500X350	200
16	LP HEATER NO. 3	9600X1270X1835	9875
17	L.P. HEATER-3 & STAND PIPES(LOOSE ITEMS)	2700X500X400	140
18	LP HEATER NO. 3, INSTRUMENTS	1600X500X400	250
19	LP HEATER NO. 3, STAND PIPES	2200X700X500	100
20	LP HEATER NO. 3,INSTRUMENTS	500X300X300	125
21	TUBRINE OIL COOLER	5050X1650X1980	8200
22	TUBRINE OIL COOLER	5050X1650X1980	8200
23	TOC (LOOSE ITEMS)	750X500X200	80
24	TOC (LOOSE ITEMS)	800X600X600	60
25	EXCITER AIR COOLER	2850X650X600	892
26	EXCITER AIR COOLER	2850X650X600	892
TOTAL			55195

TECHNICAL CONDITIONS OF CONTRACT (TCC)

Annexure-I

WEIGHT DETAILS OF ONE UNIT

6	BFP (HYDERABAD SUPPLY)				
SN	DESCRIPTION	PACKAGE SIZE IN MM	UNIT Wt.	QTY. (NOS.) for each unit	Gr.WEIGHT(KG)
1	BFP SKID (PUMP ASSLY. + BASE PLATE + TUBING + SEAL COOLERS)	2250 X 1000 X1050	5,770	3	17310
2	BP SKID (PUMP ASSLY. + BASE PLATE+ TUBING)	1650 X 1200 X 950	2,511	3	7533
3	GRILLAGE	10200 X 2500 X 900	5,030	3	15090
4	HYDRAULIC COUPLING (DD)	1800 X 1700 X 1800	3,560	3	10680
5	HYD. COUPLING W. O. COOLER (DD)	3700 X 1500 X 500	1,475	3	4425
6	HYD. COUPLING L. O. COOLER (DD)	3100 X 1300 X 450	775	3	2325
7	HYD. COUPLING LOOSE ITEMS	-----	710	3	2130
8	SUCTION STRAINER AT BP SUCTION DD)	900 X 800 X 1400	600	3	1800
9	BFP RECIRCULATION VALVE (DD)	1800 X 550 X 1400	250	3	750
10	LOCAL GAUGE BOARDS WITH INSTRUMENTS (DD)	2200 X 300 X 1800	500	3	1500
*11	LOOSE ITEMS	-----	2,200	3	6600
TOTAL (KG)					70143

TECHNICAL CONDITIONS OF CONTRACT (TCC)

Annexure-I

WEIGHT DETAILS OF ONE UNIT

7 CEP (HYDERABAD SUPPLY)					
S.N.	DESCRIPTION OF EQUIPMENT	DIMENSIONS(MM)	UNIT WT.(KG)	TOTAL NOS FOR EACH UNIT	Gr.WEIGHT(KG)
1	CEP ASSEMBLY	Φ 1100 X 3250	1,700	3	5100
2	CANISTER	Φ 900 X 3100	260	3	780
3	CEP FOUNDATION RING	1100 X 1100 X 150	185	3	555
4	CEP SUCTION STRAINER	900 X 800 X 1400	600	3	1800
5	LOCAL GAUGE BOARD WITH INSTRUMENTS (DD)	2000 X 300 X 1800	400 (PER UNIT)	1	400
6	LOOSE ITEMS	-----	210	3	630
TOTAL					9265

8 HP HEATER(HYDERABAD SUPPLY)				
S.NO	DESCRIPTION	DIMENSIONS	QTY	Gr.WEIGHT (MT)
1	HP Heater No. 5	2400 (H) X 2200 (W) X 10700 (L)	1Nos.	17.25
2	HP Heater No. 6	2400 (H) X 2200 (W) X 12100 (L)	1Nos.	20.75
TOTAL (MT)				38

9 FLASH TANKS (BHOPAL SUPPLY)					
S.No	DESCRIPTION	QTY/SETS	SIZE (MM)	Unit Wt(Kg.)	Gr.Wt.(Kg)
1	HP Flash Tank	1	4100 (L) X 3000(W) X 2900(H)	4600	4600
2	LP Flash Tank	1	2900(L) X 2200(W) X 2100(H)	3400	3400
3	Unit F/T	1	2500(L) X 1500(W) X	1000	1000

TECHNICAL CONDITIONS OF CONTRACT (TCC)

Annexure-I

WEIGHT DETAILS OF ONE UNIT

	1400(H)	
TOTAL (Kg)		9000

10 MISC. TANKS(BHOPAL SUPPLY)						
S.No	DESCRIPTION	QTY/SETS	SIZE (MM)	Unit Wt(Kg.)	Gr.Wt.(Kg)	REMARK
1	Clean Oil Tanks	1	5400 (L) X 4900(W) X 3400(H)	10200	10200	for both units
2	Dirty Oil Tank	1	5400 (L) X 4900(W) X 3400(H)	10200	10200	for both units
3	Oil Unloading Tank	1	2250 (L) X1200 (W) X 900 (H)	550	550	for both units
4	O/H CST	2	13550 (L) X 3800 (W) X 4200(H)	21000	42000	for both units
5	SW Tank	1	6100(L) X 2500(W) X 2900(H)	7500	7500	for both units
	PW Tank	1	4100(L) X 2000 (W) X 2600(H)	3600	3600	for both units
TOTAL (Kg) FOR BOTH UNIT					74050	
TOTAL (Kg) FOR EACH UNIT					37025	

11 RE JOINTS(BHOPAL SUPPLY)						
S.No	DESCRIPTION	QTY/SETS	SIZE (MM)			Gr.Wt.(MT)
1	RE Joint INLET	1	2800 (H) X 3200 (W) X 5315 (L)			9.05
2	RE Joint OUTLET	1	2800 (H) X 2950 (W) X 3705 (L)			8.30
TOTAL (MT)						

TECHNICAL CONDITIONS OF CONTRACT (TCC)

Annexure-I

WEIGHT DETAILS OF ONE UNIT

12 H.T. MOTORS(BHOPAL SUPPLY)					
S.No	DESCRIPTION	QTY/SETS	SIZE (MM)	Unit Wt(Kg.)	Gr.Wt.(Kg)
1	BFP	3	4000 X 3000 X 3000	15000	45000
2	CEP	3	2000 X 1600 X 2500	6000	18000
TOTAL (Kg)					63000

13 BUTTER FLY VALVE (BHOPAL SUPPLY)					
S.No	DESCRIPTION	QTY/SETS	SIZE (MM)	Unit Wt(Kg.)	Gr.Wt.(Kg)
1	Dia 1800 (RL)	7	2800 (L) X 2000 (W) X 750 (H)	5760	40320
2	Dia 1200 (RL)	1	2100 (L) X 1600(W) X 400(H)	2670	2670
3	Dia 700 (RL)	2	1600(L) X 1100(W) X 400(H)	790	1580
4	Dia 600 (RL)	1	1500(L) X 900(W) X 600(H)	600	600
5	Dia 600 (RL)	1	1500(L) X 1100(W) X 400(H)	575	575
6	Dia 500 (RL)	4	1300(L) X 800(W) X 350(H)	380	1520
7	Dia 450 (RL)	1	1300(L) X 800(W) X 350(H)	265	265
8	Dia 450 (RL)	3	1300(L) X 800(W) X 350(H)	275	825
9	Dia 400 (RL)	4	1100(L) X 600(W) X 300(H)	270	1080
10	Dia 400	3	1100(L) X 600(W) X 300(H)	390	1170
TOTAL (Kg)					50605

14 BOUGHT OUT ITEM (PEM SUPPLY)					
SL.NO.	ITEM DESCRIPTION	Qty	Approx. Dimensions (LXBXH)	TOTAL WT. KG.	Remark

BHEL-PSWR

Tender Specification No: **BHE/PW/PUR/SKT-BAL STG U#3/1236**

Technical Conditions of Contract –Volume I A (Part I : Contract Specific Details)

Page 72

TECHNICAL CONDITIONS OF CONTRACT (TCC)

Annexure-I

WEIGHT DETAILS OF ONE UNIT

1	CONTROL VALVES				21 nos. per unit
2	FLOW ELEMENTS				11 nos. per unit
3	CHAIN PULLEY BLOCK / HOIST:				
a)	ELECTRIC HOIST				Total 10 Hoist each 2000Kg/Hoist
b)	CHAIN PULLEY BLOCK				
4	CHEMICAL DOZING SYSTEM				
a)	Hydrazine Dosing system	2	6m X 2m X 3.5m	4500	for one (1) number skid only
b)	Ammonia Dosing system	2	6.3m x 2m x 3.5m	5500	for one (1) number skid only
c)	NaoH Dosing system	2	2.0m x 1.5m x 1.5m	1500	for one (1) number skid only
d)	Phosphate Dosing system	2	6.5m x 2m x 3.5m	5500	for one (1) number skid only
e)	Bulk Ammonia Dosing system	1	5m x 3m x 2m	3000	for one (1) number skid only
5	LUBE OIL TRANSFER PUMPS			750	
6	AIR TRAPS				Qty very small
9	ME BELLOWS			4500	
10	STEAM TRAPS				Qty very small
11	VALVES:				
a)	AIR RELEASE VALVE			637	
b)	BALL VALVES				Qty very small
c)	GM Valve			432.35	
d)	Power Cycle Valves			2315	
e)	CS/Gate/Globe/NRV			36.2	
f)	Cast Iron Valve			4662.5	

TECHNICAL CONDITIONS OF CONTRACT (TCC)

Annexure-I

WEIGHT DETAILS OF ONE UNIT

g)	BUTTER FLY VALVES(WATER SERVICE)			6977	
12	AUX PRDS			1500	
13	COLTCS	4	3m x2.5 m 2.5m	14000	
15	DESUPERHEATER FOR WET STEAM WASHING			45	
	Plate Heat Exchangers	5	3 m x 2.5m 1.5m	27500	
	Sump pumps	3	1 m x1m	1500	
16	MISC. PUMPS	11	2.5m x 1.5m	17500	
18	SELF CLEANING STRAINER	2	3m x 0.6m	10000	
TOTAL(KG)				112355	

15	BOUGHT OUT ITEM (HARDWAR SUPPLY)	
S.N	ITEM ID	Description
1	BG001	EMPTY H2 CYLINDER
2	BG002	EMPTY CO2 CYLINDER
3	BG004	PORTABLE GAS ANALYSER
4	BG005	MOISTURE MEASURING SYSTEM
5	BG007	VAPOUR EXHAUSTER
6	BG008	MOTORISED TEMPERATURE CONTROL VALVE WITH ACTUATOR NB250 VAR-02
7	BG009	H2 GAS ANALYSER CABINET
8	BG011	REFRIGERATION GAS DRYER
9	BG018	STARTING RESISTOR FOR DC S.O MOTOR
10	BG020	SOUND ABSORBING COVER
11	BH009	WELDED TITANIUM TUBES GR.2 (FOR CONDENSOR)
12	BH010	CONDENSOR AIR EVACUATION PACKAGE (VACUUM PUMP)
13	BH012	AIR EXHAUSTER WITH MOTOR (GSC AIR EXHAUSTER)
14	BT002	JACKING OIL PUMPS
15	BT003	AOP & EOP
16	BT004	DUPLEX FILTER (LUB.OIL)
17	BT005	DUPLEX FILTER (JACKING OIL)
18	BT006	BUTTERFLY VALVES

TECHNICAL CONDITIONS OF CONTRACT (TCC)
Annexure-I
WEIGHT DETAILS OF ONE UNIT

19	BT007	THREE WAY TEMP. CONTROL VALVE
20	BT008	DOUBLE THREE WAY VALVES
21	BT009	NRV WITH ALUMINIUM FLAP
22	BT010	PRESSURE LIMIT VALVE
23	BT011	OIL PURIFICATION UNIT (OIL CENTRIFUGE)
24	BT012	OIL VAPOUR EXHAUSTER
25	BT013	LEAD DIAPHRAGM
26	BT014	SPRAY NOZZLES
27	BT015	DIRT CATCHERS
28	BT016	DAMPER
29	BT017	VARIABLE LOAD SPRING CAGES
30	BT023	TURBINE OIL
31	BT025	OIL PURIFICATION SYSTEM (CENTRAL)
32	BT026	GROUP CABLES
33	BT029	FLOW NOZZLES FOR PG TEST
34	BT043	CONTROL FLUID (FRF)
35	BT046	LP BYPASS STOP & CONTROL VALVE WITH EHA AND WATER INJECTION VALVE
36	BT065	GEAR PUMP (LUB. OIL RECIRCULATION)
37	BT074	VACUUM BREAKER VALVE WITH PNEUMATIC ACTUATOR
38	BT075	SEAL STEAM SUPPLY & LEAKAGE STEAM CONTROL VALVE WITH PNEUMATIC ACTUATOR
39	BT080	EHA FOR TURBINE VALVES ALONGWITH HPSU
Approx. Weight (MT)		271 MT

16.TG-INTEGRAL PIPING

1. FOR TURBINE (C.S. & A.S.) - 31.0 MT
2. FOR TURBINE FIRE RETARDANT FLUID (S.S.) - 15.0 MT
3. FOR GENERATOR (CS & A.S.) FOR SEAL OIL, GAS SYSTEM ETC. – 13.0 MT

17	EXTERNAL/RE-GENERATIVE & OTHER PIPING SYSTEM (PC CHENNAI SUPPLY)		
PG	MA	Brief Description	Design Wt (MT)
80	311	HRH FROM INTERCEPTOR VALVE TO TURBINE	12.00
80	330	EXTRACTION STEAM TO LP HEATER-1	6.80

BHEL-PSWR

TECHNICAL CONDITIONS OF CONTRACT (TCC)
Annexure-I
WEIGHT DETAILS OF ONE UNIT

80	331	EXTRACTION STEAM TO LP HEATER-2	3.40
80	332	EXTRACTION STEAM TO LP HEATER-3	4.60
80	375	UNLISTED SV EXHAUSTS - TG SCOPE	4.60
80	381	HP HEATER VENTS - TG SCOPE	0.90
80	382	LP HEATER VENTS	1.50
80	385	VENT FROM UNLISTED PPG/EQPT TO COND	2.30
80	387	CONDENSATE PUMP VENT	1.10
80	388	CONDENSER AIR EVACUATION PIPING	3.30
80	398	TURBINE WASHING STEAM	3.70
80	400	CONDENSATE SUCTION	3.20
80	401	CD FROM PUMP TO LPH1/DC INLET TEE AND RE	10.00
80	402	CD FROM LPH1/DC INLET TEE TO TG TP	6.30
80	407	CONDENSATE FOR SEALING OF VACUUM	1.30
80	408	CONDENSATE DUMP FROM HEADER	2.20
80	411	CONDENSATE/MAKE-UP TO CONDENSER	2.00
80	413	UNLISTED CONDENSATE	1.10
80	440	CONDENSER DRAINS	0.20
80	442	GLAND STEAM COOLER DRAINS	0.30
80	444	LP HEATER-2/3/4/5 DRAINS AND DRIP PUMP I	3.00
80	447	HP HEATER DRAINS	9.20
80	449	TG CYCLE PIPING DRAINS AND VENTS	7.30
80	673	LUBE OIL PIPING SYSTEM	4.30
80	901	Sd Valves&Specialities-Boiler Lightup	1.00
		Total	95.60

18	INSULATION (PEM SUPPLY)	
SL.NO.	ITEM DESCRIPTION	TOTAL WT. MT
1	Thermal insulation	260
	TOTAL (MT)	260

NOTE:

1. The list is tentative and has been given to enable the contractor to study the nature of work to be done in this contract. There may be variation in size, weight etc. and no claim, whatsoever, will be entertained on account of this by BHEL.
2. Some of the packages may be sent in parts to suit the site condition / transportation, the same is to be assembled at site without any extra cost, likewise the package may be assembled together

TECHNICAL CONDITIONS OF CONTRACT (TCC)

Annexure-I

WEIGHT DETAILS OF ONE UNIT

and send as a single assembly. Contractor may have to dismantle and erect or erect as single assembly as per the instruction of BHEL engineers without any extra cost.

SUMMARY WEIGHT DETAILS FOR EACH UNIT		
S.No.	EQUIPMENT / PACKAGE	APPROX. WT(MT)
1	STEAM TURBINE & AUX	584.5
2	TURBO GENERATOR & AUX	346.475
3	CONDENSOR & AUX	284.445
4	ACG	2.754
5	LP HEATERS AND COOLERS	55.195
6	BFP	70.143
7	CEP	9.265
8	HP HEATERS	38
9	FLASH TANKS	9
10	MISC TANKS	37
11	RE JOINTS	17.35
12	HT MOTORS	63
13	BUTTERFLY VALVES	50.44
14	BOUGHT OUT ITEMS (BHEL PEM SCOPE)	112.3
15	BOUGHT OUT ITEMS FROM HARDWAR	271
16	TG INTEGRAL PIPING (HARDWAR)	59
17	EXTERNAL/RE-GENERATIVE & OTHER PIPING SYSTEM	95.6
18	INSULATION	260
	TOTAL	2365.467
	TOTAL (MT) APPROX.	2365

Above weight details are given to give broad idea about the entire system. However scope of work under subject tender is limited to the balance left over job. Scope of balance works is as indicated in Chapter VII 'Terms of Payment' in this specification

TECHNICAL CONDITIONS OF CONTRACT (TCC)
Annexure-I
WEIGHT DETAILS OF ONE UNIT

DETAILED PURCHASE ORDERS FOR BOUGHT OUT ITEMS, PLOT PLAN, RELEVANT DRAWINGS AND FOUNDATIONS ETC. SHALL BE FURNISHED DURING EXECUTION OF WORK IN CONSULTATION WITH CUSTOMER. NO EXTRA CLAIMS IN THIS REGARD SHALL BE ENTERTAINED FROM BIDDERS.

TECHNICAL CONDITIONS OF CONTRACT (TCC)

Chapter-XI General

11 GENERAL

11.0.1

The work covered under this specification is of highly sophisticated nature, requiring the best quality of workmanship for fabrication, engineering and construction management. The Bidder should ensure timely completion of work. The Bidder must have adequate quantity of tools, construction aids, equipments etc, in his possession. He must also have on his rolls adequate, trained, qualified and experienced supervisory staff and skilled personnel.

11.0.2

The work shall be executed under the usual conditions affecting major power plant construction and in conjunction with numerous other operations at site. The Bidder and his personnel shall co-operate with the personnel of other agencies, co-ordinate his work with others and proceed in a manner that shall not delay or hinder the progress of work as a whole.

11.0.3

All the work shall be carried out as per the instructions of BHEL engineer. BHEL engineer's decision regarding the correctness of the work and method of working shall be final and binding on the Bidder.

11.0.4

The Bidder shall at his cost perform any services, tests etc, although not specified but nevertheless required for the completion of work.

11.0.5

Contractor shall erect all the equipments as per sequence prescribed by BHEL at site. The sequence of erection, methodology will be decided by the BHEL engineers depending upon the availability of material, work fronts etc. No claims for extra payment from the Contractor will be entertained on the grounds of deviation from the methods and sequence of erection adopted in erection of similar TG sets or for any reasons whatsoever.

11.0.6

All the necessary certificates and licenses required to carryout this work are to be arranged by the Contractor expeditiously at his cost.

11.0.7

The work to be carried out under the scope of these specifications covers the complete work of collection from stores/storage yard, handling, transporting, unloading at erection site, pre-assembly, erection, alignment, hot alignment, bolting, fastening, welding, radiography, leveling, cold pulling, adjusting, Non-destructive testing, Post weld heat treatment, hydraulic test, chemical cleaning, passivation, steam blowing, oil flushing, water flushing, air flushing, pre-commissioning tests, trial running of auxiliaries covered under these specifications, commissioning and all other activities till handing over of the unit. The work shall conform to dimensions and tolerances specified in the various drawings, documents etc. That will be provided during the course of installation. If any portion of the work is found to be defective in workmanship or not conforming to drawings or other specifications, the Contractor shall

TECHNICAL CONDITIONS OF CONTRACT (TCC)

Chapter-XI General

dismantle and re-do the work duly replacing the defective materials at his cost failing which the work will be got done by BHEL at the cost and risk of the contractor. Contractor may please note that the loading of materials at storage yard/Stores in contractor's Trailer / Carriers while collecting materials will be done by material handling agency deployed by BHEL.

11.0.8

The terminal points as decided by BHEL shall be final and binding on the Contractor.

11.0.9

The indicative schedule of weight of major equipments given in relevant appendices is meant for providing a general idea to the Contractor about the magnitude of the work involved.

11.0.10

During the course of execution of this work, certain rework/ modification/ rectification/ repairs/ fabrication etc will be necessary on account of feed back from various thermal power stations on units already commissioned and/or units under erection and commissioning and also on account of design discrepancies and manufacturing defects and site operation/maintenance requirements. Contractor shall carryout such rework/ modification/ rectification/ fabrication/ repairs etc promptly and expeditiously. Daily log sheets indicating the details of work carried out, man hours; consumables used etc, shall be maintained by the Contractor and got signed by BHEL engineer every day. Claims of contractor, if any, for such works will be dealt as per relevant clauses of General Conditions of Contract.

11.0.11

All tools and tackles, fixtures, equipments, materials, manpower, supervisors/ engineers, consumables etc required for this scope of work shall be provided by the Contractor. All expenditure including taxes and incidentals in this connection will have to be borne by him unless otherwise specified in the relevant clause.

11.0.12

The contractor shall make adequate security arrangements including employment of security personnel and ensure protection from theft, fire, pilferage, damage and loss of materials/equipments issued to him for the work. Special care will have to be taken to guard against pilferage / theft of copper tubing, brass fittings, brass valves and other costly materials.

11.0.13

All equipments shall be handled very carefully to prevent any damage or loss. No bare wire ropes, slings etc, shall be used for handling of the equipments without the specific permission of the engineer.

11.0.14

Contractor shall ensure proper housekeeping and remove all scrap materials periodically from various work area covered in the scope and deposit the same at the place earmarked for this purpose. In case of contractor's failure to do the same, BHEL reserves the right to remove scrap at contractor's cost and risk.

TECHNICAL CONDITIONS OF CONTRACT (TCC)

Chapter-XI General

11.0.15

Access to site for inspection by BHEL and customer engineers shall be made available by the contractor at all times.

11.0.16

Contractor shall mobilize sufficient quantity of sleepers for stacking of materials in his custody.

11.0.17

Performance testing of equipment will also form part of the work to be carried out by the contractor.

11.0.18

The Contractor's scope of work is further described in the following clauses:

11.1 COLLECTION AND RETURN OF EQUIPMENTS, MATERIALS & CONSUMABLES

11.1.1

Contractor shall take delivery of the components, equipments, lubricants, chemicals, special consumables, steel etc from the storage yard/stores/sheds of BHEL/ client. The Contractor should note that the transport of equipments to erection site, assembly yards etc should be done by the prescribed route, without disturbing the other works and contractors and in the most professional manner. Special equipments such as laboratory equipments, measuring and controls equipments, special electrodes, valves, shims, packing materials for joints and seals, lubricants, actuators etc, shall be stored, when taken over by the Contractor, in appropriate manner as per BHEL's instructions.

11.1.2

The contractor shall return all parts, materials, consumables etc. remaining extra over the normal requirement with proper identification tags to BHEL stores. In case of any misuse or use over actual requirement, BHEL reserves the right to recover the cost of parts/materials used in excess or misused, with departmental charges.

11.1.3

Transportation of lube oil, Chemicals, Gas cylinders etc from stores, is included in the scope of this contract. The contractor shall have to return all the empty and excess drums to the customer/BHEL stores. Similarly, transport of chemicals for various pre-commissioning activities/processes mentioned in clauses herein from BHEL/customer's stores and charging of chemicals into the system for carrying out various pre-commissioning activities and processes mentioned herein and returning of remaining and/or the empty containers of the chemicals to customer/BHEL stores is the responsibility of contractor. After completion of oil flushing operation, the used oil shall be filled in empty drums and which in turn shall be returned to BHEL/customer's stores.

11.2 TEST TAPPING POINTS

TECHNICAL CONDITIONS OF CONTRACT (TCC)

Chapter-XI General

Installation and welding of Tapping Points for taking performance test measurements shall be carried out by the contractor as part of this work for the equipments covered under this tender specification under the guidance of BHEL engineer. The scope will be limited to all the tapping points for which materials are available and their locations identified within the regular contract period and extensions thereof.

11.2.1

All packing and forwarding material shall be returned as soon as the material is unpacked. The location for storage of such materials shall be as indicated by BHEL Engineer.

11.2.2

All Measuring and Monitoring Devices (MMD) used for the work in scope of these tender specifications shall be calibrated by the accredited agencies that are approved by BHEL or calibration tractability is established upto National Physical Laboratory.

11.2.3

Contractor shall furnish the consumption details of chemicals, lubricants, TIG welding filler wire, welding electrodes and other consumables on monthly basis.

11.3 GENERAL

11.3.1

During the course of erection, platforms and floor grills are to be cut at certain places to route steam, oil, water and air piping, cable trays, etc or for accommodating erection, rigging etc, the cutting of platforms and grills should be minimum and as approved by BHEL Engineer. After completion of work, the platform/grills cut shall be made good neatly as instructed by BHEL engineer.

11.3.2

Erection and welding of stainless steel fittings including supply of necessary stainless steel welding electrodes is within the scope of the work/specification.

11.3.3

No temporary supports should be welded on to the piping.

11.3.4

Contractor shall carry out preservation painting on all items taken from stores. The preservation painting has to be carried out on material taken from stores and also on material erected wherever the shop painting has given away. Periodical inspection shall be made as per the instructions of BHEL engineer and the portion of items or the complete items needing painting shall be carried out to the satisfaction of BHEL engineer. This facility shall be provided by the contractor till the commissioning and handing over of the equipment to the customer. Preservative and touch up painting on equipments covered under this specification stored at stores/storage yard shall also be carried out by the contractor.

TECHNICAL CONDITIONS OF CONTRACT (TCC)

Chapter-XI General

11.3.5

Adjustment of spring hangers for piping shall be done by the contractor during initial erection. After initial commissioning trials, it is possible that the spring hangers have to be adjusted repeatedly till the correct spring compression is achieved. Contractor shall do the same to the satisfaction of BHEL engineer. The marking of cold and hot positions on the hangers shall be done by the contractor.

11.3.6

The contractor shall return to BHEL the excess materials left over after completion of work, materials issued for temporary pipelines for HT, chemical cleaning, flushing, blowing etc. and materials issued on returnable basis in neatly dressed condition. Necessary grinding, edge cutting (square facing), edge preparation (vee), painting etc. to the condition similar to the one at the time of issue shall be in scope of work.

11.3.7

Wherever the equipments are erected by the contractor and connected piping is done by other agency, contractor shall weld / tighten the incoming pipes to either the equipment or the counter flange provided on the equipment.

11.3.8 APPROACH AND OPERATING PLATFORMS

ERECTION OF PERMANENT APPROACH PLATFORM AND LADDERS ETC FOR GSC, FLASH TANKS, LUBE OIL / CONTROL OIL TANKS, HP/LP BY PASS VALVES, ESVS / IVS, hot / ELECTRIC MONORAIL HOISTS, LOCAL PLATFORMS FOR VARIOUS INACCESSIBLE VALVES AND EQUIPMENT ETC. ARE IN THE SCOPE OF WORK. THE STRUCTURAL STEEL AND OTHER MEMBERS WILL BE SUPPLIED IN RANDOM LENGTH/SIZE & WILL HAVE TO BE CUT TO REQUIRED SIZE AND PROFILE AS INCIDENTAL TO WORK.

TECHNICAL CONDITIONS OF CONTRACT (TCC)

Chapter-XII CIVIL WORKS, FOUNDATION, GROUTING

12 PREPARATION OF FOUNDATION

12.1

Buildings, foundations and other necessary civil works for supporting structures, equipments etc, will be provided by the BHEL/customer. The checking of dimensional accuracy, axes, elevation, levels etc, with reference to bench marks of foundations and anchor bolt pits and also adjustments of foundation level, dressing and chipping of foundation surfaces of all equipments contractor/BHEL shall prepare protocols before taking over the foundations. Dressing and chipping of foundations upto 25mm for achieving proper levels will be within the scope of work/specification.

12.2

All minor foundations and anchor points required for installing erection equipments like winches, anchors etc. are to be cast by the contractor.

12.3

The complete work of secondary grouting of equipments is included in the scope of work/specification. Contractor shall arrange all manpower, T&P, form work and shuttering materials, all grouting materials such as ordinary portland cement, sand, stone chips etc & quick-setting-non-shrink-free-flow special grout mix of required specification (like conbextra-gp-2 or equivalent).

12.3.1

The quick-setting-non-shrink-free-flow special grout mix shall be purchased only from the following BHEL approved vendors:

1. M/S FOSROC CHEMICALS (INDIA) PVT LTD;
2. M/S SIKA INDIA PVT LTD;
3. M/S PAGEL CONCRETE TECHNOLOGIES PVT LTD;
4. M/S PIDILITE INDUSTRIES LTD.

In order to ensure the quality, the major grouting of equipments using any of above grout mixes shall essential be done as per the recommendations of supplier with regard to grout preparation and use of machinery etc under the supervision of the respective supplier. BHEL has arrangement with above suppliers for supervision services and the supervision charges for the same will be borne by BHEL. However, the contractor shall ensure readiness of equipment for grouting in all respect before such a service is requisitioned and the duration is not prolonged unduly. Any overstay required due to contractor shall be charged to the contractor with BHEL's departmental charges. Contract shall consult BHEL engineer before deciding upon the vendor for the above.

12.3.2

Cleaning of the foundation surfaces, pocket holes, anchor bolt pits and de-watering and making them free of oil, grease, sand and other foreign materials by soda washing, water washing, compressed air and other approved methods will be within the scope of this work.

TECHNICAL CONDITIONS OF CONTRACT (TCC)

Chapter-XII CIVIL WORKS, FOUNDATION, GROUTING

12.4

BHEL will provide only shims and packer plates (either machined or plain), which are received from BHEL's manufacturing plants and go as permanent part of the equipment. Additional packer plates and shims if required will have to be prepared by the contractor out of steel plates, steel sheets to meet site requirements. Necessary steel plates for this purpose will be provided by BHEL free of cost.

12.5

The contractor shall carry out scrapping and matching of embedded plates, permanent spacers and all the matching parts of turbine, generator, pumps and other equipments under scope wherever required. The support and sole plates matching and concrete surface bedding is also covered in the scope of work. The fine dressing of concrete shall be with Prussian blue-match checks.

12.6

Packer plates shall not only be blue matched with foundations but also inter-packer contact surfaces, contact surfaces between packer and pedestals, contact surface between packer and foundation frame etc. shall also be blue matched and required percentage contact shall be achieved by chipping and scrapping as per engineer's instructions.

TECHNICAL CONDITIONS OF CONTRACT (TCC)

Chapter-XIII EQUIPMENT INSTALLATION

13 EQUIPMENTS INSTALLATION – COMMON REQUIREMENTS

13.1

Filling of lubricants for steam turbine, turbo-generator and other rotating auxiliaries for purpose of oil flushing, initial fill up and subsequent topping up during various stages of work is in the scope of the contractor.

13.2

All works such as cleaning, leveling, aligning, hot alignment, trial assembly, dismantling of certain equipments/components for checking and cleaning, surface preparation, fabrication of sheets, tubes and pipes as per general engineering practice and as per BHEL engineer's instructions at site, cutting, grinding, straightening, chamfering, filling, machining, chipping, drilling, reaming, scraping, lapping, shaping, fitting-up, drilling of holes, making dowel pins, minor rectification of foundation bolts etc. are incidental to the erection/commissioning and any other work/activity which is necessary to complete the work satisfactorily, shall be carried out by the contractor as part of the work.

13.3

Cleaning, servicing, lubrication of actuators, pumps, headers, governing system, ESV & IV, control valves, LP bypass, Cold Re-heat Non Return Valves with power cylinders and other valves, tanks, vessels etc. during erection and commissioning stages is in the scope of work. However, gaskets/pickings/lubricants for replacement will be provided by BHEL free of cost.

13.4

All equipment shall be preserved and protected periodically before and after erection as per advice of BHEL engineer. The journals of steam turbine rotors, generator rotor, HT motors and other rotating machines shall be thoroughly cleaned, greased/painted with preservative agents periodically as instructed by BHEL engineer.

13.5

Trial run of all motors including checking direction of rotation in uncoupled condition, check alignment and re-couple the motor to driven equipment.

13.6

After initial trial of rotating equipments, control and power cabling for motors and other equipments/instrumentation may have to be disconnected for checking alignment and resetting/realignment/hot alignment. Contractor will have to provide services for disconnection and reconnection of control and power cables.

13.7

All racks or assembled units like Governing Rack, LP Bypass Rack system, Cold Re-heat Non Return Valve, Seal Oil Unit, Gas Unit, Seal Oil Valve Rack, Gas Cylinder Racks etc supplied from manufacturing units will be tested in BHEL/ Customer stores or at site. This may require transportation, filling of oil, water etc in these racks for carrying out testing of these racks. Defects noticed during testing of these racks will have to be rectified by the contractor free of charges. Further, any pipeline / flanges / fittings not found assembled properly, the same have to be rectified / corrected by the contractor free of charges.

TECHNICAL CONDITIONS OF CONTRACT (TCC)

Chapter-XIV PIPING INSTALLATION

14 PIPING INSTALLATION

14.1

The scope of work in piping system (air, Gas, Water, Oil, Steam, Governing oil/Control oil etc.) will include cutting to required length, edge preparation, laying, fixing and welding of the elbows/fittings/valves etc, fixing supports/hangers/shock absorbers/ guides and restraints etc and carrying out all other activities/works to complete the erection and also carrying out all pre-commissioning/ commissioning operations mentioned in these specifications as per engineer's instructions and/or as per approved drawings. Weld joints and NDT requirement for all TG Integral piping, and other piping's as applicable under tender specification shall be as per drawings/schemes and suiting to site requirement. The necessary drawings/documents for these weld joints will be provided at site during execution of work.

14.2

Carrying out of piping as per the specifications between equipments constituting terminal points, whether the terminal equipments fall within the scope of the work/specification or not, is within the scope of the work/ specification. The contractor shall complete terminal joints at either ends, with due NDE & PWHT if applicable, for all the piping schemes covered in the scope of work.

14.3

Fit up and welding/bolting/fastening of piping to the terminal points (such as stubs, valves, flanges on terminal points/equipments, stubs on headers, battery limits etc) forming part of the scope of work/specification and stress relieving and radiography of joints so made are also within the scope of work. Permanent fasteners and gaskets will be supplied by BHEL.

14.4

Interconnection/ Hook-up, if any, with the existing system shall form part of work. Such interconnections, hook-ups may require shut down of running plant and the relevant work has to be completed within such planned shutdowns. This may call for working with enhanced resources and on extended hours. Contractor's offer shall cover all such contingencies.

14.5

All drains / vents / relief / escapes / safety valve piping to various tanks/ sewage / drain canal / flash box / condenser / sump / atmosphere etc. from the stubs on the piping and equipments erected by contractor is completely covered in the scope of this tender specification.

14.6

The following items of work shall be incidental and forming part of piping fabrication and erection:

- (1) To locate cause of vibrations in equipments/auxiliaries/pipelines and carrying out necessary corrections in case the same is attributed to the contractor.

TECHNICAL CONDITIONS OF CONTRACT (TCC)

Chapter-XIV PIPING INSTALLATION

- (2) Fabrication and erection & welding of racks, steel supports, guides, restraints for all the piping. Steel for this purpose will be supplied by BHEL free of charge in random and running lengths.
- (3) Pre-assembly of spring suspension/hangers and shock absorber as per requirement.
- (4) Erection of steam traps, filters, flow nozzles/ flow indicators/ flow orifices other measuring elements in the piping. These may have been supplied either by BHEL or their customer. This may involve cutting of pipe lines, fresh edge preparation and welding with stress relieving wherever applicable.
- (5) Fabrication / making of bends for pipes and tubes of diameter up to 65mm.
- (6) Matching of all fittings like tees, bends, flanges, reducers valves, socket fittings, etc with pipes for welding.
- (7) Servicing of valves, Power Cylinders and actuators etc.
- (8) Cleaning of all pipes by wire brushing / blowing by compressed air.
- (9) Welding of root valves with small length of piping to the pressure, flow and level tapping points on piping or flow nozzles/orifices/metering/ measuring elements fixed on piping.
- (10) Welding of blanks with stress relieving if required on a temporary basis.

14.7

Pipelines will be field routed as per schemes/ suggestive layout or as per the instructions of BHEL engineer. Pipes & tubes will be supplied in random lengths and running lengths. The contractor shall have to lay the piping after carrying out the necessary fabrication, edge preparation, routing etc to suit site requirement in best professional manner.

14.8

As far as possible, pre-assembly shall be done. The pipe laying shall be carried out from the available terminal point/points or any other area between the terminal points. The erection can be carried out on temporary supports to obtain proper alignment and welding. After fixing the permanent supports, all the temporary supports shall be removed. The alignment, distances and loading of the supports shall be checked and the required settings to be ensured as per requirement.

TECHNICAL CONDITIONS OF CONTRACT (TCC)

Chapter-XV CONDENSER INSTALLATION

15 CONDENSER INSTALLATION

15.1

The condenser will be dispatched in loose parts mainly comprising of bottom plates, dome valves, front and rear water chamber, front and rear water boxes, side walls, hot well, spring elements, support plates, air extraction pipes, baffles, stiffening rods and pipes etc. the condenser is to be assembled at site in position by welding the different parts. Condenser tubing and tube expansion (roller expansion) is to be done at site by the contractor, after taking due care to clean all the tube holes. After final alignment and leveling of turbine exhaust and condenser, the same has to be welded to the exhaust position of LP exhaust as per the sequential welding procedure. Condenser tube material is stainless steel.

15.2

Before insertion of tubes, the contractor shall clean the holes in the tube plates and tube support plates to remove paint, corrosion spots, oxide scales etc. Usage of suitable cleaning agent may also be required which has to be supplied by the contractor.

15.3

The tubes shall be expanded using an Automatic Electronic Torque Controlled Tube Expanding unit or Pneumatic Tube Expander. Tube expansion shall be checked with dial bore gauge. The total set up including tube expanders and tube cutting tools etc. for carrying out the complete condenser tube expansion works shall be provided by the contractor.

15.4

The contractor shall carry out the condenser neck welding with LP cylinder exhaust hood only after final installation of LP casing. Neck welding shall be subjected to specified non-destructive testing.

15.5

The hydrostatic testing of steam space and hydraulic testing of water space up to the terminal point after assembly of water boxes are also included in the scope.

15.6

Work of painting of condenser surfaces in various area and at various stages of work are specified elsewhere in these specifications.

TECHNICAL CONDITIONS OF CONTRACT (TCC)

Chapter-XVI GENERATOR & HANDLING EQUIPMENTS

16.1 GENERATOR INSTALLATION

16.1.1 GENERATOR STATOR

The Generator stator, weighing approximately 218 MT may be transported from Manufacturing Unit to site by special wagon consisting of 8 bogies (four on either side) with facilities to swivel or **by special trailer**. The contractor shall have to unload the generator stator from the Wagon/Trailer at a suitable place outside Machine Hall. The Stator shall be moved from the place of unloading and placed within the reach of strand jack arrangements by the contractor in consultation with BHEL Engineer.

16.2.2

THE GENERATOR STATOR SHALL BE LIFTED AND PLACED BY THE CONTRACTOR WITH THE HELP OF STRAND & JACK AS PER THE SCHEME ENVISAGED BY BHEL ON TO THE GENERATOR FOUNDATION.

Generator Stator shall be lifted by Strand & Jacks / Lift & Shift arrangement method. The Scope of contractor shall take complete responsibility and carry out the liaison and follow up with transporters, filling of ditches/levelling etc. for marching of wagon to unload at suitable location/point of lifting near the TG building, Shifting of same providing required arrangements to suitable locations / point of lifting etc. (as per requirement), arranging the Strand & Jacks/Lift & Shift arrangements, making resting Foundations /Footings to suit the installation of his Strand & Jacks arrangements (as required) & their assembly /installation with expert supervision till lifting & placement of stator to required / designed foundation / elevation. Contractor's responsibility shall also to carry out all related civil works/ footings / foundations with providing of all materials for his strand & jacks / Lift & shift arrangements as scope of work.

16.2.3

THE ASSEMBLY OF THE SPECIAL WAGON FOR RETURN AFTER UNLOADING OF STATOR IS IN THE SCOPE OF THIS WORK.

For lifting and placement of stator, it may require holding the some of structures / casting of certain foundations. Contractor shall visit site and study & discuss with BHEL Engineer at site and submit his plan (which shall not affect the project schedule) for deployment of these arrangements at site for lifting of these equipments along with Technical Bid. Contractor shall deploy these Strand and Jacks arrangements & other resources well in advance to suit the site requirement so as to lift & place these equipments on required foundations in minimum possible time. Some of the renowned agencies such as (1) **M/s. Fagioli PSE India Pvt. Ltd.(203,Krishna Bhavan, Govandi Station Road, Deonar, Mumbai-400088,Tel.No. 022-25564388, Fax No. 022-25562565)**, (2) **M/s. Freight Wings (P) Ltd.(309, Rex Chambers, Walchand Hirachand Marg. Ballard Estate, Mumbai-400001,Tel. No.022-22631714/22619988)**, (3) **M/s. Dorman Long Technology Ltd.(233, Bharat Industrial Estate, Lal Bahadur Shashtry Marg, Bhandup-West, Mumbai-400078, Tel No. 022-25961960, Cell No. 09820192807)**, (4) **M/s. Basu & Basu Engineers (Pvt.) Ltd.(Kolkata, Tel. No. 033-24642967/24664069, Fax No. 033-24664621)** who are in this field in the country, known to BHEL, can be contacted (if required) by contractor or any other similar agencies known to contractor.

TECHNICAL CONDITIONS OF CONTRACT (TCC)

Chapter-XVI GENERATOR & HANDLING EQUIPMENTS

The lifting and placement of stator shall be required to be done and put on foundation within one week time after availability of material and other essential inputs, and clear the holds for further civil & structural works.

Lifting of these equipments by Jacks and Sleeper method is not permitted.

16.2 HANDLING OF HEAVIER EQUIPMENTS

Contractor shall provide all required suitable cranes and trailers for loading of materials during collection of from BHEL/ client's stores/ storage yard, transportation to site of work and at work site including unloading at site of works for all equipments and consignments including heavy and voluminous equipments/ components/ consignments like HP turbine module, IP turbine module, LP turbine inner-outer casing, LP turbine inner casing, LP rotor, generator rotor, brushless exciter, HP heaters, etc.

BHEL shall not provide any T&P other than those specified for the specific work as per relevant Appendix and other relevant clauses of tender specification.

TECHNICAL CONDITIONS OF CONTRACT (TCC)

Chapter-XVII HYDROSTATIC TESTING, PRESERVATION & OTHER TESTS

17 HYDROSTATIC TESTING, PRESERVATION & OTHER TESTS

17.1

Contractor shall carry out the following tests required to complete the erection and commissioning of the TG Set:

- (1) Hydraulic testing of individual equipments like condenser, coolers, heaters, other auxiliaries and equipments. Required capacity Hydraulic test pump/Fill pump and other necessary arrangement shall be provided by contractor to carry out hydraulic testing, chemical cleaning of the equipments and piping as part of scope of work under this tender specification.
- (2) Ultrasonic test
- (3) Dye Penetrate test
- (4) Magnetic Particle Test.

All above facilities (men, materials, equipments, consumables etc) with operating engineer/experienced person and proper approach wherever required shall be provided by the contractor for satisfactory completion of the above tests.

17.2

Contractor shall lay all necessary temporary piping, welding, supports, install pumps, valves, pressure gauges, electric cables and switches etc, required for the Hydro test, Air leak test, Chemical cleaning, Steam blowing etc.. After the test is over, all the temporary piping, pumps, etc will be removed. It may also specifically be noted that servicing, erection and dismantling of piping and equipments for conducting above tests will be done by the contractor. No separate payment shall be made for this purpose.

17.3

All the above tests shall be repeated till all the equipments, piping and systems satisfy the technical and statutory requirements. All related works form part of the scope.

17.4

Suitable welding and stress relieving of temporary blanks or suitably fixing temporary blank flanges with gaskets and fasteners and welding and providing suitable de-aeration/ venting /drain points with valves as per BHEL engineer's instruction, for performing hydro test of piping is within the scope of work. Required valves, fasteners, blank flanges, blanks or steel for blank flanges shall be provided by contractor. After completion of hydraulic test, welded blanks shall be cut and removed and weld burrs ground finished and cavities/scars of cutting weld filled and ground as per BHEL engineers' instruction.

17.5

Hydro test of piping may have to be repeated several times to meet technical and statutory requirements before application of insulation.

17.6

While conducting hydraulic test of steam lines, water lines, oil lines either individually or grouping a few lines or in portions. Blanks/spools may have to be put up at terminal points, strainers, walls, flanges etc. After conducting the tests, the blanks shall be removed and the lines restored. Also interconnecting piping between boiler and turbine, the hydraulic test may have to be done section

TECHNICAL CONDITIONS OF CONTRACT (TCC)

Chapter-XVII HYDROSTATIC TESTING, PRESERVATION & OTHER TESTS

wise and some-times piping of other agencies may have to be combined. Contractor shall carry out all such incidental work to satisfactorily conduct the hydro test. Wherever work is involved in the terminal points, Contractor shall carryout the same as per instruction of BHEL engineer. The decision of BHEL engineer is final and the same is binding on the contractor.

The contractor shall carry out any other tests as desired by BHEL engineers on erected equipment covered in the scope of this contract during testing and commissioning to demonstrate the satisfactory completion of any part or whole of work performed by the contractor.

TECHNICAL CONDITIONS OF CONTRACT (TCC)
Chapter-XVIII PRE-COMMISSIONING TESTS, COMMISSIONING, POST
COMMISSIONING

18 PRE-COMMISSIONING TESTS, COMMISSIONING, POST COMMISSIONING

18.1

Commissioning of the TG equipments with associated Aux. and other Equipments with auxiliaries shall involve the following tests and activities of the equipments erected:

- (a) Trial run of Boiler Feed Pumps, CEP, Vacuum Pumps, Booster Pump, etc and other pumps/equipments like Misc pumps etc and other various rotating machineries / pumps as per tender specification.
- (b) Trial run of motors/ drives for various auxiliaries.
- (c) Hydraulic Test, Chemical Cleaning, Oil flushing of lube oil system, Jacking oil/Lifting oil, HP oil supply system, Governing oil system/Control oil system, LP Bypass system, Air cleaning/blowing of pipelines, closed systems, Tanks and Vessels.
- (d) Flushing of all pipelines by air/oil/water/Chemicals/steam as the case may be.
- (e) Servicing of all valves, Hydraulic Power cylinders, HP Valves (ESV), HP Overload Bypass valves, IP Valves, LP Bypass valves, CRHNRV and fittings.
- (f) Manual/mechanical cleaning of Oil tanks, Suction Strainers / Filter elements of CEP, BFP, Booster Pump, Vacuum Pumps, Misc. Pumps, and other various equipments & tanks /vessels erected by the contractor. This may have to be repeated several times during the commissioning process.
- (g) Chemical cleaning of piping systems, as per requirement. Contractor shall carry out disassembly and reassembly of vulnerable components like spray nozzles, gauges, instruments etc. as instructed by BHEL during this process.
- (h) Putting turbine on barring gear.
- (i) Rolling and synchronization.
- (j) Full load operation.
- (k) Trial operation
- (l) Assistance in PG Test.

The above activities/tests/trial runs may have to be repeated till satisfactory results are obtained and also to meet the technical and statutory requirements.

18.2

Contractor shall lay temporary pipelines with fittings and accessories etc. as instructed by BHEL engineer for the purpose of pre-commissioning and commissioning activities like Hydraulic testing,

TECHNICAL CONDITIONS OF CONTRACT (TCC)

Chapter-XVIII PRE-COMMISSIONING TESTS, COMMISSIONING, POST COMMISSIONING

chemical cleaning, oil flushing, steam blowing etc. of piping and other equipments as part of the scope of work. Temporary installations shall be dismantled by contractor and returned to BHEL stores as specified elsewhere in this technical specification.

18.3

The contractor shall provide necessary assistance to facilitate/enable electrical and instrumentation testing and commissioning of equipments under this scope of work, to BHEL and their Testing & Commissioning agency.

18.4

The contractor shall carry out any other test as desired by BHEL engineer on erected equipments covered under the scope of this contract during testing, pre-commissioning and commissioning, to demonstrate the completion of any part or parts of work performed by the contractor.

18.5

In case any malfunctioning and / or defect is found during tests / trial runs such as loose components, undue noise or vibrations, strain on connected equipments etc. The contractor shall immediately attend to these defects/ malfunctioning and take necessary corrective measures. If any readjustment and realignments are necessary, the same shall be done as per BHEL engineer's instructions, free of cost.

18.6

Cleaning of oil tank by sand blasting or other methods as per instructions of BHEL engineer before and after oil flushing is responsibility of contractor.

18.7

The contractor shall associate for initial and subsequent fillings of gas in generator gas system and when required till unit is handed over to Customer.

18.8

The contractor shall carry out leak test of generator air cooling system to the satisfaction of BHEL engineer.

18.9

Replacing/changing mechanical/other seals of equipment, pumps etc. during commissioning stage is within the scope of work.

18.10

During the stages of commissioning, and till Unit is handed over, if any part of TG and auxiliaries need repair/rectification/rework/replacement, the same shall be done expeditiously and promptly by the contractor. Contractor's claim if any, for such repair/rectification/rework/ replacement etc for reasons not attributable to the contractor will be governed by relevant clauses of 'General Conditions of Contract'. The parts to be replaced shall however, be provided by BHEL free of cost.

18.11

TECHNICAL CONDITIONS OF CONTRACT (TCC)

Chapter-XVIII PRE-COMMISSIONING TESTS, COMMISSIONING, POST COMMISSIONING

During this period, though BHEL's and customer's engineers will also be associated in the work, the contractor's responsibility will be to make available resources in his scope till such time the commissioned units are taken over by the customer.

18.12

In case any malfunctioning and/or defects are found during tests, trial run such as loose component, undue noise or vibration, strain on connected equipment etc., The contractor shall immediately attend to these defects/ malfunctions and take necessary corrective measures. If any readjustment or realignment is necessary, same shall be done as per BHEL engineer's instruction.

18.13

The pre-commissioning activities will start prior to Lube oil, HP Oil supply System, Governing/ Control oil flushing etc. of the TG and various trials, commissioning operations shall continue till the TG is handed over to customer. Simultaneous commissioning checks, activities will be in progress in various areas like trial run of various equipment, checking of equipment erected, making ready for trial runs, filling up of lubricants, chemicals etc. All these works need specialized gangs including electricians, Instrument Technicians, Fitters, in each area to render assistance to BHEL commissioning staff. Contractor shall earmark separate manpower for various commissioning activities. This manpower shall not be disturbed or diverted. The mobilization of these commissioning gangs shall be sufficient so that planned commissioning activities are taken up in time and also completed as per schedule and the work is to be undertaken round the clock if required.

18.14

Contractor shall cut open works if needed as per BHEL engineer's instructions during commissioning for inspection, checking and make good the works after inspection is over, without any extra payment.

18.15

After the start of commercial operation of machine, commissioning activities will continue. It shall be the responsibility of contractor to provide following manpower along with supervisor as part of commissioning assistance for a period of three months **per Unit**.

- | | |
|--------------------------------------|------------|
| 1) Supervisor | 2 Nos. |
| 2) Pipe fitter/Millwright fitter | 2 Nos. |
| 3) Welder | 2 Nos. |
| 4) Rigger | 2 Nos. |
| 5) Electrician/instrument technician | 1 No. each |
| 6) Unskilled worker | 6 Nos. |

18.16

The above figures shows only minimum required over and above labour required for completing pending erection and commissioning works and clearing of punch lists. Contractor has to provide number of personnel and other resources as per work demand.

18.17

TECHNICAL CONDITIONS OF CONTRACT (TCC)

Chapter-XVIII PRE-COMMISSIONING TESTS, COMMISSIONING, POST COMMISSIONING

It shall be specifically noted that above employees of the contractor may have to work round the clock along with BHEL commissioning engineers.

18.18

During commissioning, opening of valves, changing of gaskets, checking, realigning of rotating and other equipment, attending to leakages in piping, tanks etc and adjustments of erected equipment may arise. Valves shall be serviced and lubricated to the satisfaction of BHEL engineer during the erection and commissioning as per BHEL engineer's instructions.

18.19

It is the responsibility of the contractor to provide for necessary resources till the completion of work under these specifications, even in case erection, testing and commissioning of the TG and other equipments are delayed due to reasons not attributable to the contractor.

TECHNICAL CONDITIONS OF CONTRACT (TCC)

Chapter-XIX WELDING, HEAT TREATMENT, RADIOGRAPHY

19.1 WELDING AND HEAT TREATMENT

19.1.1

Removal of welding slag and burrs by hand files, with brushes and/or flexible grinders will be carried out simultaneously.

19.1.2

On all steam, oil, instrument, gas, air (Instrument air/services air) piping, Cooling water Piping, DM water piping etc. both TIG welding and subsequent arc welding or total TIG welding process is to be adopted as instructed by BHEL engineer.

19.1.3

All weld joints on piping shall be ground / filed / dressed on completion of welding and before NDE as per instructions BHEL engineer.

19.1.4

The Contractor shall procure all electrodes and filler wires of approved quality / brand as per the standards and specifications of BHEL and instruction of BHEL Engineer.

19.1.5

Contractor should purchase the electrodes as per the recommendations of BHEL engineer, welding manual, welding schedule and other relevant documents. The electrodes shall be purchased only from BHEL approved manufacturers.

19.1.6

The purchase of electrodes shall be accompanied by proper test certificate and these certificates should be submitted regularly for the scrutiny of BHEL engineer.

19.1.7

All electrodes shall be stored in a clean dry area. The storage room shall be of permanent nature and damp proof, and the room shall be exclusively meant for storage of welding electrodes and filler wires. Excepting for a vent in the top, it is not preferred to have any other opening like windows or ventilators. The temperature inside the room has to be kept in the range of 8-10⁰ c above atmospheric temperature and humidity should be less than 50%. This is to be accomplished by using electric heaters or infrared lamps. The storage room must be provided with hygrometer and thermometer. Temperature and humidity are to be monitored regularly. 15-20 holders, welding cables, connecting cables to equipments and other welding accessories including temporary electrical connection from construction power point to individual equipment like winches, hoisting equipment, welding generators, transformers, heat treatment equipment and other construction equipment shall be arranged by contractor.

19.1.8

All racks and other items used for storage of electrodes shall be of steel and not of wood.

19.1.9

TECHNICAL CONDITIONS OF CONTRACT (TCC)

Chapter-XIX WELDING, HEAT TREATMENT, RADIOGRAPHY

All electrodes soon after purchase shall be offered for inspection to the BHEL engineer. Contractor shall be strictly prohibited from using electrodes not inspected/approved by BHEL engineer.

19.1.10

All welding consumables shall be issued to the welders only by authorized person who is controlled by contractor's welding engineer. The necessary baking requirements are to be ensured by Contractor's welding engineer.

19.1.11

All welders shall be tested and approved by BHEL engineer/customer before they are actually engaged on work though they may possess the requisite certificate. BHEL reserves the right to reject any welder without assigning any reasons. Statutory requirements like IBR approval for welders are to be complied with before starting of the work. If required, the welders may have to undergo Procedure Qualification test also. The decision of BHEL Engineer will be final in this regard.

19.1.12

All charges for testing of contractor's welders including destructive and non-destructive tests conducted by BHEL at site shall have to be borne by the contractor. However for initial testing of welders the test will be provided by BHEL. However, if deployed welders fails in initial testing due to lack of experience OR frequent testing of new welders, due to non-availability/non-deployment of earlier qualified/tested welders, it shall be the responsibility of Contractor to provide necessary test plates at his cost for above testing.

19.1.13

BHEL engineer is entitled to stop any welder from his work if his work is unsatisfactory for any technical reason or if there is a high percentage of rejection of joints welded by him, which, in the opinion of BHEL engineers, will adversely affect the quality of welding though the welder has earlier passed the tests prescribed. The fact that the welders have passed the test does not relieve the contractor from his contractual obligations to check the performance of the welders. Contractor shall submit a monthly performance record of all welders.

19.1.14

All welded joints shall be subject to acceptance by BHEL engineer whose decision will be final and binding.

19.1.15

Pre-heating and stress relieving before and after welding are part of erection work and shall be performed by the contractor in accordance with instructions of BHEL engineer. Contractor has to arrange for the recorders along with accessories and suitable technicians for heat treatment purpose. The temperature recorders and thermocouples shall be duly calibrated. During preheat and stress relieving operations the temperature shall be measured as per the instructions of BHEL engineers by thermocouples and recorded graphs for the heat treatment works carried out shall be the property of BHEL.

19.1.16

TECHNICAL CONDITIONS OF CONTRACT (TCC)

Chapter-XIX WELDING, HEAT TREATMENT, RADIOGRAPHY

For the purpose of stress relieving, thermocouples have to be attached to the weld joint. The number of temperature measuring points and locations are as per the standards of BHEL. Thermocouples have to be attached using battery operated portable thermocouple attachment unit and not by manual arc welding. Contractor shall arrange sufficient number of thermocouple attachment units.

19.1.17

Wherever necessary, contractor should provide temperature indicator/temperature recorder as required by BHEL engineer for measuring preheat temperature for welding or for controlling temperature of metal for hot correction etc. Decision of BHEL engineer on method and of checking preheat temperature or controlling temperature for hot correction and welding shall be final and binding on contractor.

19.1.18

Heat treatment may be required to be carried out at any time (day or night) to ensure the continuity of the process. The contractor shall make all necessary arrangements including labour required for the same as per directions of BHEL.

19.1.19

Heat treatment requirements shall be as per the Welding Schedules of BHEL

19.1.20

For weld joints of heavy structural items like beams, I-sections, if heat treatment is required, the same shall be carried out as part of the work.

19.1.21

Checking effectiveness of stress relieving by hardness tests (either by Poldi Hardness Tester or other approved test methods as per BHEL engineer's instruction) including necessary testing equipments is within the scope of the work/specification.

19.1.22

TIG welding process is to be used for all root pass welds in pipes. Subsequent welding after root pass can be carried out by manual metal arc welding with basic coated electrodes. For the pipe of thickness less than 6mm, the entire welding has to be carried out by TIG welding. However, BHEL site engineer will have the option of changing the method adopted. For manual arc welding shall be done as per weaving technique and the width of weaving shall not exceed 1.5 times of the dia of the electrodes.

19.1.23

Two pieces to be joined shall be individually checked for the weld edge preparation and profile dimensions and with respect to the template. Dye penetrant check shall be carried out on edge prepared surfaces at random. The percentage shall depend on piping system as specified by BHEL engineer.

19.1.24

Joint fit up will be a stage for inspection.

TECHNICAL CONDITIONS OF CONTRACT (TCC)

Chapter-XIX WELDING, HEAT TREATMENT, RADIOGRAPHY

19.1.25

All joints shall be offered for visual inspection after root run. Subsequent welding should be made only after the approval of root run.

19.2 RADIOGRAPHY

19.2.1

Radiographic inspection of welds shall be arranged by the contractor including all consumables like isotope camera, x-ray film, chemicals etc. Scaffolding and approaches for taking radiographs.

The contractor shall provide the necessary skilled technician and labours for taking the radiographs. While taking radiographs, the contractor has to use proper penetrometer/ image quality indicators as instructed by the BHEL engineer. All the processed and accepted films will be the property of BHEL. In this regard, the contractor has to adhere to the safety rules/regulations laid by BARC authorities from time to time. It may please be noted that invariably the radiographic work will be carried after the normal working hours.

19.2.2

Contractor shall note that 100% radiography shall be taken on all high pressure welding till such time the welders' performance is found to be satisfactory. Subsequently, subject to consistency in welder's performance, the percentage of radiography will be based on BHEL's standard practice/code requirement. The defects shall be rectified immediately and to the satisfaction of BHEL engineer. The decision of BHEL engineer regarding acceptance/rejection of the joints will be final and binding on the contractor.

19.2.3

Wherever radiographs are not accepted, on account of bad shot, joints shall be re-radiographed and re-shots submitted for evaluation. Radiographs shall be taken on joints after carrying out repairs. However, if defect persists after first repair, as per radiograph, carrying out repairs and radiography shall be repeated till joint is made acceptable in case, the joint is not repairable, the same shall have to be cut and repaired at contractor's cost. Decision of BHEL engineer in all these matters is final and binding on the contractor.

19.2.4

100% radiography of weld joints of certain piping has to be carried out as per BHEL standards/drawings/specification.

19.2.5

It may also become necessary to adopt inter-layer radiography/MPT/UT depending upon the site/technical requirement necessitating interruptions in continuity of the work and making necessary arrangements for carrying out the above work. Necessary trained personnel shall be deployed for this purpose.

TECHNICAL CONDITIONS OF CONTRACT (TCC)
**Chapter-XX ACID CLEANING/ALKALI FLUSHING/STEAM BLOWING/OIL
FLUSHING**

20 ACID CLEANING/ ALKALI FLUSHING/ STEAM BLOWING/ OIL FLUSHING ETC

20.1

Contractor shall lay and erect temporary pipelines with fittings and accessories and also erect/commission the chemical cleaning/ circulating pumps after servicing as per requirements, tanks and other installations, as a system as instructed by BHEL for the purpose of chemical cleaning, steam blowing, steam washing, steam flushing, water flushing, water washing, oil flushing of piping and shall provide all other arrangements as per requirement as part of scope of work.

It shall be specifically noted by the contractor that all pipes for above works shall be supplied in random length and in loose condition. Contractor has to assemble and erect them as per schemes / drawings provided by BHEL. Further, flanges bend etc for completing the scheme shall be machined/ fabricated by the contractor at his own cost. However, plates/ steel etc for the same will be provided by BHEL free of charges.

20.2

After the chemical cleaning/ flushing have been successfully completed, dismantling of all temporary installations as instructed by BHEL is within the scope of work under this specification. The dismantled materials shall be dressed and returned to BHEL as stated elsewhere in this tender spec.

20.3

Preservation of the cleaned surfaces will be the responsibility of contractor under the guidance of BHEL engineer.

20.4

Hydraulic test of temporary piping is to be carried out as per the instructions of BHEL Engineer. Carrying out repairs, if any, is in the scope of work/specification.

20.5

For chemical cleaning of the piping system, contractor will have to lay temporary piping to connect the entire system irrespective of whether the equipment/system connected is in the scope of contractor or not. Decision of BHEL Engineer in this regard will be final and binding on the contractor.

20.6

During the initial stages of work, trenches for draining water may not be available after alkali flushing or mass flushing for discharging and emptying. Necessary low point drains and temporary piping for this will have to be provided by contractor from materials provided by BHEL.

20.7

Laying effluent discharge line from mixing tank (for acid cleaning or any other chemical cleaning process) as per the instructions of BHEL engineer and dismantling, servicing for preservation and handing over the same to BHEL stores after completion of the job is within the scope of work/specification.

TECHNICAL CONDITIONS OF CONTRACT (TCC)
**Chapter-XX ACID CLEANING/ALKALI FLUSHING/STEAM BLOWING/OIL
FLUSHING**

20.8

Radiographic examination of weld joints on temporary pipes as required by the Engineer In-charge should be carried out.

20.9

Contractor shall also carry out the repairs or attend leaks etc., in the temporary piping and equipments for the above operations / activities while carrying out the above activities / operations.

20.10

For chemical cleaning of system which consist of equipment/piping erected by the contractor and also equipment/piping erected by other contractors of BHEL/customer's contractor has to arrange for workers and supervisory staff as required supplementing/complimenting the labour and supervisory staff mobilized by other agencies for chemical cleaning of the portion of equipment erected by them in the system. Decision on the strength of gangs and supervisory staff for deployment of labour and allocation of work for them at site by BHEL engineer is final and binding on the contractor.

20.11

Contractors quoted rate shall be inclusive of fabrication, cost of consumables, erection, dismantling of temporary piping and servicing of the equipments and valves and handing over to BHEL. No separate payment on this account shall be entertained.

20.12

After acid cleaning/pickling of lubricating system (including oil piping of lube oil system, HP Oil supply system, oil tank and other fittings) of rotating machines, oil flushing for lubricating systems, LP Bypass systems etc as per instructions of BHEL Engineer shall be carried out. Cleaning of oil tank of lubricating oil system of rotating machineries, cooler etc before and after oil flushing is the responsibility of the contractor.

20.13

For full welding of structures, tanks and piping etc, only welding generators shall be used. The use of welding transformers will be subject to the approval of BHEL Engineer.

20.14

Erection and commissioning of connecting piping – permanent and temporary for oil purification equipments and all operations for cleaning, oil flushing, dismantling of temporary piping during pre and post-commissioning of equipment up to full load shall be the responsibility of contractor as part of scope of work.

TECHNICAL CONDITIONS OF CONTRACT (TCC)

Chapter-XXI TOOLS AND TACKLES, MEASURING AND MONITORING DEVICES

21 TOOLS AND TACKLES, MEASURING AND MONITORING DEVICES

21.1

The contractor shall provide all (except those indicated in BHEL scope) required tools and plants, monitoring and measuring devices (MMD) and handling & transportation equipments for the scope of work covered under these specifications. Contractor has to provide suitable cranes for material handling at BHEL/client's stores/storage yard. BHEL's crane will not be available for this purpose. Please refer relevant appendix for the list of T&P being provided by BHEL free of charges on sharing basis.

21.2

All tools and tackles to be deployed by the contractor for the work shall have the prior approval of BHEL engineer with regard to brand, quality and specification. Indicative list of major T&P to be arranged by contractor has been furnished in relevant appendix. Contractor shall also mobilize all other T&P necessary for timely and satisfactory completion of the work in scope.

21.4

Contractor shall provide all required suitable cranes and trailers for materials handling during collection from BHEL/ client's stores/ storage yard, transportation to site of work and at work site for all equipments and consignments including heavy and voluminous equipments/ components/ consignments like HP turbine module, LP turbine inner-outer casing, LP turbine inner casing, LP rotor, generator rotor, brushless exciter, HP heaters, etc. BHEL/customer shall not provide any T&P other than mentioned in relevant appendix for the purpose identified. The contractor shall make suitable arrangements/arrange crane well in advance for lifting and placement to final position of sections at required elevation/ location with utmost care.

21.5

Contractor shall provide the complete operating crew like operator, helpers for handling trailing cable for EOT. It may be specifically noted that the EOT crane shall be shared by many other agencies working within the TG hall. The contractor shall have to extend the services of the EOT crane operation to all such other agencies as instructed by BHEL; the operation cost (for crew) will be shared proportionately amongst the beneficiary agencies on mutually agreed terms and rate.

21.6

Contractor has to provide spanners of all sizes for carrying out the complete erection / commissioning works. No spanners will be provided by BHEL to the contractor.

21.7

Contractor has to arrange slings of all sizes for completing the works covered under these specifications except the special slings for generator stator lifting/handling, which will be provided by BHEL free of charges on returnable basis.

TECHNICAL CONDITIONS OF CONTRACT (TCC)

Chapter-XXI TOOLS AND TACKLES, MEASURING AND MONITORING DEVICES

21.8

All tools and tackles to be deployed by the contractor for the work shall have the prior approval of BHEL engineer with regard to brand, quality and specification.

21.9

Timely deployment of adequate quantity of T&P is the responsibility of the contractor. The contractor shall be prepared to augment the T&P at short notice to match the planned program and to achieve the milestones.

21.11

Complete set of hydraulic jacks of 50 tonnes and 100 tonnes capacity shall be arranged by the contractor for use during erection and commissioning of turbine. Also, the contractor shall arrange hydraulic jacks of 100 tonnes and 63 tonnes capacity along with long high pressure hoses of suitable length for generator erection and alignment. These jacks shall be of internationally reputed make, highly reliable and maintained in excellent working condition. They shall be tested for safe working before deploying in actual work. These jacks shall not be permitted for use anywhere other than steam turbine/ generator area.

21.12

All jack bolts that are required during erection for carrying out roll-check etc will have to be arranged by the contractor. No jack bolts will be provided by BHEL.

21.13

Contractor shall maintain and operate his tools and plants in such a way that major breakdowns are avoided. In the event of major breakdown, contractor shall make alternative arrangements expeditiously so that the progress of work is not hampered.

21.14

In the event of contractor failing to arrange the required tools, plants, machinery, equipment, material or non-availability of the same owing to breakdown, BHEL will make the alternative arrangement at the risk and cost of the contractor.

21.15

The T&P to be arranged by the contractor shall be in proper working condition and their operation shall not lead to unsafe condition. Contractor shall obtain prior approval of BHEL for all the T&P before deploying in actual work. The movement of cranes and other equipment should be such that no damage / breakage occur to foundations, other equipments, material, property and men. All arrangements for the movement of the T&P etc shall be the contractor's responsibility.

21.16

Normally, use of welding generators only is permitted for welding. The use of welding transformers will be subject to prior approval of BHEL.

21.17

The contractor at his cost shall carry out periodical testing of his construction equipments and calibration of measuring & monitoring devices (MMD). Test / calibration certificates shall be

TECHNICAL CONDITIONS OF CONTRACT (TCC)
Chapter-XXI TOOLS AND TACKLES, MEASURING AND MONITORING
DEVICES

furnished to BHEL. MMD shall be calibrated only at accredited laboratory as per the list available with BHEL or any other laboratory approved by BHEL. All calibration shall be traceable to national or international standards.

TECHNICAL CONDITIONS OF CONTRACT (TCC)

Chapter-XXII PRESERVATIVE PAINTING

22 WELD FIT-UP AND WELD JOINT PROTECTIVE PAINT, COMPONENT PRESERVATIVE PAINTING ETC.

- 1) All protective paints for the protection of weld joint fit-ups, application of primers on finished weld joints are in the scope of contractor.
- 2) Two coats of steam washable paints shall be applied on steam side of LP turbine and condenser components, as advised by BHEL. The steam washable paints, primer and thinner will be provided by contractor as part of scope of work along with other like arrangements for surface preparation and paint application like sand/shot-blasting, consumables like surface cleaning agents, paint brush, brush cleanser, labour and necessary tools and plants as required for completion of work.
- 3) The water boxes shall be sandblasted to remove all traces of primer applied at the works. Thereafter apply two coats of primer paint followed by two/three coats of alloyed resin machinery enamel paints as approved by BHEL. Contractor shall submit manufacturer's batch test certificate / test certificate from BHEL approved laboratory for the primers and paints. Prior approval of BHEL for each and every batch of the primer & paints shall be mandatory. In order to achieve a desired minimum paint dry film thickness (DFT) as specified in BHEL drawing, number of coats may be applied and method of application shall be as recommended by the paint manufacturer. Required paints & primers and other consumables shall be arranged by contractor.
- 4) All site weld joints falling in steam side shall be painted with two coats of steam washable paint.
- 5) All water side surfaces of water chambers including tube plate shall be thoroughly surface prepared and painted. Required primer & paints and other consumables for condenser water box and tube plates shall be provided by Contractor.
- 6) After the successful completion of hydraulic testing, the interior surfaces of the water boxes, main tube plates shall be painted with suitable anticorrosive paints as per special procedures laid down by BHEL. Required necessary paints along with primers and other consumables shall be arranged by Contractor.
- 7) Prior to hydraulic testing of water side of condenser, interior surfaces of water boxes shall be painted.
- 8) After completion of tubing and tube side hydro test, all water side surfaces of water chambers including tube plate shall be painted.
- 9) Preservation of all components/equipments during various stages of erection, commissioning till handing over is in the contractor's scope. All prescribed methods of surface cleaning prior to application of preservative paint shall be followed by the contractor. **Contractor has to arrange all primer and paints, and other consumables like wire brush, painting brush required for this work.**

TECHNICAL CONDITIONS OF CONTRACT (TCC)

Chapter-XXIII LINING AND INSULATION

23 LINING AND INSULATION

23.1

Application of thermal insulation/ spray insulation, finishing, cladding and outer casing etc of the following:

1. TG integral piping and tanks & vessels
2. Other equipments including bois, though not listed above but required for completion
3. ST-TG auxiliaries including, but not limited, to heat exchangers, pumps, tanks and vessels and other equipments
4. TG integral piping including condensate and extraction system piping

23.2

The work shall conform to dimension and tolerances specified in the various drawing and documents that will be provided during the execution. If any portion of the work is found to be defective in workmanship or not conforming to drawings or other specifications, the contractor shall dismantle and re-do the work duly replacing the defective materials at his cost. Failing which the work will be got done by engaging other agencies or departmentally and recoveries will be deducted from contractor's bills towards expenditure incurred including 30% departmental charges.

23.3

The terminal points as decided by BHEL shall be final and binding on the contractor.

23.4

All insulation and refractory materials including iron components and outer sheet casing materials, cladding sheets etc required will be supplied by BHEL and the same have to be erected/ applied as per the drawings and specifications of BHEL by the contractor.

23.5

The contractor shall provide the required quantity of wire, nails, and planks for formwork and other materials for shuttering and curing works.

23.6

Contractor shall observe all precaution for laying, curing etc of pourable insulation. The contractor at his own cost shall redo any defective works found.

23.7

Wool insulation is received at site as loose bonded mattresses in standard sizes. These are to be dressed/cut to suite the equipments. Multiple layers of wool have to be applied as directed and as per drawings and specifications for all equipments/ systems covered under the scope of work.

23.7

Cutting & dressing of insulation bricks to suit the site area of application is incidental to work.

23.8

Removable type of insulation has to be provided for valves fittings, expansion joints etc as per drawing or as directed by BHEL engineer.

23.9

TECHNICAL CONDITIONS OF CONTRACT (TCC)

Chapter-XXIII LINING AND INSULATION

The cladding and outer casing are aluminium sheets. All relevant specifications and procedures with regards to beading, sealing etc for aluminium sheets have to be adhered to.

23.10

Cladding/outer casing shall be fixed expeditiously, so as to avoid damage to the insulation from the weather.

23.11

The overlapping surface of outer casing/cladding sheet shall be coated with sealing compound, which will be supplied by BHEL free of cost.

23.12

To take care of bimetal corrosion due to variety of metals in contact of each other viz retainer to support, support to outer casing/cladding, cladding-to-cladding etc, suitable paints specified by BHEL, to be applied and/or neoprene rubber packing/strips or any other insert may have to be fixed as required.

23.13

The contractor shall leave certain gaps and openings while doing the work as per the instructions of BHEL engineer to facilitate inspection or during commissioning to fix gauges, fittings, instruments etc. These gaps will have to be finished as per drawings at later date by the contractor at his cost.

Contractor shall cut open works in needed as per BHEL engineer's instructions during commissioning for inspection, checking and make good the works after inspection is over without any extra payment.

23.14

A log book shall be maintained by the contractor for the clearance of the area for application of refractory and insulation where the contractor does the work on his own accord without prior permission. The work should be re-done, at his own cost, where necessitated.

23.15

Wastage allowances for the material issued are envisaged as follows:

A	Pourable & castable insulation	-	2%
B	Insulation bricks and mortar	-	2%
C	Wool mattresses	-	2%
D	Cladding sheets	-	2%

The wastage allowance will be applicable on the net issued quantity i.e. Total quantity issued reduced by the quantity returned to stores as unused/fresh item. Contractor shall reconcile the material issues periodically as prescribed by BHEL site. Payment for the done will be regulated as per relevant section.

23.16

TECHNICAL CONDITIONS OF CONTRACT (TCC)

Chapter-XXIII LINING AND INSULATION

The following works are also included in the scope of this contract:

- Cutting of cladding sheets as per the profile of the equipment and painting on inner surface two coats of bituminous paint. Paint shall be arranged by contractor.
- Cutting of the wool mattresses to the required shape and application of finishing cement of required thickness wherever required.

23.17

Insulation work of temporary piping for alkali boil out, steam blowing and chemical cleaning has to be carried out at site. The same have to be removed and returned to the BHEL stores after the completion of activity. Rates quoted for application of wool for boiler and auxiliaries will be applicable for this work also. No separate payment will be made for removal of temporary insulation and return of the same to BHEL stores/yard.

23.18

In certain instances, co-ordinated/ phased application of castable refractory/ insulation on pressure parts etc may be necessitated in consideration of sequence of activities of other erection agencies. Contractor shall do such phased work as may be directed by BHEL.

23.19

Prior to application of refractory bituminous painting on the pressure parts and other area is under contractor scope. The bituminous paint shall be arranged by contractor. No separate payment will be made for application of paint.

TECHNICAL CONDITIONS OF CONTRACT (TCC)

Chapter-XXIV FINAL PAINTING

24 FINAL PAINTING

24.1 WORK OF PRESERVATION AND PAINTING OF CONDENSER SURFACES IN VARIOUS AREAS AND AT VARIOUS STAGES OF WORK

A. STEAM SIDE PAINTING

TWO COATS OF STEAM WASHABLE PAINTS SHALL BE APPLIED ON STEAM SIDE OF LP TURBINE AND **CONDENSER SHELL INTERNALS**, AS ADVISED BY BHEL. THE STEAM WASHABLE PAINTS, PRIMER AND THINNER WILL BE SUPPLIED BY BHEL FREE. HOWEVER, ARRANGEMENTS FOR SURFACE PREPARATION AND PAINT APPLICATION, CONSUMABLES LIKE SURFACE CLEANING AGENTS, PAINT BRUSH, BRUSH CLEANSER, LABOUR AND NECESSARY TOOLS AND PLANTS ARE IN THE SCOPE OF CONTRACTOR.

ALL SITE WELD JOINTS FALLING IN STEAM SIDE SHALL **ALSO** BE PAINTED WITH TWO COATS OF STEAM WASHABLE PAINT.

B. WATER SIDE PAINTING

THE WATER BOXES SHALL BE SANDBLASTED TO REMOVE ALL TRACES OF PRIMER APPLIED AT THE WORKS. THEREAFTER TWO COATS OF EPOXIDE PRIMING PAINT OR AS PER PAINTING SCHEME APPROVED BY GSECL FOLLOWED BY TWO/THREE COATS OF HIGH BUILD BLACK COAL TAR EPOXY (E.G., "APCODUR CP684" OF ASIAN PAINTS **OR EQUIVALENT FROM ANY OTHER BHEL/GSECL APPROVED MANUFACTURER**). CONTRACTOR SHALL SUBMIT MANUFACTURER'S BATCH TEST CERTIFICATE / TEST CERTIFICATE FROM BHEL/GSECL APPROVED LABORATORY FOR THE PRIMERS AND PAINTS. PRIOR APPROVAL OF BHEL FOR EACH AND EVERY BATCH OF THE PRIMER & PAINTS SHALL BE MANDATORY. IN ORDER TO ACHIEVE A DESIRED MINIMUM PAINT DRY FILM THICKNESS (DFT) AS SPECIFIED IN BHEL DRAWING, NUMBER OF COATS MAY BE APPLIED AND METHOD OF APPLICATION SHALL BE AS RECOMMENDED BY THE PAINT MANUFACTURER. REQUIRED PAINTS & PRIMERS AND OTHER CONSUMABLES SHALL BE ARRANGED BY CONTRACTOR.

ALL WATER SIDE SURFACES OF WATER CHAMBERS INCLUDING TUBE PLATE SHALL BE THOROUGHLY SURFACE PREPARED AND PAINTED. REQUIRED PRIMER & PAINTS AND OTHER CONSUMABLES FOR CONDENSER WATER BOX AND TUBE PLATES SHALL BE PROVIDED BY CONTRACTOR. **CARE SHALL BE TAKEN TO PLUG THE EXPANDED TUBE ENDS TO PREVENT ENTRY OF PAINT INTO THE TUBES. THE CONTRATOR SHALL ARRANGE FOR THE PLUGS IF NOT PROVIDED ALONGWITH THE TUBES.**

THE WATER SIDE PAINTING ON WATER BOXES, WATER CHAMBERS AND TUBE PLATES SHALL BE DONE PRIOR TO THE WATER SIDE HYDRAULIC TEST OF THE CONDENSER.

24.2

All exposed metal parts of the equipment including piping, structures, railings etc wherever applicable, after installation unless otherwise surface protected, shall be first painted with at least one coat of suitable primer which matches the shop primer paint used, after thoroughly cleaning all such parts of all dirt, rust, scales, greases, oils and other foreign materials by wire brushing, scraping or sand blasting, and the same being inspected and approved by BHEL engineer for painting. Afterwards, the above parts shall be finished with two coats of alloyed resin machinery enamel paints.

24.3 Touch-up painting on damaged areas –

TECHNICAL CONDITIONS OF CONTRACT (TCC)

Chapter-XXIV FINAL PAINTING

- a) For coatings damaged up to metal surface

Surface preparation shall be carried out by manual cleaning. Minimum 6 inches adjoining area with existing coating shall be roughened by wire brushing, emery paper rubbing etc., for best adhesion of patch primer. Primer coat of touch-up primer has to be applied by brush immediately after the surface preparation.

Over this primer coat, finish coat and final finish coat shall be applied as covered above by brush within maximum seven (7) days of application of touch up primer.

Painting scheme is enclosed for information at relevant annexure. However, for execution only the latest document shall be applicable and no claim whatsoever shall be entertained in case of any variance between such documents. Similarly, documents as provided progressively during the execution of work for all other products/ equipments etc shall be applicable.

24.4

Painting of welded areas / painting of areas exposed after removal of temporary supports / touch-up painting on damaged areas of employer's structures, where inter-connection, welding / modification etc. has been carried out by the bidder.

- (a.) Clean the surface to remove flux spatters and loose rust, loose coatings in the adjoining areas of weld seams by wire brush and emery paper.
- (b.) Painting procedure to be followed as mentioned above for touch-up painting on damaged areas.

24.5

The scope of work includes painting of colour bands, lettering, marking and signs for direction of flow/rotation, names etc of approved colours as per the standard colour codes and specifications specified in tender specification or as advised by BHEL/customer engineer at site for the equipments/ components covered in these specifications.

24.6

All exposed metal parts of the equipment including piping, structures, hand railing, grating etc shall be thoroughly cleaned off dust, rust, scales and other foreign materials by manual or mechanised wire brushing, scrapping, sand blasting etc and the same being inspected and approved by BHEL/customer engineer before application of primer. Afterwards, the above parts shall be finish painted with specified number of coats as per specification.

24.7

In certain isolated instances where it is not possible to clean the equipments as explained above, cleaning by grinding might have to be resorted to. No damage to the equipment/components should be caused.

24.8

Surface to be painted should be free of oil and grease. It should be removed by using suitable cleaning agents including permitted solvents. Surface cleaned by chemical agent, if required, shall be treated further as prescribed in use of such cleaning agents. The contractor at his own cost shall provide all the consumables and application implements.

24.9

During the preparation of surface, if the shop coat is damage by chemical cleaning or by mechanical means, contractor shall repair the same free of cost to BHEL.

TECHNICAL CONDITIONS OF CONTRACT (TCC)

Chapter-XXIV FINAL PAINTING

24.10

Specified drying time shall be permitted from one to another coat.

24.11

This work requires working at higher altitudes from ground level to as high as 70 m and more. The work spread is also substantial involving substantial run of structures and piping. Contractor shall take sufficient precautions to avoid any accident and hazard in all respects. The ropes, ladders, scaffolding materials, clamps etc and climber used should be of standard quality for safe and smooth execution of work.

24.12

Contractor shall carry out the work in such a way that other erected equipment, structure, civil foundations and other property are not damaged. For damages in any of such cases due to lapses by contractor, BHEL shall have the right to recover the cost of such damages from the contractor.

24.13

Contractor shall take due care to cover/protect the equipment which are already painted while carrying out the painting of other adjacent equipment. If so happens, it shall be cleaned and repainted by the contractor without any extra charges.

24.14

In general, painting of structural parts and colour bands, lettering, marking of direction of flow/rotation etc will be carried out by brush painting. However, areas/equipment inaccessible for manual painting has to be painted by spray painting. The decision of BHEL engineer, in this regard, shall be final and binding on the contractor. Laying of air hose pipe and any other line required shall be done by contractor at his cost. The contractor shall provide spray equipment set including air equipments.

24.15

The contractor shall provide all the necessary scaffolding materials, temporary structures and necessary safety devices etc, during execution of the work.

24.16

Final painting work shall be started after obtaining clearance from BHEL engineers and as per his instructions.