

Bharat Heavy Electricals Limited
(A Govt. Of India Undertaking)

Project Engineering
Management



Ref. No. PE/PG/OP1/E-4747/2014-05
Enquiry No.: PE/PG/OP1/E-4747/14
Date: 14/05/2015

2X660 MW IB BANHARPALLI UNITS 3 & 4
LUBE OIL TRANSFER PUMPS

CORRIGENDA / ADDENDA -5

Dear Sirs,

Following query was received for the subject tender and same has been clarified as mentioned below:

S. No.	Reference / Bidder's Query	BHEL Reply
1	<p>Refer Technical Data Sheet (Page 13 of technical specification)</p> <p>Statement of the referred clause:- Capacity 6600LPH inlet/outlet size as 80NB/80NB.</p> <p>Clarification required:- In 6600LPH standard size is 40NB instead of 80NB. If you require 80NB size then there is 24900 LPH capacity. So please clarify the same.</p>	<p>With reference to vendor queries regarding the inlet/outlet size for 6600LPH . Please note 40NB size is acceptable.</p>

All bidders are requested to go through the same and quote for the subject tender accordingly.

Thanking you,
Yours faithfully,
For and on behalf of BHEL

ROHIT JUNEJA
(ENGINEER/Project Group-II-1)

ROHIT JUNEJA
ENGINEER/PG-II-1,
BHEL/PS-PEM
POWER PROJECT ENGINEERING INSTITUTE,
PLOT NO. 25, SECTOR - 16A, NOIDA (UP)
(OFF) 0120-4368848.

Regd. Office:
BHEL House
Siri Fort
New Delhi-110049