

Sl.No.	Material Code & Description	Quantity Required	Unit	Lot No.	Quantity Required
1	HW8474801613 MS WEB BRACKET SUITABLE FOR HANGING 4-POLE HANGER(FOR SHROUDED CONDUCTOR BAR)	240	No.	1	15/06/2015
2	HW8474801621 4-POLE HANGER(FOR SHROUDED CONDUCTOR BAR)	250	No.	1	15/06/2015
3	HW8474801630 ANCHOR CLAMP(FOR SHROUDED CONDUCTOR BAR)	10	No.	1	15/06/2015
4	HW8474801648 200 AMPS ALUMINIUM CONDUCTOR (W-TYPE) BAR PVC INSULATED (RED COLOUR) IN 4.5 MTR. LENGHT, HEAVY DUTY SUITABLE FOR OUTDOOR APPLICATION	60	No.	1	15/06/2015
5	HW8474801656 200 AMPS ALUMINIUM CONDUCTOR (W-TYPE) BAR PVC INSULATED (BLUE COLOUR) IN 4.5 MTR. LENGHT, HEAVY DUTY SUITABLE FOR OUTDOOR APPLICATION	60	No.	1	15/06/2015
6	HW8474801664 200 AMPS ALUMINIUM CONDUCTOR (W-TYPE) BAR PVC INSULATED (YELLOW COLOUR) IN 4.5 MTR. LENGHT, HEAVY DUTY SUITABLE FOR OUTDOOR APPLICATION	60	No.	1	15/06/2015
7	HW8474801672 200 AMPS ALUMINIUM CONDUCTOR (W-TYPE) BAR PVC INSULATED (GREEN COLOUR) IN 4.5 MTR. LENGHT, HEAVY DUTY SUITABLE FOR OUTDOOR APPLICATION	60	No.	1	15/06/2015
8	HW8474801680 BOLTED JOINT (FOR SHROUDED CONDUCTOR BAR) WITH PVC COVER	250	No.	1	15/06/2015

9	HW8474801699 CURRENT COLLECTOR BRACKET SINGLE TYPE (FOR SHROUDED COUNDUCTOR BAR)	15	No.	1	15/06/2015
10	HW8474801702 HEAVY DUTY CURRENT COLLECTOR ARM WITH 100 AMPS CURRENT COLLECTOR SHOE(COMPLETE SET FOR SHROUDED COUNDECTOR BAR)	50	No.	1	15/06/2015
11	HW8474801710 CURRENT COLLECTOR SHOE 100 AMPS (ONLY SHOE FOR SPARE PURPOSE FOR SHROUDED COUNDECTOR BAR)	10	No.	1	15/06/2015
12	HW8474801729 END POWER FEED WITH PVC COVER (FOR SHROUDED COUNDECTOR BAR)	50	No.	1	15/06/2015
13	HW8474801737 END COVER (PVC) FOR SHROUDED COUNDECTOR BAR	50	No.	1	15/06/2015
14	HW8420185124 ROTARY GEARED TYPE LIMIT SWITCH WITH SILVER CADMIUM CONTACT & THERMAL TEST CURRENT OF 40 AMP. OR MORE & RATED VOLTAGE OF 415 VAC OR MORE. GEAR RATIO=60:1.NO. OF CONTACT -S 2 NC OR MORE.ALUMINIUM DIE CAST BODY WITH IP-54 OR IP-55 PROTECTION	20	No.	1	15/06/2015
15	HW8420185132 GRAVITY TYPE/WEIGHT OPERATED FLOOR MOUNTING LIMIT SWITCH WITH SILVER CADMIUM CONTACT & THERMAL TEST CURRENT OF 10AMP. OR MORE & RATED VOLTAGE OF 500 VAC, NO. OF CONTACTS 1 NC OR MORE. ALUMINIUM DIE CAST BODY WITH IP-54 OR IP-55 PROTECTION	20	No.	1	15/06/2015

16	HW8435110192 SPRING RETURN TYPE MASTER CONT -ROLLER FOR WORKING ON 110/220 VAC CONTROL VOLTAGE WITH FOUR OR MORE STEPS ON EITHER SIDE, THERMAL TEST CURRENT OF 40A, CONTACT MATERIAL OF SILVER CAD -MIUM;IP-54 PROTECTION;MINIMUM 8 NO. OF CONTACTS;MOUNTING HORZ. WITH METALLIC BODY; CONFIRMING TO IS 13947 (PART-1)	40	No.	1	15/06/2015
17	HW8403346026 CONTROL TRANSFORMER 2000VA RATING,PRIMARY 415V/50HZ,SECON -DARY 220V,115V.BASE MOUNTING WITH MOUNTING HOLES,SCREW TERMINAL FOR INPUT/OUTPUT WITH MARKING PLATE	6	No.	1	15/06/2015
18	HW8403346034 CONTROL TRANSFORMER 3500VA RATING,PRIMARY 415V/50HZ,SECON -DARY 220V,115V.BASE TERMINAL WITH MOUNTING HOLES,SCREW TERMINAL FOR INPUT/OUTPUT WITH MARKING PLATE.	9	No.	1	15/06/2015