

**Qualifying requirement for procurement of Polyester film for  
Transformer Winding**

- 1- Polyester Film of 50 micron thickness x 900 mm width should be able to withstand electrical strength 200 kv/mm minimum using 6 dia electrode as per IS-2584.
- 2- Minimum 2 nos PO Copies of Past 2 year ( 2014-2016) of Polyester film 50 micron supplied to BHEL Jhansi , Bhopal or reputed Indian Transformer manufacturing company above 132 KV class for minimum total weight of 300 kg in a year.
- 3-Documentary verification of above for procurement of raw materials & supply of past 2 year ( 2014-2016) Polyester Film 50 micron with copy of invoice , Test Certificates .

*D.K. Anand*  
22.4.16

(D. K. ANAND)  
Sr. D.G.M. (TRE)  
B.H.E.L., Jhansi