

Annexure-C to tender 2750604E/OT-13

TECHNICAL SPECIFICATION for 5KVA OFFLINE UPS

S.No	Description	Quantity
1	Supply, Installation and testing of 5KVA offline UPS with batteries. Input supply: 230V +/-10%, Output supply: 230V +/-10% Wave: Sinusoidal, Frequency: 50Hz +/- 3 Hz. Input Protection: Overload and short circuit protection of UPS. On/off indication of UPS. Batteries: 12V sealed maintenance free batteries for 30 MIN BACK UP. Make: Rocket/ Exide/ Quanta/ Amaron or any other reputed make.	02 Set

M.V. Santosh Kumar
12/5/15

M. V. SANTOSH KUMAR
Engineer / Elect. Services / M & S
BHEL / BAP / RANIPET - 632 406.