

TENDER ENQUIRY No - PE/PG/YTP/E-5082/15, Dated 14.10.2015

PROJECT : 2 X 800 MW YERAMARUS TPP

BOQ CUM PRICE FORMAT : INSULATING MATS



S. No.	ITEM CODE	ITEM DESCRIPTION	Total quantity (Sq.Meter)	UNIT EX - WORKS PRICE (Rs)	TOTAL EX - WORKS PRICE (Rs)	ED	CST AGAINST FORM-C, E1/E2 /VAT @% (WHICHEVER IS APPLICABLE)	FREIGHT INCL SERVICE TAX @.....% OF EX WORKS PRICE	TOTAL F.O.R PRICE
				1	2	3	4	5	6=(2+3+4+5)
1	507-40006-A	CLASS- A, UPTO 3.3 KV SWITCHGEAR [CATEGORY III AS PER AMENDMENT NO. 2 MARCH 2010 OF IS 15652:2006]	1650						
2	507-40007-A	CLASS- B, ABOVE 3.3 & UPTO 11KV SWITCHGEAR [CATEGORY III AS PER AMENDMENT NO. 2 MARCH 2010 OF IS 15652:2006]	160						
TOTAL:									
NOTES:									
1	Insulating mats shall be manufactured and tested in accordance with latest version of IS:15652.								
2	Mats shall be supplied in units of 1x1 meters. The thickness of CLASS-A shall be 2mm (+/-10% Tolerance) while thickness of CLASS- B insulating mats shall be 2.5 mm (+/-10% Tolerance). Mats shall be light blue in colour.								
3	Bidder to comply the requirements of enclosed Quality plan no. PED-507-00-Q-008, R-2. Materials consumed during testing shall be to bidder's account.								
4	Insulating mats to be supplied shall be BIS marked.								
5	Type tests shall be conducted on one sample/lot of each type of insulating mats for the project. Sample shall be drawn by BHEL representative out of entire lot offered for inspection by vendor. However type testing shall be applicable for each lot of each type for the project. Type test shall be conducted at CPRI. The cost of testing of each lot shall be to bidder's account.								
6	BHEL reserves the right to witness the testing for which due notice shall be given by the Vendor .								

Handwritten signature and date: 14/10/15