

BOQ CUM PRICE SCHEDULE
LT XLPE FIRE SURVIVAL CABLE FOR 4 X 270 MW BHADRADRI TPS

S.No.	Item code	Item name	UOM	Order Quantity	Order Quantity LOT-I	Drum Length	UNIT EX-WORKS PRICE (Rs.)	TOTAL EX-WORKS PRICE (Rs.)	ED including cess @...% (for self manufactured items only) (Rs.)	CST @% Against C-form & E1/E2 or VAT @%, Whichever is applicable (Rs.)	FREIGHT CHARGES (Including Service Tax, if any) @ % of Quoted Total Ex-works (Rs.)	TOTAL FOR SITE PRICE
1	507-38009-A	1C-300- CU ARMoured	MTR	3500	2500	500						
2	507-38071-A	1C-95- CU-ARMoured	MTR	1000	1000	500						
3	507-38069-A	1C-70- CU-ARMoured	MTR	3000	2500	500						
4	507-38074-A	1C-35- CU-ARMoured	MTR	14500	10500	500						
5	507-38002-A	12C-2.5- CU-ARMoured	MTR	12000	9000	1000						
6	507-38021-A	3C-2.5- CU-ARMoured	MTR	4000	3000	1000						
7	507-38023-A	3C-95- CU-ARMoured	MTR	2000	1500	500						
TOTAL												

NOTES :

- Quantities indicated above shall be known as Order Quantities. The variation in quantities of all sizes put together shall be limited to (-) 30% to (+) 30% of the total contract value derived on the basis of the Ordered quantities .
- The bidder shall indicate the unit price of each type and size of cables listed as per the BOQ-Cum-Price Schedule enclosed with this specification. The unit prices shall apply for adjustment of variation in quantity as stipulated above.
- Lot-1 Quantity indicated above shall be cleared for manufacturing along with LOI. However, manufacturing of the cables shall be taken up by the successful bidder only after approval of technical and quality documentation. Subsequent lots shall be cleared for manufacture based on progress of engineering and site requirements.
- Overall tolerance on total dispatched quantity of each size shall be (-) 2% and (+) 0%. Cables consumed for testing and inspection shall be to bidder's account.
- Standard drum length shall be 500metres. Tolerance on individual drum length shall be ±5%. For 1C-35- CU-ARMoured & 12C-2.5- CU-ARMoured cables, one short length of not less than 200m may be accepted only in the final drum length to complete the supply. The overall tolerance limits stipulated above shall continue to apply (in case short lengths are accepted).
- In case the quantities cleared by BHEL for manufacturing (in a lot) are manufactured and offered for inspection by successful bidder in more than one batch, BHEL reserves the right to witness type testing on all batches without any price implication.
- Bidder shall indicate unit price of cables inclusive of type test charges. No separate Type Test charges are to be quoted by bidder.
- Bidder shall quote for all sizes of cables as per specification, failing which their offer shall be rejected.
- Delivery schedule of LOT-1 and subsequent lots shall be as per NIT.

Pruthi