



Bharat Heavy Electricals Limited
(A Govt. Of India Undertaking)

**Project Engineering
Management**

**OPEN TENDER ENQUIRY FOR OIL FILLED SERVICE TRANSFORMER FOR 1X 800 MW
GSECL WANAKBORI STPP UNIT 8**

Ref No. : PE/PG/WAN/E-5142/2015

Date: 22.01.2016

CORRIGENDUM/ ADDENDUM-02

Tender Enquiry no.: PE/PG/WAN/E-5142/2015 dtd. 31.12.15


DUE DATE
01 FEB 2016
10.00 AM

Bidder to consider the point as below w.r.t to technical specification of Oil Filled Service Transformer (No.PE-TS-408-302-E001):

Cl. No. 30 of Datasheet-A, Sheet 40 of 50 (*.pdf running page 70 of 89) shall be read as "Max. Current density of conductor coil of HV and LV winding shall be between 3 to 3.5 A/Sq.cm".

The bidders who have already submitted their bids for the said tender enquiry, may go through the corrigendum and in case it is felt required, may furnish revised bid with envelopes duly superscribed as "Revised bid (only to be considered)".

All bidders are requested to visit the website www.bhel.com (Tender Notifications Section) OR www.bhelpem.com, all future corrigenda/addenda, if any, for this tender shall be hosted only on above websites.


Mazhar Wahab

Sr. Engineer, PG-1-1,
BHEL PEM

Please reply to:

Mazhar Wahab, Sr. Er./ Gaurav Jain, Dy. Mgr/ PGI-I

BHEL-PEM,

Power Project Engineering Institute Building

HRD & ESI Complex Plot No. 25, Sector -16 A,

Noida-201301 (U.P.)

Tel No. 0120-4213606/4368835

Page 1 of 1