



THE INFORMATION ON THIS DOCUMENT IS THE PROPERTY OF BHARAT HEAVY ELECTRICALS LIMITED. IT MUST NOT BE USED DIRECTLY OR INDIRECTLY IN ANY WAY DETERIMENTAL TO THE INTEREST OF THE COMPANY.

1002A-43131-3  
DRAWING No.

FIRST ANGLE PROJECTION

( ALL DIMENSIONS ARE IN mm )

FORM DG 38(B)



DESIGN DATA AND PIPE CONNECTION LIST FOR STEAM TRAP ( THERMOSTATIC BIMETALLIC TYPE):-

TAG NO OF STEAM TRAP	VAR 01
	MAL23AA041
	MAL24AA041
MATERIAL OF STEAM TRAP	ASTM A 182 F91
MAX. INLET PR. (g)	67bar
MAX. INLET/OUTLET TEMP.	601°C
d1	24.3 mm
d2	33.4 mm
HYDROSTATIC TEST PR.(bar)	101(min.)
TYPE OF END CONNECTION	BUTT WELD

OUTLET PRESSURE IS ATMOSPHERIC PRESSURE.

**NOTE:-** THIS DRAWING SHALL BE READ WITH  
DOC. NO. 413137U8401.

Inventory No.	Sign & Date	Ref.Drawing No.
---------------	-------------	-----------------

GMS No./C B O M		AGREED DEPT	NAME	SIGN	DATE
GRADE OF UNTOL.DIM					
M/CG.-d/M/f AA0230208					
WELDING-A/B/d/d AA0621104					
GAS CUTTING-T3'AA0621101					
REV	DATE	ALTERED CHECKED	ANIL	ANIL	
01	18.12.15				

TYPE OF PRODUCT OR NAME OF CUSTOMER/PROJECT		BHARAT HEAVY ELECTRICALS LTD. RANIPUR, HARDWAR		DRN	P.S.SHARMA	SD	23.09.15	NO. OF VAR
DEPT	STE	SCALE	N.T.S.	CHD	ANIL	SD	23.09.15	
CODE	4011	WEIGHT (KG)	-	APPD	S.K.GUPTA	SD	23.09.15	73 74
TITLE :		STEAM TRAP		REF. TO ASSY. DRG.				
THERMOSTATIC (BIMETALLIC TYPE)				DRAWING NO.	3-13137-V2001		REV.	01
				SHEET No. 01	No. OF SHEETS 01		22 23 24	75 77

SIZE A3

## Table of content

page

1	Scope of Application .....	2
2	Type-tested Valves .....	2
3	Referenced Documents .....	2
4	Technical Data and Design.....	2
5	Inspection certificate / Declaration of Compliance in Dependence on Fluid, Pressure and Temperature .....	2
6	QA-Requirements regarding the Valve Manufacturer and his Suppliers .....	2
7	Manufacturing and Inspection Plan (MIP) .....	3
8	Condition for Manufacturing.....	3
9	Fabrication and Inspection.....	3
9.1	Steel Castings .....	3
9.2	Rolled or Forged Material.....	3
9.3	Connecting Elements .....	3
9.4	Welding.....	3
9.5	Manufacturing Inspections .....	4
10	Marking .....	4
11	Surface Protection .....	4
12	Documentation.....	5
13	Final inspection.....	5
14	Delivery and Packing.....	5
15	Guarantee.....	6
16	Spares .....	6
17	Special Tools & Tackles .....	6
18	Supplementary Requirements.....	6
19	Deviations .....	6

Continued page 2 to 6

Copying of this document, and giving it to others and the use or communication of the contents thereof, are forbidden without express authority. Offenders are liable to the payment of damages. All rights are reserved in the event of the grant of a patent or the registration of utility model or design.

## **1 Scope of Application**

This Technical Purchasing Specification covers requirements regarding steam trap. This steam trap is used to withstand water hammer. Steam trap discharge the condensate to condenser with virtually no banking up & also without loss of steam.

## **2 Type-tested Valves**

Valves with a valid type-testing certificate according to PED97/23/EC and to the corresponding VdTÜV-Merkblätter, of TRD 110 attachment 1 as well as accordingly to the registration of DIN-DVGW fulfill the requirements of this specification.

For these valves the requirements for manufacturing and testing agreed upon with the TÜVs respectively with the DVGW-federation shall be fulfilled (declaration of commitment).

## **3 Referenced Documents**

- AD2000-W 0
- AD2000-W 7
- AD2000-HP 0
- AD2000-HP 5/3
- TRD 100
- EN 287-1
- DIN EN ISO 15607
- DIN EN ISO 15609-1
- DIN EN ISO 15614-1
- EN 1418
- EN 10028
- EN 10204
- EN 10213
- EN 10222
- EN 10273
- DIN 1690-10
- EN 1559-1
- EN 1559-2
- EN 12266-1/-2
- DIN 17175,
- PED 97/23/EC

In case of differences or contradictions of the referenced documents the higher requirements shall be applied.

## **4 Technical Data and Design**

The criteria, e.g. fluid, pressure, temperature, material of the casing, etc., as well as other technical data are given in the enquiry.

## **5 Inspection certificate / Declaration of Compliance in Dependence on Fluid, Pressure and Temperature**

an Inspection Certification 3.1 according to EN 10204 must be provided for steam trap.

## **6 QA-Requirements regarding the Valve Manufacturer and his Suppliers:**

The valve manufacturer as well as his suppliers for the main components like e.g. pressure guiding components, instrumentation and control, shall have an introduced and well-working quality management system, e.g. according to EN ISO 9000 series or equivalent standard. Manufacturers of pressure guiding components shall have in addition a certificate according to AD2000-W 0 respectively TRD 100.

As far as welding will be performed on the valves, the weld shop shall be certified according to AD2000-HP 0.

## **7 Manufacturing and Inspection Plan (MIP)**

The valve manufacturer shall prepare a Manufacturing and Inspection Plan containing sufficient information on the sequence and extent of the valve inspections as well as the main raw material and shall deliver this to the purchaser for review at the latest 4 weeks after order receipt, but at least 2 weeks before starting manufacturing.

## **8 Condition for Manufacturing**

Manufacturing of the valve mentioned in point 7 shall not be started before the review for the design as well as for the MIP has been given by the purchaser. To prohibit any delay the valve manufacturer shall call for missing reviews and remind the purchaser on time.

By reviewing the MIP the purchaser does not take on any responsibility for processes or manufacturing details of the valve manufacturer or his suppliers, or for the valve itself.

## **9 Fabrication and Inspection**

### **9.1 Steel Castings**

Steel castings, e.g. valve casings, covers, etc., shall be manufactured and inspected according to EN 10213 and EN 1559 part 1 and part 2 and DIN 1690 part 10, and following minimum requirements:

- Analysis (chemical composition) per heat
- Mechanical properties per heat and heat treatment batch, for castings with an individual weight > 1000 kg testing per casting
- Amount of non-destructive testing according to DIN 1690 part 10:
  - weld ends of valves without connection pieces: Quality class A with quality grades S1 + V1
  - transition areas: quality class B with quality grades S2 + V2
  - weld ends of valves with connection pieces: Quality class B with quality grades S2 + V2
- remaining areas of the casting: quality class D with quality grades S3 + V4; additionally for castings  $\geq 500$  kg or DN  $\geq 400$  mm each casting 100% volume inspection shall be performed.

### **9.2 Rolled or Forged Material**

Rolled or forged material, e.g. connection piece, shall be manufactured and inspected according to the corresponding material standard, e.g. EN 10028, EN 10088, EN 10222, EN 10273, DIN EN 10216-2 and DIN 17440, etc. and following supplements:

- Analysis (chemical composition) per heat
- Mechanical properties per heat and heat treatment batch

### **9.3 Connecting Elements:**

Connecting elements shall be manufactured and tested according to AD2000-W 7. As far as there is a requirement for a test certificate for grade properties, this shall be an inspection certificate 3.1 according to EN 10204.

### **9.4 Welding**

As far as welding will be performed on the valves (also in case of fabrication welding on castings):

- Welding shall be performed only by welders tested in line with EN 287 or mechanized welds by welding operators tested in line with EN 1418
- Corresponding welding procedure specifications and procedure approval records according to
  - DIN EN ISO 15607
  - DIN EN ISO 15609-1
  - DIN EN ISO 15614-1 shall be available.
- Fabrication welds on castings shall be inspected according to DIN 1690.
- Fabrication welds having a length  $\geq 150$  mm or a depth  $\geq 40\%$  of the wall thickness or a depth  $\geq 25$  mm shall be recorded.
- Design welds shall be inspected according to AD2000-HP 5/3. In case of serial production manufacturer-specific inspection concepts may be applied with written agreement of the purchaser.
- If cast steel parts are subjected to heat treatment in the course of valve manufacture, all parts

heated shall subsequently be subjected to a 100% surface crack examination.

## 9.5 Manufacturing Inspections

Manufacturing inspections shall be performed according to PED 97/23/EC / EN 12266. The PED 97/23/EC as a superior legislation shall be observed and applied. These are especially:

- a) Pressure test
  - Test P10 according to EN 12266 part 1
- b) Leak test
  - Test P11 + P12, leakage class B according to EN 12266 part 1
- c) Functional test
  - Test F20 according to EN12266 part 2
- d) Verification of dimensions
  - Main dimensions
  - connecting dimensions

All tolerance ranges which are important for the function shall be recorded. as

  - Stem diameter
  - Diameters of guides and fits

## 10 Marking

Valves shall be marked as follows:

- The name and address or other means of identification of the manufacturer and, where appropriate, of his authorized representative established within the Community
- Nominal diameter
- Nominal pressure class
- Casing material
- Flow direction arrow
- Identification-no. (also commission-no.)
- The year of manufacture
- Identification of the pressure equipment according to its nature, such as type, series or batch identification and serial number
- Essential maximum/minimum allowable limits
- CE marking

Valves with a total weight > 1000 kg shall be marked additionally with a permanent information of the weight on the valve or on an safe name- plate.

The provisional KKS-Labels which are fabricated and properly sized are to be made of plastic or similar unbreakable material and attached to the component by wire. The lettering on the labels should include the KKS classification in back, permanent ink.

Marking of the materials for all pressure loaded casing components shall survive during all manufacturing processes according to AD2000-HP 0.

## 11 Surface Protection

Surface coating of non-stainless steel valves shall be applied as follows

<u>Paint (Coat)</u>	<u>Paint Type</u>	<u>No. of coat</u>	<u>DFT*</u>
Primer Paint	: Epoxy base Zinc rich primer paint	1 Coat	35
Intermediate Paint	: Epoxy TiO2 Pigmented Polyamide Cured Paint	1 Coat	70
Finish (Final) Paint	: Aliphatic Acrylic 2 Pack Polyurethane Finish paint	2 Coats	75

\*DFT – Dry Film Thickness (final) in microns

- Shade as per RAL – Grey 9002

## 12 Documentation

All the documentation for the delivered valve shall remain with the valve manufacturer and shall be stored

for at least 10 years. This documentation shall be labelled such as to ensure traceability and allocation to the corresponding valve and shall be marked as belonging to BHEL. The valve manufacturer shall check the documentation with respect to completeness and correctness before shipping the valve. The valve manufacturer shall certify this at the time of the delivery. It is the obligation of the valve manufacturer to hand over a copy of the total documentation to the purchaser on request and free-of-charge.

BHEL expects a documentation of the module/parts including all instructions which are necessary for service, installation and maintenance. Amendments will be requested separately.

In accordance to the Machinery Directive (98/37/EC) and Pressure Equipment Directive (97/23/EC) the following records and logs shall be provided to the purchaser in any case:

- manufactures declaration
- Declaration of conformity
- Material certificates
- Pressure test
- Non-destructive tests

The documentation - also that of the sub suppliers - shall be written in English language and shall contain at least:

- Test certificates of the prematerial (at least inspection certificate 3.1B according to EN 10204)
- Records of all inspections performed by the valve manufacturer or his sub suppliers during manufacturing:
  - Non-destructive inspections of e.g. weld areas or welds
  - Verification of dimensions
  - Pressure and leak tests
  - Functional tests
- Heat treatments performed
- The European Union guidelines and standards which are valid and can be used for the area of application (e.g. PED 97/23/EG, Low-Voltage Guideline 73/23/EEG, etc..) are to be designated in the declaration of conformity according to the remarks and applied quality modules, and shall include all relevant data (see e.g. appendix VII of Guideline 97/23/EG). Risk disclosure and danger analyses in accordance with EN 1050 are to be handed over to BHEL if necessary.
- If materials without European material approval are drawn on for the order (order papers/designs) (e.g. ANSI/ASME materials) appropriate substitute certificates from a designated authority shall be procured and documented accordingly. If the order pertains to a component of a total design group, then all certificates and certification of the component of the highest category of the total design group shall be made available.

### **13 Final inspection**

The purchaser reserves the right to perform final inspections on his ordered parts in the shop of the valve manufacturer, as well as in the shop of his sub suppliers

### **14 Delivery and Packing**

Details regarding delivery are given in the order, however at least following details shall be given together with the delivered parts:

Actualization of standards and instructions

- Purchaser
- Order-no. / project
- Manufacturer commission-no. / works-no.
- Specification
- Number of pieces
- Type / item
- Nominal diameter [DN]
- Maximum allowable pressure [PS]
- Maximum allowable temperature [TS]
- Fluid
- Manufacturer drawing-no.
- Identification-no. of the valve
- Piece weight

Together with the delivery of the valve the valve manufacturer shall hand over a certificate 2.1 according to EN 10204 in English, which confirms that the delivered valve fulfills the requirements given in the order and in this specification. Furthermore the valve manufacturer shall confirm that only materials as listed in the design bill of material have been used and that the documentation is available in his shop in line with Item 12 above and that he has checked the documentation carefully.

Packing of the valve shall be as follows:

- The valve shall be packed and locked that way, that in general case any damage will be prohibited.
- All openings shall be plugged.
- Detail parts respectively components shall be packed individually, however assignment shall be ensured.
- As far as necessary accessory devices for transportation purposes shall be attached to the valve and/or to the packing, e.g. lifting eyes and lifting signs.
- Bearing areas shall be marked, if necessary.

#### **15 Guarantee**

The supplier shall guarantee trouble free operation of the equipment for a period of 2 years after installation and commissioning or a period of 3 years from the date of dispatch of equipment whichever is earlier.

If during erection/commissioning and operation at site, any defect in any component is detected, purchaser's / owner's site representative shall prepare the assessment report and a copy of the same shall be forwarded to the supplier. The supplier shall replace / rectify the concerned items free of charge. The supplier, if he so desires, may depute his representative to site at his own cost otherwise the report of purchaser's / owner's site representative shall be binding on the supplier.

#### **16 Spares**

The offer of valves shall include the requirement of spares to be made available at the time of erection & commissioning. A separate offer of spares to be required for 3 to 5 years of operation shall also be separately enclosed along with main offer.

#### **17 Special tools & tackles**

Any special tools & tackles, required for erection, commissioning and maintenance of valves shall be included in main offer per set of valves.

#### **18 Supplementary Requirements**

The valve manufacturer shall send following documents in triplicate written in English language to the purchaser's department for records. Documents listed under a) and c) shall be delivered with the order acknowledgement:

- a) Part drawing showing the function of the valve and the design bill of material
- b) Operating and maintenance instruction
- c) Spare part list

#### **19 Deviations**

Any deviation from this purchasing specification has to be reported to the purchaser immediately.

Any deviation is accepted only if this has been approved or accepted by the purchaser in writing.

In case of any deviation from the specified properties, also if the proof by testing is not required, the purchaser has the right to reject the material.