

GLOBAL TENDER ENQUIRY FOR C.W. TREATMENT PLANT OF 1X800 MW
KOTHAGUDAM TPP

Ref No. : PE/PG/KOT/E-4775/2015

Date: 20.06.15

CORRIGENDUM/ ADDENDUM-3

Subject: Considering change in Part-I Extension & Technical Specification

Our Ref : TENDER ENQUIRY NO: PE/PG/KOT/E-4775/2015, DTD-17.04.2015
Package : C.W. TREATMENT PLANT
Project : 1X800 MW KOTHAGUDAM TPP

This is in reference to the above Tender Enquiry No: E-4775/2015, DTD-17.04.2015, please note the following:

1. Due date for submission of tender is extended from existing date 20/06/2015, 02:00 PM (IST) to **04/07/2015, 02:00 PM (IST)**. Part-I bids shall be opened on **04/07/2015, 03:00 PM (IST)**.
2. Following changes have been made in the technical specification and are enclosed herewith:
 - AMENDMENT#2
 - ANNEXURE-1 (DATA SHEET-A (Rev-01))
 - ANNEXURE-2 (P&ID (Rev-02))
 - ANNEXURE-3 (SECTION-D (Rev-01))

Thanking You,

With Regards,
For & on behalf of BHEL



Kamal Kishore
Sr. Engineer./PG-II-2
BHEL-PEM, NOIDA
M.No. 09971962269/0120-4368508

Please reply to:
Kamal Kishore (Sr. Engineer./PG-II-2)
Power Project Engineering Institute Building
HRD & ESI Complex Plot No. 25, Sector -16 A,
BHEL-PEM, Noida-201301 (U.P.)
Tel No. 0120-4368508



**AMENDMENT ON TECHNICAL SPECIFICATION FOR CW TREATMENT PLANT
1X800 MW TSGENCO KOTHAGUDEM TPS, STAGE –VII, PALONCHA.**

SPECIFICATION NO.: PE-TS-410-156-A001

AMENDMENT NO # 2

REV. NO. 00

DATE: 15/05/2015

Page 1 of 1

The following modifications with respect to Technical Specification for **CW TREATMENT PLANT** BHEL's Technical specification no **PE-TS-410-156-A001** shall apply. Bidder to note that existing clauses/details as appearing in the specification stands deleted and clauses/details as mentioned in "Modified to or Read as" column shall be applicable and complied by the bidder.

MODIFIED CLAUSES/PAGE NUMBERS.

SI no.	Vol. No.	Section/ Description	Clause no	Page no	Existing clause/details	Modified to or Read as
1.	IIB	SECTION- C1	6-e	10 OF 191	Lime pit neutralized effluent from N-Pit Dewatering pump to CW Forebay (consider 200 meter piping distance).	Lime pit neutralized effluent from N-Pit Dewatering pump to Nearest Plant Drain (consider 200 meter piping distance).
2.	IIB	SECTION- C1	2.5.3	18 OF 191	Furnace Temperature Probe: Thermocouple 1 no.	Clause deleted.
3.	IIB	SECTION- C1	DATA SHEET-A	42 OF 191	DATA SHEET-A (REV-00).	Shall be replaced by DATA SHEET-A (REV-01), Refer ANNEXURE-1.
4.	IIB	SECTION- C1	P&ID	47 OF 191	P&ID (REV-01).	Shall be replaced by P&ID (REV-02), Refer ANNEXURE-2.
5.	IIB	SECTION- D1	1, 2 & 3	66 TO 67 OF 191	Rev-00, Sheet no-66 to 67 of 191.	Two sheets replaced by Rev-01, Refer ANNEXURE-3.