



भारत हेवी इलेक्ट्रिकल्स लिमिटेड

BHARAT HEAVY ELECTRICALS LIMITED

निविदा सूचना/Tender Notice

निविदा संख्या /Tender No: 20150203/TE/A/39

दिनांक/ Date:25/03/2016

Sealed Tenders are invited in Two Part Bid System for supply , Installation & Testing of Earthing Electrode 80x3000 mm.

- **Submission of Tender:** Till 14:30 hrs **15/04/2016**
- **Opening of Part –I (Techno commercial) bid :** At 15:00 Hrs. on **15/04/2016**
- Techno-Commercial bid (Part-I) & Price Bids (Part-II) should be submitted in separate envelopes. These two envelopes should be submitted in a common sealed envelope. Techno-Commercial Bid shall contain detailed Technical Specification, taxes & duties, payment terms, delivery period, Validity of offer, Un priced bid etc. The confirmation to the terms & conditions must be submitted along with Techno-Commercial bid. **Please mention Tender No., Type of bid (i.e. Part-I or Part-II), Due date of opening on the envelop.**
- **Duly completed offers should reach following address on or before due date and time to Office of AGM (MM) CSU&FP, BHEL,Industrial Area Jagdishpur,Dist. Amethi-227817, UP.**
- **Bids can be deposited in the Tender Box, kept in the following location in BHEL-CSU &FP:**
Administrative Building
Fabrication Plant
Bharat Heavy Electricals Ltd
Industrial Area Jagdishpur
Dist. Amethi
PIN-227817, UP

1. Pre-Qualifying Requirement (PQR) condition:

Sr. No.	PQR Condition	Vendor remarks
1	Vendor should have supplied similar/ same item to BHEL/PSU/reputed companies in past 02 (two) Years. A copy of purchase order is required to be submitted as a documentary proof.	
2	Audited annual report (balance sheet and Profit & Loss Account) & ITR of last 3 years (i.e. FY 12-13,13-14 & 14-15)	
3	For Manufacturer: Capabilities with respect to personnel, equipment and manufacturing Facilities.	
4	For Dealer: 1) Authorization letter from OEM is mandatory. 2) In case of foreign principal: An agency agreement deed copy is Required.	

2. Vendor to submit documents including Tender Document with offer after signed & stamped on each page. Non compliance of signed & stamped of documents are liable to be rejected the offer.
3. Technical Specification is attached at Annexure-A.
4. Item description and scope of supply/work:

Sl. No.	Description of item	Unit	Qty
1	FU8345010024 SUPPLY,INSTALLATION & TESTING OF MAINTENANCE FREE G.I. EARTHING ELECTRODE (PIPE IN PIPE TECHNOLOGY),80 MM DIA., LENGTH 3000 MM, TERMINAL SIZE: 50 X 6 MM. WITH EARTH ENHANCEMENT MATERIAL -50 KG	Nos.	20

5. Terms and conditions:

Sl. No	Terms	Description	Supplier Confirmation
1	Techno commercial Compliance Statement	Vendor to submit Techno commercial Compliance Statement (Refer Annexure -3 of Enclosure-1 of TE) with offer	
2	Offer Validity	90 days from the date of opening of Part-I offer (Techno-commercial)	
3	Price	The prices to be firm and inclusive of all taxes and duties, freight and insurance etc. Supplier will submit Billing breakup along with the offer. Insurance will be in supplier scope.	
4	Evaluation	On the basis of total cost to BHEL,FP-Jagdishpur inclusive of loading, if any.	
5	Delivery	For Supply: Within 4 (Four) Weeks from the date of PO. Earlier delivery is acceptable to BHEL. For Installation and Testing: Within 1 (One) Week from date of Intimation by BHEL to start the work.	
6	Delivery Terms	FOR, BHEL (FP) Stores, Jagdishpur.	

7	Payment Term	100 % Payment shall be made within 45 days from the date of receipt and acceptance of material/system at BHEL-FP against submission of Installation certificate issued by BHEL.	
8	Guarantee Certificate	Materials to be supplied in good quality and free from defects. More over all the Item/materials Shall carry a Guarantee for a period 12 months from the date of acceptance at BHEL -FP Store. Defects if any found in this period shall be indicted to the supplier and the same to be replaced by supplier free of cost (including to and fro transportation) within 1 month.	
9	Test Certificate	Required	
10	Excise duty	ED payable shall be restricted to the prevailing rate of the basic price.	
11	VAT	VAT is payable for intra state dispatches	
12	CST	CST is not payable by BHEL, However C-form shall be provided by BHEL. In case BHEL is not in a position to issue C form the differential CST i.e. the diff in CST for supplies with and without C-form is only payable	
13	Octroi /Entry tax	Applicable taxes to be indicated in offer and is payable extra only on submission of documentary proof	
14	Service Tax	To be paid by BHEL , if applicable.	
15	Liquidated Damages	<p>For Supply: The delivery of Equipment shall be made within the time prescribed .Failure to dispatch the equipment in time as per delivery specified would make the vendor liable to an un-conditional penalty at the rate of half (1/2) percentage of the supply value for delay of each week in supply subject to a maximum of ten percentage (10%) of Supply value.</p> <p>For Installation & Testing: Installation & Testing of equipment shall be made within the time prescribed. Failure to complete the work as per the time specified would make the vendor liable to an un-conditional penalty at the rate of half (1/2) percentage of the Installation & Testing value for delay of each week in Installation &</p>	

		Testing subject to a maximum of ten percentage (10%) of Installation & Testing value.	
16	Pre Dispatch Inspection	If required BHEL will have pre dispatch inspection.	
17	Rejection	The supplier shall arrange replacement/ repair within one month from the date of rejection intimation upon failure on supplier's part to comply. BHEL will take whatever appropriate action they may think fit in addition to repair/return of rejected material at the cost and risk of the supplier.	
18	Risk purchase	In case of delays in supply of materials/defective materials not fulfilment of any other terms and conditions given in the purchase order, the purchase may cancel the full or part thereof, and may also make purchase of such material from elsewhere/alternate source at the risk and cost of supplier.	
19	Arbitration	Any dispute arising out of this contract shall be referred to the sole arbitration of GM-CSU & FP-BHEL, Jagdishpur. Its award shall be final and binding on the parties. The venue of arbitration in all cases shall be at Administrative building, BHEL-CSU & FP, Jagdishpur.	
20	Jurisdiction	In case of any suit or other legal proceedings arising under or relating to the contract, the Jurisdiction of Sultanpur (UP) district court shall apply	
21	Consignee	The Stores Officer, Fabrication Plant, BHEL, IA Jagdishpur, Distt.- Amethi (UP) 227817	
22	Billing Address	The Purchase officer, CSU & FP, BHEL, IA Jagdishpur, Distt-Amethi (UP),227817	

6. Special Instruction:

- For all the new vendors who are not registered with BHEL (CSU & FP) as well as vendors registered with BHEL (CSU & FP) who have not submitted Supplier Registration Form (SRF) earlier, duly filled up "Supplier Registration Form" through <http://supplier.bhel.in> along-with all the supporting documents. Please confirm in your offer that SRF has been filled. However please note that if in any case SRF has not been filled within 15 days of tender opening, your offer may liable to be ignored. Kindly inform us after filling the SRF.

2. In case vendors do not accept commercial terms of NIT proper loading shall be done during the evaluation.
3. Duly filled & signed with company seal on all documents to be submitted along with offer.
4. Offers not meeting our requirement because any kind of deviations in technical or commercial terms are liable to be rejected by BHEL at its discretion.
5. Please submit point wise compliance to our specification, terms & conditions .Otherwise it will be presumed that you are accepting BHEL's Terms & condition.
6. BHEL, CSU & FP- Jagdishpur reserve the right to increase or decrease the quantity of item mentioned in Tender enquiry.
7. Please quote price in figures & words both. In case the prices quoted in words and figures are different, the value indicated in words will be considered for evaluation and establishing L1 status.
8. The offers of the bidders who are on the banned list and also the offers of bidders, who engage the services of the banned firms, shall be rejected. The list of firms is available on web site www.bhel.com

7. Reverse Auction (RA):

BHEL reserves the right to go for Reverse Auction (RA) instead of opening the sealed envelope price bid, submitted by the bidder. This will be decided after techno-commercial evaluation. All bidders to give their acceptance for participation in RA. Non-acceptance to participate in RA may result in non-consideration of their bids, in case BHEL decides to go for RA. In case BHEL decides to go for Reverse Auction, only those bidders who have given their acceptance to participate in RA will be allowed to participate in the Reverse Auction. Those bidders who have given their acceptance to participate in Reverse Auction will have to necessarily submit "online sealed bid" in the Reverse Auction. Non-submission of "online sealed bid" by the bidder will be considered as tampering of the tender process and will invite action by BHEL as per extant guidelines in vogue.

8. MSE Suppliers can avail the intended benefits as per Annexure-1 of Enclosure-1.
9. Tender's other details are attached at Enclosure-1.
10. Contact person details:

Shri Arvind Kumar Yadav
Engineer –MM
Phone: 05361 224131
Mob: 09935664480/07571888808
E-mail: aky@bhelcsufp.in



(Arvind Kumar Yadav)
Engineer-MM

Sl. No.	Specification	Confirmation by vendor	Remarks
1	Name of Manufacture		
A	EARTHING ELECTRODE ASSEMBLY		
1	Inner & Outer pipes of the earth electrodes are marked with ISI mark as per IS:1239		
2	Dimensions of the outer pipe (Dia. X Length X Thickness in mm)		
3	Dimensions of the inner pipe (Dia. X Length X Thickness in mm)		
4	The level of hot hot dip galvanizing of M.S. Pipes in microns		
5	Terminal size (50x6x100mm)		
6	Ohmic value (1- 3 ohm)		
B	B-EARTH ENHANCEMENT MATERIAL		
1	Brand Name of the earth enhancement material (if any)		
2	Contents of the earth enhancement material		
3	Resistivity of the earth enhancement material		
4	pH value of the earth enhancement material		
5	Moisture retaining capacity at 105 degree C		
6	Granular size of the material		
7	Water solubility (in percentage)		
8	Thermal stability of the material (Temperature range)		
C	Electrode & Installation confirming to IS -3043		
D	Installation & ohmic testing at site (BHEL-FP, Jagdishpur) by vendor		

Accepted
15/3/16