

PRE-QUALIFICATION CRITERIA

1. Bidder shall have proven design for Form IVB Type 7 as per IEC standard cable termination requirement Draw out LV Switchboards. BHEL/NTPC will assess the design. If assessment team is not convinced offer is liable for rejection.
2. Bidder/ Sub-vendor should have manufactured and supplied at least a total of four Hundred & fifty (450) nos. draw out type Air Circuit Breaker Panels and / or draw out MCC Panels complete in all respects with fault rating of at least 50kA for 1 sec. and 105kA (peak) **under a single order** and these panels should have been in successful operation for a period of not less than two (2) years prior to the date of Techno-Commercial bid opening.
3. Bidder/ Sub-vendor should have manufactured and supplied at least one hundred & Fifty (150) nos. of draw out Circuit Breaker Panels with Air Circuit Breakers having fault Rating of at least 50kA for 1 second, 105kA MAKING and 50kA BREAKING, which Should have been in successful operation for a period of not less than two (2) years prior to the date of Techno-Commercial bid opening.
4. Each Single Front Panel shall be counted as one (1) Panel, Double Front Panel as one (1) Panel and Air Circuit Breaker Panel as one (1) Vertical Panel.
5. BHEL EPD/NTPC may visit the facilities for assessment, irrespective of documents submitted, if the assessment team found that vendor design is not satisfied offer will be rejected.
6. Vendor shall have a minimum of pending orders worth Rs.5Crores to Rs.10Crores. As on date of bid opening. The copies of pending orders shall be furnished along with technical Bid. BHEL may re-confirm/verify with the purchasers of concerned Purchase Orders.
7. Vendor shall have a minimum capability of production per month for 15 ACB verticals and 75 MCC DFDO verticals. If BHEL EPD/NTPC assessment team found same is not been verified/satisfied during visit offer will be rejected technically.
8. Vendor shall be submit last three years financial balance sheet duly certified by chartered accountant for verification and assessment by BHEL. BHEL without any reason has right to reject vendor offer after assessment of financial capability of vendor.
9. If vendor is not submitting required documents or not replying to BHEL Queries after technical bid opening with in 4days from the date of request from BHEL, their offer will be rejected under "non-responsive category". All documents will be acceptable in soft copy also.
10. Bidder shall duly fill all attached formats and submit along with technical offer.
11. The technically qualified vendors confirming all the above Qualification criteria shall be referred to NTPC for final approval. Only NTPC accepted vendor's bids shall be considered for further process in tender.