

PRE-QUALIFICATION REQUIREMENTS

Following are the pre-qualification requirements (PQR) for supply of Thermal Insulation of TIP.

Sl No	Pre-Qualification Requirements	Vendor's confirmation Indicating page no. where documents are placed
1.	Vendor should have an experience in design, supply and application of Thermal Insulation of hot pipes (as per IS 14164:2008 or equivalent) of at least two complete SG/TG sets of 200MW or above projects and satisfying the criteria given below: a. Min. pipe size covered= Nb400 b. Temperature of operating fluid= 350°C and above.	
2.	Vendor to furnish following documents: a. Purchase order copy in support of sl. no. 1 above, along with all technical annexures like BOM, site data conditions, sample calculations used for calculating insulation thicknesses & K-values at different mean temperature (100, 150, 200, 250 and 300°C) This purchase order should not be older than 5 years as on the date of bid opening.	
3.	Vendor to confirm compliance to BHEL quality plan no. QA/BE/QP/316/SQP Rev. 00 (enclosed).	
4.	Vendor to confirm Inspection by BHEL nominated inspection agency SGS as per quality plan no. QA/BE/QP/316/SQP Rev. 00 (enclosed).	

Notes:

1. BHEL would consider the offers and open the price bids of only those bidders, who fulfill the Pre-Qualification requirements (PQRs).