

PRE QUALIFICATION CRITERIA FOR LT CABLES

INDENT NO: IND: 16: PS: 0005: FEX: 1 & 4 DATED: 29.04.2016

BIDDER SHALL MEET ALL THE FOLLOWING REQUIREMENTS

- **MINIMUM 500 METERS OF 1.1 KV LT POWER CABLE OF SIZE 185 SQMM TO 16 SQMM 4CORE / 3.5CORE ALUMINIUM ARMoured PVC INSULATED CABLES AS PER CUSTOMER TECHNICAL SPECIFICATION CONFORMING TO IS1554 SHOULD HAVE BEEN MANUFACTURED AND SUPPLIED BY OEM OR SUPPLIED BY THEIR APPROVED AGENCIES AND SUPPLIED ANY WHERE IN INDIA DURING THE LAST 5 YEARS.**

- **TEST REPORT AND WARRENTY CERTIFICATE FOR THE ABOVE MENTIONED CABLES SHOULD BE FURNISHED BY THE BIDDER.**


Engineer/FEX