



TITLE

2X660 ENNORE SEZ STPP
D/G EOT CRANE FOR CWPH (70/18T)
(50T TO 150T CAPACITY)
PRE-BID CLARIFICATION SCHEDULE

SPECIFICATION NO. PE-TS-412-501-A002

VOLUME: III

REV 00

August 2015

Page 1 of 1

PRE-BID CLARIFICATION SCHEDULE

S. NO.	SECTION/CLAUSE/PAGE NO.	STATEMENT OF THE REFERRED CLAUSE	CLARIFICATION REQUIRED	BHEL REPLY
1.0	CCD (Crane Clearance Diagram)	Wheel load diagram in CCD.	Wheel load in wheel load diagram (i.e.- 36T) seems to be lower side, Whereas calculated wheel load is 42T (Approx.). Hence please clarify.	Wheel load (without impact) per wheel given in LT wheel load diagram of CCD shall be considered as 42.0T
2.0	Data Sheet, Crane Clearance Diagram & price format	In the technical data sheet A the crane capacity is mentioned as 60/18 T, in clearance diagram also, it is mentioned as 60/18 T whereas in price schedule it is mentioned as 70/18 T.	Please clarify the correct capacity of the crane enable us to quote for the same.	Bidders are requested to refer to page no. 3 & 7 of 212 of technical specification indicating amendment w.r.t. crane capacity & hook approaches. Crane capacity required under said enquiry shall be 70/18T.

The bidders hereby clarifies that above mentioned are the only clarifications required on the technical specification for the subject package.