



TITLE
**4 X 270 MW BHADRADRI STPP
 VENTILATION SYSTEM**
 PRE-BID CLARIFICATION SCHEDULE

SPECIFICATION NO. PE-TS-411-554-A001
 VOLUME: III
 REV 00
 March 2015
 Page 1 of 1

PRE-BID CLARIFICATION SCHEDULE

S.NO.	SECTION/CLAUSE/PAGE NO	STATEMENT OF THE REFERRED CLAUSE	CLARIFICATION REQUIRED
1	Specific Technical Requirements under C & I, Sl.No.8, Page 167 of 377	Whether Open and Close Limit Switch are applicable for all manual Valves at Pump discharge since there are two specific Manually operated valves like Check Valves & Globe Valves are provided in addition to Motorised Butterfly Valves (as per revised P & I diagram) .The Limit Switch cannot be provided in these type of valves. Pl.Clarity.	Limit switches are not required in all valves. The Limit switches are required wherever some interlock is required in the operation. Bidder may suitably take care of the same.
2	Specific Technical Requirements under C & I, Sl.No.4, Page 167 of 377	Whether this Local Control Panel to be considered (if required at all) Relay Based or PLC based - Please clarify	Common PLC based control system is there for AC & Ventilation system and scope of supply of PLC is in AC Vendor scope. However, all interlock instrument as per technical specification shall be in ventilation bidders scope. Further, all the applicable IO of Ventilation system shall be provided to AC vendor by the bidders so that same can be inbuilt in PLC system for control and interlock as per specification.

The bidder hereby clarifies that above mentioned are the only clarifications required on the technical specification subject package



Company Seal

Signature

Name M.B.Chakraborty

Designation

Company : C.DOCTOR & CO (PVT) LTD.

Date 10.06.15