

Corrigendum against tender enquiry no. 7635/S/6240/15/4834A2

1.2 After installation,

** Display of Real time Pressure and Instantaneous/cumulative Flow at remote location within 10 mtrs. of the location where flow meters are installed.

** Display of Real Time/ historical Data of Flow and Pressure of Compressed Air on Flow Computer/Data Logger at Central Monitoring Place.

** Display of Real Time/ historical Data of Flow and Pressure of Compressed Air on PCs of authorized users using BHEL intranet.

** **Minimum authorised users shall be 5.**


10.08.16
Purchase Executive