

7

BHARAT HEAVY ELECTRICALS LIMITED, JHANSI
SPECIFICATION FOR 11KV LOAD BREAK SWITCH

Specification No	9331
Item No	SP/ELEC/9331
Quantity	02 No




- 1 VENDOR must submit complete information against clause No. 5 (Qualifying condition). The offer meeting this clause would only be processed.
- 2 The " offered" Column and where applicable, the " Deviations" Column of this format shall be filled in by the Vender and submitted along with the offer. Technical details also submitted with the offer. Inadequate / incomplete, ambiguous, or unsustainable information against any of the clauses of the specification / requirements shall be treated as non - compliance.
- 3 The offer and all documents enclosed with offer should be in English language only.

SCOPE :
DESIGN, MANUFACTURING, TESTING, PACKING AND SUPPLY OF LOAD BREAK SWITCH--- 11 KV , 03 POLE, 630 AMP., MANUALLY OPERATED WITH TRIP MECHANISM & Aux. contact

S.NO	DESCRIPTION FOR BHEL REQUIREMENT	SPECIFIED / TO BE CONFIRMED	OFFERED	DEVIATIONS
1.0	This specification governs the quality requirements of design, manufacturing, testing, packing and supply for of LOAD BREAK SWITCH -- 11 KV 630 AMP. THREE POLE , INDOOR,MANUALLY OPERATED WITH TRIP MECHANISM & Aux. contact	VENDER TO CONFIRM		
1.2	Quantity	02 NO.		
1.3	Location	IMPULS TEST		
2.0	REQUIREMENT			
2.1	11 KV 630 AMP. THREE POLE , INDOOR,MANUALLY OPERATED WITH TRIP MECHANISM & Aux. contact	VENDER TO CONFIRM		
2.2	switch shall be mounted vertically	VENDER TO CONFIRM		
2.3	8 No +8 NC Auxiliary contact	VENDER TO CONFIRM		
2.4	Mechanical ON/OFF Indication	VENDER TO CONFIRM		
2.5	G.A. Drawing	VENDER TO SUBMIT		
2.6	Technical litrature with dimention	VENDER TO SUBMIT		
2.7	Model of offered load break switch	VENDER TO SPECIFY		
2.8	Manufacturer of offered load break switch	VENDER TO SPECIFY		
3.0	Accessaries			
	A. Operating handle	VENDER TO CONFIRM		
4.0	GENERAL			
4.1	All the drawing including outline general arrangement shall be submitted to us in Triplicate for approval before commencement of work.	VENDER TO SUBMIT		
4.2	3 sets of operation/maintenance manual shall be supplied.	VENDER TO CONFIRM		
4.3	At least 15 day advance information should be given to enable us to depute our representative for inspection / testing. Dispatch shall be affected only after inspection	VENDER TO CONFIRM		
4.4	Aluminum anodized name plate for outgoing circuit shall be screwed in front and back of the panel.	VENDER TO CONFIRM		
4.5	The equipment shall be guaranteed in respect of material construction and operation against any manufacturing and design defect for a period of 24 months after supply.	VENDER TO CONFIRM		
4.6	Offer shall be sent with complete literature and necessary details.	VENDER TO SUBMIT		

JOU

6

DESIGN, MANUFACTURING, TESTING, PACKING AND SUPPLY OF LOAD BREAK SWITCH--- 11 KV , 03 POLE, 630 AMP., MANUALLY OPERATED WITH TRIP MECHANISM & Aux. contact				
S.NO	DESCRIPTION FOR BHEL REQUIREMENT	SPECIFIED / TO BE CONFIRMED	OFFERED	DEVIATIONS
5.0	QUALIFYING CONDITION			
5.1	Only those venders, who are in the line of LOAD BREAK SWITCH manufacturing or authorized agents of LOAD BREAK SWITCH manufacturer(authorization certificate required), shall quote.	VENDER TO SUBMIT		
A	Details of company profile, manufacturing facilities available at manufacturer works	VENDER TO SUBMIT		
6.0	BHEL reserves the right to verify information submitted by vender. In case the information is found to be false/ incorrect, the offer shall be rejected	VENDER TO CONFIRM		
				
				
 19/11/16				
Y.K. Dhingra Dy. Mgr.(WE&S)		Inder mathur D.G.M (WE&S)		S.J.Chakraborty A.G.M (WE&S)