


PSGSG109	<b>SPECIFICATIONS FOR Pull Rod Assy.</b>		Drg.No.	RD DG 4 35 0617 0230																																								
			Date	03.01.2015																																								
			Product	GSM-400																																								
1.0	<b>APPLICATION:</b>  Tubular insulator with metal flanges is a part of a high voltage, heavy duty switchgear. The component is intended for a 420 kV AC, 50 Hz System.																																											
2.0	<b>SPECIFICATION:</b>																																											
	2.1	<b><u>TUBE MATERIAL</u></b>																																										
	2.1.1	The POLYESTER lining used for tube shall have following properties:																																										
		<table border="1"> <thead> <tr> <th>#</th> <th>Property</th> <th>Unit</th> <th>Value</th> </tr> </thead> <tbody> <tr> <td>1</td> <td>Density</td> <td>g/ccm</td> <td>~1.3</td> </tr> <tr> <td>2</td> <td>Tensile strength</td> <td>MPa</td> <td>~1000</td> </tr> <tr> <td>3</td> <td>Impulse dielectric Strength</td> <td>kV/mm</td> <td>≥ 16</td> </tr> <tr> <td>4</td> <td>Relative permittivity</td> <td>-</td> <td>~3.4</td> </tr> <tr> <td>5</td> <td>Dielectric loss factor</td> <td>%</td> <td>~0.4</td> </tr> <tr> <td>6</td> <td>SHRINKAGE15 HR160 °C</td> <td>%</td> <td>≤ 2</td> </tr> <tr> <td>7</td> <td>SHRINKAGE</td> <td>%</td> <td>&lt; 0.5</td> </tr> <tr> <td>8</td> <td>Water Absorption</td> <td>%</td> <td>&lt; 0.5</td> </tr> <tr> <td>9</td> <td>Water Absorption @ 100°C</td> <td>%</td> <td>&lt; 0.5</td> </tr> </tbody> </table>			#	Property	Unit	Value	1	Density	g/ccm	~1.3	2	Tensile strength	MPa	~1000	3	Impulse dielectric Strength	kV/mm	≥ 16	4	Relative permittivity	-	~3.4	5	Dielectric loss factor	%	~0.4	6	SHRINKAGE15 HR160 °C	%	≤ 2	7	SHRINKAGE	%	< 0.5	8	Water Absorption	%	< 0.5	9	Water Absorption @ 100°C	%	< 0.5
#	Property	Unit	Value																																									
1	Density	g/ccm	~1.3																																									
2	Tensile strength	MPa	~1000																																									
3	Impulse dielectric Strength	kV/mm	≥ 16																																									
4	Relative permittivity	-	~3.4																																									
5	Dielectric loss factor	%	~0.4																																									
6	SHRINKAGE15 HR160 °C	%	≤ 2																																									
7	SHRINKAGE	%	< 0.5																																									
8	Water Absorption	%	< 0.5																																									
9	Water Absorption @ 100°C	%	< 0.5																																									
	2.1.2	<b>Type of Fiber:</b> Aramid / Kevlar shall be used as fiber. The material shall be resistant against arced SF6 gas.																																										
Page 1/3	PSGSG109.doc		<b>Signature</b> <i>V. Akhona</i>																																									

Contd..

PSGSG109	<b>SPECIFICATIONS FOR Pull Rod Assy.</b>		Drg.No.	RD DG 4 35 0617 0230
			Date	03.01.2015
			Product	GSM-400
2.2	2.1.3	<b>Manufacturing process:</b> The fibers shall be wound and impregnated with hot curing epoxy resin in vacuum/ pressure. The casting shall be void free and shall achieve required electrical and mechanical properties. The epoxy used shall be compatible to arced SF6 gas.		
	2.1.4	The processed material shall have good Chemical resistance against organic and inorganic acids.		
	2.1.5	The shape of the tube shall be in accordance to the approved drawing.		
	<b><u>METAL INSERTS</u></b>			
	2.2.1	Profiled metal inserts as per approved drawing shall be machined using NC machining from mechanical grade aluminum alloy as per (DIN/BIS/IS standards).		
	2.2.2	The aluminum flanges shall be glued to the epoxy tube using a hot curing adhesive (compatible to arced SF6 gas) and joined as per the practices of the supplier.		
	2.2.3	The bonding between insulator and metal flanges shall be done without roll pins /threaded bolts/ cross bolts. The bonding shall not only withstand specified mechanical forces but also offer leak tightness for use in differential pressure application.		
	3.0	<b><u>FACTORY TEST</u></b>		
	3.1	Dimensional report.		
	3.2	Mechanical load bearing capability (Tensile, ~30 kN+ 10%) for the glued joints. The joint shall have an ultimate strength of ~50 kN .		
Page 2/3	PSGSG109.doc	Signature 		

PSGSG109	<b>SPECIFICATIONS FOR Pull Rod Assy.</b>		Drg.No.	RD DG 4 35 0617 0230
			Date	03.01.2015
			Product	GSM-400
4.0	<b><u>QUALIFYING REQUIREMENTS:</u></b>			
	The supplier shall be of national / International repute with proven record and should have supplied similar material for gas insulated circuit breaker applications. These insulators shall be used for GIS application and for these applications performance reference shall be submitted.			
5.0	<b><u>GENERAL</u></b>			
5.1	Metal Flanges shall be free from sharp corners. Wherever not specified in the drawing, a radius of R 0.5 mm shall be provided at unspecified corner/Edge.			
5.2	The components shall be packed individually in appropriate packing with moisture absorbents so as to prevent transit damages.			
5.3	The components shall be guaranteed against all manufacturing defects.			
5.4	In case of doubts in specifications, the supplier shall contact BHEL for clarifications.			
Page 3/3	PSGSG109.doc		Signature <i>Arulena</i>	