

 CBU BHEL	PURCHASE SPECIFICATION Industrial Air Conditioning Unit System	Spec. No	EP:PVM:EQS:10
		Rev. No	00
		Page 1 of 35	

TECHNICAL SPECIFICATION
FOR
Industrial Air Conditioning Unit for Process Area
Approx. 13500 m³

ELECTROPORCELAINS DIVISION,
BHARAT HEAVY ELECTRICALS LTD.,
IISc POST, BANGALORE, INDIA 560012

REVISION (00)	DETAILS:	PREPARED	DATE 30.11.2015
		APPROVED	

COPYRIGHT AND CONFIDENTIALITY

The information on this document is the property of Bharat Heavy Electricals Limited.
It must not be used directly or indirectly in anyway detrimental to the interest to the company

 <p>बी एच ई एल BHEL CBU - EPD</p>	<p>PURCHASE SPECIFICATION Industrial Air Conditioning Unit for Process Area</p>	Spec. No	EP:PVM:EQS:10
		Rev. No	00
		Page 2 of 35	

1.1 SCOPE OF WORK

This specification defines the requirements for the design, engineering, assembly fabrication, procurement, testing, balancing and installation and commissioning for satisfactory performance of Heating Ventilating and Air Conditioning (HVAC) unit at the Solar PV Module Manufacturing shop in Electroporcelains Division, Bharat Heavy Electricals Ltd., IISc Post, Bengaluru. The capacity of the air conditioning system shall be suitably designed for the total shop heat load comprising of heat emanated from the process equipment, human activity in the shop and atmospheric energy ingress.

1.2 SPECIFIC SITE REQUIREMENTS OF SOLAR PV MODULE MANUFACTURING SHOP

- 1) HVAC system is to be provided in the existing shop building of BHEL – EPD, details of the building is described below and a general layout diagram provided in Annexure - I.
- 2) The shop will be provided with false ceiling and the space constraint for laying of the main ducts between the false ceiling and roof beam of the building shall be taken into account. Roof structural beams are located at every 5 m across the length of the shop and the clearance between beam and the false ceiling is minimal. On the width of the shop of 30 mtr support columns are there in the middle. The main feeder duct therefore has to be suitably provided after examining the shop in detail. For the exposed portion bidder to provide suitable thermal insulation and casing box to reduce the heat loss to bare minimum. Suitable structural support shall be provided for holding the ducting at all places and the design criteria and calculations are to be provided. The cost for structural design modification if any is to be included in the total cost of the HVAC system. However, Lump sum rate shall be quoted for any dismantling of the existing structures and for modification, which shall be quoted separately.
- 3) Bidders shall visit the site prior to submission of bid, ascertain the quantum of work involved and take into account the site conditions for design of the system and for Installation & commissioning.
- 4) Space envisaged for the air handling unit to be indicated, which will be provided by BHEL - EPD separately. Bidders in their technical bid are to provide layout plan for the AHU units indicating minimum floor area required. Location of the AHU's could be decided on evaluation of all the factors.

COPYRIGHT AND CONFIDENTIAL

The information on this document is the property of Bharat Heavy Electricals Limited. It must not be used directly or indirectly in anyway detrimental to the interest to the company

 <p>CBU - EPD</p>	<p>PURCHASE SPECIFICATION Industrial Air Conditioning Unit for Process Area</p>	Spec. No	EP:PVM:EQS:10
		Rev. No	00
		Page 3 of 35	

1.1 a INTRODUCTION

The document specifies minimum requirements for the Design, Engineering, Fabrication, Assembly, Co-ordination, Procurement, Inspection, Testing, Installation and Commissioning of complete and operable, Heating ventilating and Air Conditioning (HVAC) systems required for BHEL - EPD, Solar Module Manufacturing shop.

This specification along with the relevant codes & standards describes the minimum requirements for design, supply, installation and commissioning for HVAC system. It is not the intent to completely specify all details of design and construction; however, any additional equipment, material, services which are not specifically mentioned here, but are required to make the system complete in every aspect in accordance with the technical specification and for safe operation and guaranteed performance shall be covered under the scope of this specification. Nevertheless, the equipment and installation shall conform to high standards of engineering, design and workmanship in all respects and shall be capable of performing in continuous operation in a manner acceptable.

The Contractor/ Vendor shall make all possible efforts to comply strictly to the requirements of this Specifications and other relevant Codes & Standards. In case, any deviations are considered essential by the Contractor/ Vendor after making all possible efforts, these shall be separately listed in the Contractor's /Vendor's offer under 'LIST OF DEVIATIONS/ EXCEPTIONS TO THE TENDER DOCUMENTS for the purchaser's considerations. In the event, of any deviation not listed under the 'List of deviations / exceptions to the tender', even though it is appearing in other part of the offer shall not be considered applicable. Deviations accepted by the purchaser are the only exceptions acceptable.

Hence all the requirements shall be binding on the Contractor / Vendor without any cost and schedule implications to the purchaser. The Contractor / Vendor shall be responsible for the co-ordination of all Sub-Suppliers and for the overall guarantee of the offered equipment. It is the specific responsibility of the Contractor / Vendor to invoke all applicable referenced specifications to each Sub-Supplier.

The offered equipment shall be sourced from a regular and established manufacturer having requisite design, manufacturing and testing facilities. The offered model shall be from the regular manufacturing range of the supplier and the design shall have had a minimum of two years successful field operation with the same model having the same design and materials of construction.

Relevant information of the offered equipment like catalogues; references, user's certificates etc. shall be furnished along with the offer

COPYRIGHT AND CONFIDENTIAL

The information on this document is the property of Bharat Heavy Electricals Limited. It must not be used directly or indirectly in anyway detrimental to the interest to the company

 <p>बी एच ई एल</p> <p>BHEL</p> <p>CBU - EPD</p>	<p>PURCHASE SPECIFICATION</p> <p>Industrial Air Conditioning Unit for</p> <p>Process Area</p>	Spec. No	EP:PVM:EQS:10
		Rev. No	00
		Page 4 of 35	

The Reference Codes & Standards:

- BS EN 12449 Copper & Copper Alloy Tubes for general purposes.
- BS EN 12451 Copper & Copper Alloy Tubes for heat exchangers.
- BS 2879 Draining Taps
- BS 3505 UPVC Pressure Pipes for Cold Potable Water
- BS EN 10216-1 Seamless steel tubes for pressure purposes.
- BS EN 10217-1 Welded steel tubes for pressure purposes.
- BS 5150 Cast Iron Gate Valves
- BS 5152 Cast Iron Globe Valves
- BS EN 12334 Industrial valves, Cast Iron Check Valves.
- BS 5154 Copper Alloy Globe, Check & Gate Valves.
- BS 5588 Fire Precautions in the Design, Construction & Use of Buildings
- BS EN 779 Particulate Air Filters for General Ventilation
- BS EN 61260; 1996 Electroacoustic, Octave-band, and fractional octave-band filters
- BS EN 60651:1994 Specification for Sound Level Meters
- BS EN 60942:1998 Electroacoustic, Sound Calibrators
- HVCA Heating & Ventilation Contractors Association Publications
- ARI 210 Unitary Air Conditioning Equipment
- ARI 270 Standard for sound rating of outdoor unitary equipment
- ARI 360 Commercial and Industrial Unitary Air conditioning equipment ARI 410 Forced circulation Air-cooling and Air-heating coils
- ARI 430 Central Station Air-handling Unit ARI 650 Standard for Air Outlets and Inlets
- ASHRAE 14 Methods of testing for rating positive displacement condensing units ASHRAE 15 Safety code for mechanical refrigeration
- ASHRAE 20 Methods of testing for rating remote mechanical-draft air-cooled refrigerant condensers
- ASHRAE 52-76 Methods of testing Air cleaning Devices used in general ventilation for removing particular matter
- ASHRAE 90A Energy conservation in new building design (Sections 1 through 9) ASHRAE 70 Method of testing for rating the air flow performance of outlets and inlets ASHRAE 34 Number designation and safety classification of refrigerants
- ASHRAE 111 Practices for measuring, testing and balancing a building heating, ventilation, air conditioning and refrigeration systems
- ASHRAE Hand books
- CARRIER Handbook for air conditioning system design, Carrier air conditioning company

COPYRIGHT AND CONFIDENTIAL

The information on this document is the property of Bharat Heavy Electricals Limited. It must not be used directly or indirectly in anyway detrimental to the interest to the company

 <p>बी एच ई एल CBU - EPD</p>	<p>PURCHASE SPECIFICATION Industrial Air Conditioning Unit for Process Area</p>	Spec. No	EP:PVM:EQS:10
		Rev. No	00
		Page 5 of 35	

ASTM A53 Standard Specification Pipe, Steel, black and hot-dipped, zinc coated, welded and seamless
ASTM A90 Standard Test method for weight of coating on zinc coated (galvanized iron or steel articles)
ASTM A527 Standard Specification for steel sheet, zinc-coated (galvanized) by the Hot-dip process, lock-forming quality
ASTM A 666 Standard Specification for Austenitic stainless steel, sheet, strip, plate and flat bar
ASTM B62 Standard specification for composition bronze or ounce metal castings ASTM B88 Standard specification for seamless copper water tube
ASTM B280 Standard specification for seamless copper tube for air conditioning and refrigeration field service
ASTM C552 Standard specification for cellular glass thermal insulation ASTM D579 Standard specification for greige woven glass fabrics
ASTM E477 Testing Duct Linear Materials and prefabricated silencers for acoustical and airflow performance
NFPA 70 National Electrical Code
NFPA 90A Standard for the Installation of Air Conditioning and Ventilating Systems
NFPA 220 Standard on Types of Building Construction
NFPA 225 Method of Test of Surface Burning Characteristics of Building Materials
RMA IP-20 Specifications for Drives Using Classical Multiple V-Belts, and Sheaves – Cross Sections, A,B,C and D

1.1b SITE DATA

Engineering and design of the building HVAC systems shall be performed in accordance with the codes and standards listed in this specification. The system shall be designed for a minimum life of 30 years under normal operating conditions.

1.1c Outdoor Design Conditions

To refer the standard design conditions for Bengaluru City.

1.1d Indoor Design Conditions

Max 22°C

: Min 18°C

RH: 45 ~ 60%

COPYRIGHT AND CONFIDENTIAL

The information on this document is the property of Bharat Heavy Electricals Limited. It must not be used directly or indirectly in anyway detrimental to the interest to the company

 <p>बी एच ई एल CBU - EPD</p>	<p>PURCHASE SPECIFICATION Industrial Air Conditioning Unit for Process Area</p>	Spec. No	EP:PVM:EQS:10
		Rev. No	00
		Page 6 of 35	

The scope of the work described in this specification shall include complete HVAC systems as specified herein. The VENDOR shall provide all supervision, pressure test, performance test, material, equipment, machinery and all other items necessary to complete the HVAC systems. Any material not specifically mentioned in this specification but required for proper performance and operation shall be furnished and installed by the VENDOR. Vendor shall install all the items as required for complete system. The equipment furnished according to this specification shall conform to the requirements contained herein, unless modified in writing by the attachment or an addendum to this specification.

Compliance by the VENDOR with the requirements of this specification does not relieve the VENDOR of his responsibility to supply equipment that is of proper design & construction, fully suited for all specified conditions.

The VENDOR shall provide the requirements described below and attachments duly verified including, but not limited to the following:

Air handling units

Air cooled condensing units

Refrigerant piping and accessories

Ductwork and accessories

Microprocessor based HVAC Control Panel

Field instruments, controls and accessories

Conduit and wiring required for the control system inputs, outputs, power wiring for the controllers, actuators and terminal units.

2.1 Design Requirements

The overall dimension of the shop is : Length 70m x Width 30m x Height (false ceiling) : 5.5m. Within this shop the Solar PV Module manufacturing equipment is being installed. The air-conditioning system shall be designed, supplied, installed and commissioned for the Solar PV Module manufacturing shop.

2.2 Heat Dissipation

2.2.1 Light Heat Dissipation

Lighting heat dissipation for various rooms shall be considered, the lighting is from LED flase ceiling fittings which has very low heat emission. About 600 number of LED light fittings of 36 W each will be provided in the shop.

2.2.2 Equipment Heat Dissipation

Equipment heat dissipation inside the shop from various equipment / auxiliary shall be considered. The equipment deployed is predominantly electric induction motor driven. 4 nos of laminators are the heat emanating equipment, wherein the lamination of the panel is done at temperatures, however

COPYRIGHT AND CONFIDENTIAL

**The information on this document is the property of Bharat Heavy Electricals Limited.
It must not be used directly or indirectly in anyway detrimental to the interest to the
company**

 <p>बी एच ई एल CBU - EPD</p>	<p>PURCHASE SPECIFICATION Industrial Air Conditioning Unit for Process Area</p>	Spec. No	EP:PVM:EQS:10
		Rev. No	00
		Page 7 of 35	

the whole process is enclosed and the laminator is insulated. The surface temperature of the laminator is around 40 Deg. C and the panels (of size 1mx2m) 4 numbers at a time after emerging from the laminators at about 50 ~ 60 Deg. C will emit radiant heat into the shop floor.

The total connected electrical load for the turnkey PV Module manufacturing line is about 800 kW inclusive of the heating circuit load of about 450 kw

2.2.3 Heating / Cooling Load

Computerized calculations shall be performed using established and proven software either of the following (or an approved equal):

- Carrier, HAP or E20.
- Elite, CHVAC - Commercial HVAC Loads

2.2.4 Working Personnel

The Solar PV Module manufacturing shop is working round the clock on 3 shift basis. At any given point of time, about 60 persons will be inside the air-conditioned shop. The AC load for the working personnel and their comfort condition shall be considered for the HVAC design.

2.3 HVAC Design Criteria

- The HVAC system shall be capable of maintaining the desired conditions at all locations inside the shop area.
- Sufficient air quantity shall be considered to remove heat gain from equipment, working personnel and lights to maintain each space at the required inside design conditions.
- All equipment, ducting and piping shall be arranged to provide required clearance for installations, operation, inspection, maintenance and dismantling with the minimum interference or removal of ducting, piping and equipment. Accessibility and maintenance doors shall be installed in ductwork.

2.4 Noise Levels

Sound attenuators or other measures, if necessary, shall be applied for reducing the noise generated by the equipment or air borne noise.

2.5 Infiltration

Fresh air infiltration may be considered in order to provide a minimum fresh air intake quantity, 50% air changes per hour fresh air can be considered as infiltration requirements.

2.6 Electrical Power Supply

HVAC power and control panel power section shall be directly fed from main electrical distribution board to a single point by BHEL and further distribution to HVAC equipment shall be under the scope of HVAC Vendor. Design Supply and laying of cable from Electrical distribution board in

COPYRIGHT AND CONFIDENTIAL

**The information on this document is the property of Bharat Heavy Electricals Limited.
It must not be used directly or indirectly in anyway detrimental to the interest to the
company**

 <p>CBU - EPD</p>	<p>PURCHASE SPECIFICATION Industrial Air Conditioning Unit for Process Area</p>	Spec. No	EP:PVM:EQS:10
		Rev. No	00
		Page 8 of 35	

Solar PV Module Manufacturing shop to the HVAC power panel supplied by the vendor shall be under the scope of BHEL. Voltage rating of power feeder shall be 415 V \pm 10 % AC, 3 Phase, 50 \pm 5% Hz, 4 wire. The power supply to the HVAC Control Panel shall be furnished from 240V AC/1-Phase/50Hz power source, which are over-current protected. The HVAC Control Panel shall include a 24V DC power supplies to drive local lamps, powering transmitters and for any other 24V DC requirements. This power shall be derived by the HVAC Vendor internally. The HVAC Control Panel shall also include power supplies to drive the motorized dampers and for any other requirements.

Any other voltage required for equipment and controls shall be derived in the HVAC system power and control panel.

2.7 Drainage System

The condensate water from air handling units shall be piped into the building or plant drainage system.

2.8 Potable Water Supply

When humidification is required, steam humidification shall be employed. One potable water supply point shall be provided.

2.9 HVAC System

Direct expansion (DX) type system with air handling units and air cooled condensing units shall be considered. HVAC equipment capacity selection shall include 20% of the calculated cooling load as safety factor for contingency.


Equipment shall be connected to ductwork via flexible connections to eliminate transmission of vibration. HVAC systems shall be designed to provide temperature and humidity controlled (where specified) environments for equipment in accordance with the design criteria. System shall incorporate the use of filtration, cooling, heating, and humidification/dehumidification as required to meet the design conditions. Condensation within the building shall be prevented by proper sealing of service penetrations. Vapor barrier shall be applied to chilled water piping and supply and return air ducts.

2.10 HVAC Control System

Dedicated HVAC Control Panel shall be provided with Central Air conditioning system as a standard package. The local HVAC Control Panel shall be designed to monitor and control the operation of all equipment associated with the HVAC systems, including, but not limited to air handling units, air cooled condensing units, dampers, lights, transmitters etc. HVAC Control Panel shall also monitor all temperature and humidity set-points. Detailed control logic diagrams shall be developed for systems, with all control points, instrumentation and signals shown and identified.

COPYRIGHT AND CONFIDENTIAL

**The information on this document is the property of Bharat Heavy Electricals Limited.
It must not be used directly or indirectly in anyway detrimental to the interest to the company**

 <p>बी एच ई एल BHEL CBU - EPD</p>	<p>PURCHASE SPECIFICATION Industrial Air Conditioning Unit for Process Area</p>	Spec. No	EP:PVM:EQS:10
		Rev. No	00
		Page 9 of 35	

HVAC Control Panels shall provide one common alarm, as volt-free contact for remote indication of any failure alarm monitoring by SCADA controls for HVAC systems shall be interlocked by hardwire to the fire and gas alarm panel for HVAC shutdown in case of fire detection.

HVAC Control system vendor shall produce shop drawings for HVAC control system.

HVAC system status shall be as below:

HVAC system	Normal situation	Abnormal situation		
		Fire and smoke detection in the building	Normal power failure	Mechanical failure
Air handling units	Run	Stop	Stop	Run standby
Air cooled condensing units	Run	Stop	Stop	Run standby
Fire dampers	Open	Close	Close	No standby
HVAC control system	Run	Run	Run	No standby

2.11 Air Distribution System

2.11.1 Ductwork

Generally, ductwork shall be designed and manufactured in accordance with the standards set by SMACNA and in accordance with Specification for HVAC. Ducts shall be formed from sheet steel with hot dip galvanized coating. Average thickness of zinc coating shall be equivalent to not less than 0.6 kg/m² of zinc for all surfaces.

Duct elements shall be constructed for optimal duct air flow, for example by using baffle plates, turning vanes, reversing blades, etc. so that air turbulence, air borne noise and pressure losses are minimized. Flexible ductwork shall not be used unless necessary, however length is to be minimized (maximum length 1.0m).

Ductwork shall be designed to minimize noise transmission and to avoid noise generation from components or fittings.

COPYRIGHT AND CONFIDENTIAL

The information on this document is the property of Bharat Heavy Electricals Limited. It must not be used directly or indirectly in anyway detrimental to the interest to the company

 <p>बी एच ई एल CBU - EPD</p>	<p>PURCHASE SPECIFICATION Industrial Air Conditioning Unit for Process Area</p>	Spec. No	EP:PVM:EQS:10
		Rev. No	00
		Page 10 of 35	

Ductwork air velocities shall be provided with the techno-commercial bids for the Mains, Branches and Run-outs ducts. All rectangular 45 to 90 degree elbows in both medium and low pressure ductwork shall contain turning vanes. Radial elbows shall contain splitters. Supply and return air ductwork in conditioned spaces shall be insulated. Insulated ductwork up to 2.0m above finish floor level or exposed to outdoor air or in any location subject to physical damage shall be provided with aluminum cladding

Balancing devices shall be provided at each supply branch connection serving more than one terminal device and each terminal device. Balancing devices shall also be provided at return air ductwork as required to obtain required return airflow.

2.11.2 Dampers

Generally Volume Control Dampers (VCD) shall be provided at all duct branches in order to balance the system and achieve design/required air flow rates. Fire Dampers (FD) shall be fitted in ductwork/air transfer openings as per NFPA 90A, at all firewalls. Fire dampers shall be constructed of galvanized sheet steel. The motorized fire dampers shall be operated from the HVAC control panel. Motorized fire dampers shall be fail safe type (fail to close).

2.11.3 Air Terminals

Terminal devices (outlets) shall be selected based on the following criteria:

- In occupied rooms, the air distribution shall be such that air velocity at 0.9 m from floor shall never exceed 0.15 m/s.
- Pressure loss for each outlet on each ductwork branch or run shall be approximately equal to ensure uniform air distribution.
- Supply air grille/diffusers shall be selected for required throw and pressure drop not to exceed 20 Pa. Return air inlets shall be selected and located based on the following criteria:
- Face velocity across the inlet shall be less than 2.5 m/s.
- Static pressure drop across inlets shall be less than 10 Pa.
- Inlets shall be located at adequate distances from supply devices to prevent short circuiting of supply air.
- Air inlet/return devices should have volume control dampers

2.11.4 Filters

Access sections with doors shall be provided at each filter section as required for maintenance, filter cleaning and replacement. Filters shall be rated for efficiency of particulate matter removal in accordance with the latest editions of ASHRAE Standard 52 dust spot test.

COPYRIGHT AND CONFIDENTIAL

**The information on this document is the property of Bharat Heavy Electricals Limited.
It must not be used directly or indirectly in anyway detrimental to the interest to the company**

 <p>बी एच ई एल CBU - EPD</p>	<p>PURCHASE SPECIFICATION Industrial Air Conditioning Unit for Process Area</p>	Spec. No	EP:PVM:EQS:10
		Rev. No	00
		Page 11 of 35	

DESIGN REQUIREMENTS

3.1 Internal Heat Gains

The internal (equipment) heat dissipation loads shall be verified and confirmed by the HVAC contractor when sizing the AC equipment. For the equipment sizing purposes, the contractor shall consider heat dissipation from the electrical equipment, lighting as well as working personnel in the module manufacturing shop. To estimate the total cooling required, the total internal heat gains will then be added to heat transmission gains through exterior walls/roof and heat gains from ventilation air (outdoor air)

3.2 General HVAC Requirements

Minimum outdoor air quantities for ventilation shall meet the requirements of ASHRAE standards. Heating requirements shall be based on zero internal heat gain. The air distribution system shall be designed to prevent generation of excessive noise and vibration.

3.3 Air Contamination/Air Quality

Indoor or outdoor air may contain contaminants which may cause corrosion and affect the reliability of the equipment. To maintain the air contaminants below acceptable levels, the following issues shall be considered in the design:

- a. Humidity control shall be used to protect against corrosion. Duct heaters and humidifiers shall be provided (if required) in supply ducts to each zone to maintain design temperature and relative humidity, if required.
- b. To avoid the entrance of dust into the building, adequate filtration shall be provided in the air handling units. The specification of the filtration system shall be ascertained by visiting the site before submission of the bids.


3.4 Miscellaneous System Design Requirements

AC systems shall be shut down automatically via the fire alarm panel upon detection of smoke/fire by the plant fire protection system. Bidders to examine and evaluate the suitability of the fire alarm system deployed in the plant before submission of the bids.

- a. The CONTRACTOR shall be responsible for ensuring that all necessary fire dampers are provided within air-conditioning ducts penetrating fire wall/fire zone.
- b. All equipment, ducts, pipes, controls, etc. shall be fully treated against corrosion and sealed against moisture, sand and dust ingress.
- c. All equipment including ducts and pipes shall be vibration isolated by means of flexible piping, duct connectors, and vibration isolators as per ASHRAE requirements.
- d. Noise caused by HVAC equipment shall be 10 dB (A) below the noise level acceptable limits

COPYRIGHT AND CONFIDENTIAL

**The information on this document is the property of Bharat Heavy Electricals Limited.
It must not be used directly or indirectly in anyway detrimental to the interest to the
company**

 <p>बी एच ई एल CBU - EPD</p>	<p>PURCHASE SPECIFICATION Industrial Air Conditioning Unit for Process Area</p>	Spec. No	EP:PVM:EQS:10
		Rev. No	00
		Page 12 of 35	

stated for the applicable buildings. Noise caused by HVAC equipment can be reduced by any one of the following:

- Air Duct Silencers
- Sound Attenuators
- Duct Lining
- Selecting Quieter equipment

4.0 HVAC SYSTEM DESCRIPTION

4.1 Control room building

Bidders shall provide the requirement of the control room building for housing the system and components of HVAC system. It shall be the responsibility of the Contractor/Vendor to verify and confirm the location of condensing units as per the suitability and requirements of the system

4.2 Interface with fire protection system

The existing Fire alarm panel shall be interfaced to HVAC control panel. Upon detection of smoke or fire by the fire protection system, the AC units in the control building shall be shut down via the fire alarm panel

5.1 Equipment / Materials

All HVAC equipment and materials shall be certified to have been tested and rated for performance and to conform to all applicable codes and standards. All HVAC equipment and materials shall be new and be the latest products selected from the approved vendors' list.

5.2 Air handling units

- a) The air handling unit shall be completely factory assembled, wired, charged, tested and be ready for immediate installation. Each unit shall comprise of centrifugal supply air fan with motor, cooling coil and washable air filters, and condensate drain pan. The unit shall be enclosed in a weather proof composite casing constructed from galvanized sheet metal with a stove enameled finish. The casing shall be fully insulated and be provided with access panels/doors for maintenance.
- b) The whole unit shall be mounted suitable with rubber sheet isolation pad.
- c) Filters: Pre filter shall be 2" thick pleated disposable type filter with an average efficiency of 65% and an average arrestance of 90-92% in accordance with ASHRAE standard 52-76. After filter shall be disposable type with 95% efficiency and arrestance to ASHRAE standard 52-76.
- d) The cooling coil shall be constructed from seamless deoxidized copper tubes mechanically bonded with copper fins. All cooling coils shall be selected for a face velocity of not more than 2.5m per second and moisture carryover shall be avoided.
- e) A stainless steel sheet drain pan shall be fitted under each coil or coil section and a condensate

COPYRIGHT AND CONFIDENTIAL

**The information on this document is the property of Bharat Heavy Electricals Limited.
It must not be used directly or indirectly in anyway detrimental to the interest to the
company**

 <p>बी एच ई एल CBU - EPD</p>	<p>PURCHASE SPECIFICATION Industrial Air Conditioning Unit for Process Area</p>	Spec. No	EP:PVM:EQS:10
		Rev. No	00
		Page 13 of 35	

drain outlet provided with running trap with seal at 150% min. of fan static pressure at cooling coil to discharge to nearest drain point.

f) The fan shall be backward curved multi-vane impeller centrifugal type having non-overloading characteristics.

g) All wheels shall be statically and dynamically balanced at their rated speed in the factory as an assembled unit and shall be run on large diameter precision ground solid steel shafting in heavy duty self-aligning grease lubricated deep groove ball bearing plumber block.

h) Where two fans are fitted, these shall be connected by means of and driven through suitable flexible couplings. The fan(s) shall be mounted on a fabricated steel framework suitably extended to receive on one side a totally enclosed fan cooled motor, complete with slide rails for tensioning of V belt drive. Each drive shall have a minimum of two belts incorporating pulleys with taper lock bushes.

i) The whole fan supporting framework shall be completely isolated from the remainder of the unit by means of rubber in shear anti vibration mountings having a minimum deflection of 4mm. Flexible neoprene connectors shall be fitted to fan discharge with an external spigot termination.

j) The fan motor shall be suitable for 415V 3-phase 50Hz electrical supply and for continuous running in ambient temperatures of 50°C minimum.

k) The fan motor, pulleys, greasing points, etc., shall be arranged for ease of maintenance.

l) The controls shall be factory wired and tested and be completely enclosed within the unit. A return air thermostat shall be provided automatically cycling the compressor to maintain room conditions and shall also provide cold start operation

m) The following spares shall be provided:


- 2 no. complete set of control fuses
- 1 no. complete set of run/trip lights and bulbs
- 1 no. complete set of V belts for each air handling units.
- 1 no. set of washable filter elements for each unit.
- 1 no. set of bearings for each fan set
- Special tools for routine maintenance

n) Remote Control/Panel: Contains controls and indicator lights as follows:

- On-off fan switch
- Supply fan operating indicator light
- Mechanical cooling malfunction indicator light
- Clogged filters indicator light
- Phase failure protection
- Time delay relay
- Anti-freeze protection

COPYRIGHT AND CONFIDENTIAL

**The information on this document is the property of Bharat Heavy Electricals Limited.
It must not be used directly or indirectly in anyway detrimental to the interest to the
company**

 <p>बी एच ई एल CBU - EPD</p>	<p>PURCHASE SPECIFICATION Industrial Air Conditioning Unit for Process Area</p>	Spec. No	EP:PVM:EQS:10
		Rev. No	00
		Page 14 of 35	

- o) Electrical convenience outlet: 415V 3-phase 50Hz fused outlet, separately fused, located in unit cabinet.
- p) Unit shall be certified as complying with provisions of ARI 360 and 270 and UL 465, as applicable. Contained within the unit weatherproof casing shall be all factory Refrigeration Institute (ARI) Standard 430 for fans and 410 for coils

5.3 Air cooled condensing units

Each condensing unit shall comprise of multiple compressors and capacity matched air cooled condensers. Condensing units containing duplicate compressors/refrigerant circuits shall be preferred.

- a) Each compressor unit shall be of the serviceable hermetic design, with suitable vibration isolators and crank case heater and automatically reversible oil pump. Refrigerant compressors shall be of the reciprocating or rotary (semi-hermetic or hermetic) type with suction valve unloaders for refrigeration capacity control. The compressor unloader shall be hydraulically controlled. A hot gas muffler shall be provided with each unit. Compressors shall be provided with complete internal motor protections against motor overloads and motor winding overheat, with manual reset that discharge during manual operation, high pressure cut-out: Manual Reset, low pressure cut-out: Manual Reset, oil failure switch, crankcase heater that de-energize during compressor operation, discharge and suction stop valves, mufflers, automatically reversible oil pump for pressurized lubrication and time delay relay to prevent short-cycling. All piping connection shall have flexible pipe connections approved for refrigerant use. Refrigerant shall be R-134A or approved equivalent. For capacity control, the compressor shall unload in steps of 50%. The electric unloader shall be factory installed and Hot-gas by pass valve and piping on one compressor.
- b) Condenser coil construction shall be seamless copper tube, with "Herasite" coated aluminum extended surface plate fins integral with or mechanically attached to the tube. All components of the main power panel and all control devices shall be UL listed. Construction and ratings shall be in accordance with ARI standard 210, 270 and 410 and shall comply with ASHRAE 15 Safety Codes, and the National Electrical Code.
- c) The casing shall be fully weatherproofed for outside installation and be arranged to allow for an ease of maintenance. An integral control panel shall be provided with a lockable hinge access door. The control panel shall be factory pre-wired and tested and shall incorporate all necessary pressure detectors and overload devices to facilitate fully automatic operation.
- d) Minimum degree of ingress protection for the motors shall be to IP 56. All motors shall be suitable for 415V 3-phase 50Hz electrical supply and be suitably insulated to IEC 60085 to continuously run in ambient temperatures of 50°C.

COPYRIGHT AND CONFIDENTIAL

**The information on this document is the property of Bharat Heavy Electricals Limited.
It must not be used directly or indirectly in anyway detrimental to the interest to the
company**

 <p>बी एच ई एल CBU - EPD</p>	<p>PURCHASE SPECIFICATION Industrial Air Conditioning Unit for Process Area</p>	Spec. No	EP:PVM:EQS:10
		Rev. No	00
		Page 15 of 35	

e) Air-conditioning equipment shall have suitable accessories to prevent surface condensation and to prevent carryover of condensed moisture into the ducts through supply air stream.

5.4 Vibration Isolators

Vibration isolators shall be provided for all motor driven equipment.

5.5 Refrigerant pipe work

Refrigerant piping shall be direct expansion (DX) type hard copper tubing conforming to ASTM B88-62 Type L with seamless wrought copper solder type fittings, isolation valves, filter-drier of the replaceable core type with micron filtration, and sight glass as required. Piping 9.5 mm and smaller shall be type K.

5.6 Valves

Valves 29 mm and smaller shall be forged brass body, diaphragm type, packless globe valve with solder ends. Valves 35 mm and larger shall be bronze alloy, non-rotating disk, nylon seats, bolted bonnet globe valve with solder ends.

5.7 Pipe insulation

Insulation shall be applied in accordance with MANUFACTURER'S instructions over clean, dry pipe after all testing is completed and approved. Pipe insulation shall be heavy density rigid fiberglass with factory applied vinyl coated embossed foil vapour barrier laminate jacket with pressure sealing lap adhesive. The insulation shall be rated non-combustible by Underwriters Laboratories. Insulation for suction lines shall have a minimum thermal resistance (R value) of 1.46 meter-degree Kelvin per watt. Liquid and hot gas lines outside the building shall be insulated with minimum 25 mm thick glass fiber insulation with weatherproof covering. Insulation shall be Owens Corning Fiberglass ASJ/SSL or equal.

5.8 Condensate drain piping

All condensate drains from air conditioning equipment shall be trapped and vented with condensate drain pipes to be routed to an approved receptor. Approved indirect waste receptors shall be piped and drain to the plant sanitary sewer system. An alternate method shall be to terminate condensate drain piping at outdoor dry-well type sumps where condensate shall seep to below grade.

5.9 Ductwork

5.9.1 Ductwork Materials

All material used in fabrication of ducts, plenums, stiffeners and supports shall be new galvanized steel. Sheet metal shall be galvanized steel sheet metal with a minimum zinc coating of 0.6 kg per square meter. Duct fabrication and installation shall be in accordance with SMACNA standards as mentioned in this document. Ductwork materials shall be in accordance with the following schedule:

COPYRIGHT AND CONFIDENTIAL

**The information on this document is the property of Bharat Heavy Electricals Limited.
It must not be used directly or indirectly in anyway detrimental to the interest to the
company**

 <p>बी एच ई एल CBU - EPD</p>	<p>PURCHASE SPECIFICATION Industrial Air Conditioning Unit for Process Area</p>	Spec. No	EP:PVM:EQS:10
		Rev. No	00
		Page 16 of 35	

a) Zinc Coated Steel Sheets

14 gauge and over (thinner), ASTM A527, Coating Designation G90 Lock Forming Quality. Under 14 gauge (thicker), ASTM A526, Coating Designation G90 Commercial Quality.

b) Structural Steel Shapes

ASTM A36 plain or zinc coated in accordance with ASTM A123

c) Bars

ASTM A575 or A576, plain or zinc coated in accordance with ASTM A123 or ASTM A164, Type GS.

Note : The main duct will be exposed to atmosphere hence the proper insulation and casing shall be provided and the design details to be provided to prevent any heat loss due to outside weather conditions.

5.9.2 The Gasket Materials shall be as follows:

a) For joints subject to disassembly and removal: Neoprene, 1/8 inch thick, ASTM D1056, Grade RE43-41 to RE45-E1, cellular solid or 30 - 40 Shore A durometer neoprene, with dovetail joints or equal.

b) For joints not subject to disassembly and removal: Weatherproof Type 1202t, 1/8 inch thick tape with dovetail joints, Foster 30-02 sealant, Epolux Cadaseal 770, as applicable to the joints construction or equal.

Products which contain asbestos are prohibited. This prohibition includes items such as packing or gaskets even though the item is encapsulated or the asbestos fibers are impregnated with binder material

5.9.3 Hangers, Supports, and Supporting Steel


Hangers for ductwork shall be in accordance with SMACNA, Low Pressure Duct Construction Standards. Equipment or ductwork shall be supported only from structural steel, reinforced concrete, or solid masonry.

Hangers and supports for equipment and ducts when attached to structural steel shall be welded or mechanically attached using manufacturers' standard clamps, brackets or clips. For cases if these need to be attached to reinforced concrete or solid masonry structures, attachment shall be done by using manufacturers' standard inserts or fasteners. All welds to structural members and supports from hollow masonry shall be subject to the approval of Engineer-in-charge, and manufacturer's load ratings for any device shall not be exceeded.

Threaded weld studs will be permitted. However, threaded weld studs shall be used in tension only and in specific areas as approved by Engineer-in-charge. Threaded weld studs shall meet all manufacturer's requirements and / or limitations including restrictions on stud size for overhead

COPYRIGHT AND CONFIDENTIAL

**The information on this document is the property of Bharat Heavy Electricals Limited.
It must not be used directly or indirectly in anyway detrimental to the interest to the company**

 <p>बी एच ई एल CBU - EPD</p>	<p>PURCHASE SPECIFICATION Industrial Air Conditioning Unit for Process Area</p>	Spec. No	EP:PVM:EQS:10
		Rev. No	00
		Page 17 of 35	

weld positions. Stiffener angles may be used as part of the hanger system in ducts, if the stiffener angle is sized to meet the sum of the stiffener and trapeze load requirements. Do not exceed hanger spacing requirements.

Supports for rectangular ducts, supported from above, shall be the trapeze type with shelf angle or structural tubing and rod or angle hangers, and if supported from vertical structural, by an angle bracket type. When reinforcing is applied to the longer sides only, the reinforcing shall be tied together by welding an angle or rod between the reinforcing members on each of the unreinforced sides of the duct. When reinforcing is applied to the four sides, all corner joint shall be welded together. Strap hangers shall not be used for the support of vertical ducts. Equipment shall be suspended by rods and angles, in accordance with manufacturer's instructions

5.9.4 Elbows

Rectangular radius elbows shall be standard radius (R - 1.5 w) wherever space permits. Short radius rectangular elbows shall be provided with vanes. All square throat rectangular elbows shall be provided with single thickness turning vanes. Turning vanes in ducts with acoustical lining shall be anchored, riveted or welded to the duct.

Turning vanes shall be 2 inches radius, shall have a 0.75 inch trailing edge, shall be spaced 1- ½ inches O.C., and shall be installed in accordance with SMACNA Standards. The use of spot welding or sheet metal screws to attach either turning vanes or splitters to the elbow cheek is not permitted.

Round elbows shall be machine formed and of the same metal gauge requirements as for the straight lengths. Centerline radius of elbows shall be 1.5 times the diameter except reducing elbows shall have a centerline radius of 1.5 times the diameter of the larger end. Multi-piece round elbows shall be made of a minimum of 5 pieces.

5.9.5 Branch Take-offs and Tees


Branch takeoffs shall be made at main duct transverse joints using straight duct sections and elbows. Tapped tee connections where required shall be provided with extractors. Tees in main ducts shall be made by elbows joined at the main duct transverse joint or, if with square throat, may be of one piece with fixed splitter. Short radius tees shall be provided with single thickness turning vanes.

5.9.6 Access and Inspection Doors

Access and inspection doors shall be provided in sheet metal work. Inspection doors shall be located at:

COPYRIGHT AND CONFIDENTIAL

**The information on this document is the property of Bharat Heavy Electricals Limited.
It must not be used directly or indirectly in anyway detrimental to the interest to the
company**

 <p>CBU - EPD</p>	<p>PURCHASE SPECIFICATION Industrial Air Conditioning Unit for Process Area</p>	Spec. No	EP:PVM:EQS:10
		Rev. No	00
		Page 18 of 35	

- a) Motor operated dampers
- b) Fire dampers
- c) Splitter dampers
- d) Turning vanes (upstream side)
- e) Other similar items requiring inspection or maintenance

Access doors shall be to provide personnel entry into the following unless provided by the equipment manufacturer:

- a) Filter plenums
- b) Return air plenums
- c) Other such locations requiring personnel access into a space

Inspection doors shall provide minimum openings of 120 square inches, unless otherwise specified. Access doors shall have minimum size of 16 inches by 24 inches and not exceed 20 inches by 54 inches. All access doors shall open against the pressure in the duct or plenum.

Access and inspection doors shall be constructed to the following details:

- a) Not exceeding 16 inches by 24 inches: Single panel-insulated type, tight sealing, two hinge, two latch type and gasket seal.
- b) Larger than 16 inches by 24 inches: Double panel, insulated type, tight sealing two hinge, two latch type and gasket seal. Inspection doors only shall be removable non-hinged type.

5.9.7 Instrument Test Holes

Instrument Test Holes shall be Ventlock 699, as manufactured by Ventfabrics, Inc., or equal as approved.

5.9.8 Air Distribution Devices

Air Distribution Devices shall be provided as part of the Air Distribution System and as specified herein. Diffusers, registers, and grilles shall be manufactured from extruded aluminum and shall be supplied complete with opposed blade volume control dampers. Both dampers and grilles shall have concealed screw type fixings. Spring clip fixings shall not be permitted.

The required air quantity shall be distributed evenly to the space intended without causing noticeable drafts or dead spots anywhere in the occupied zone. All return air square diffusers shall be identical to the supply air diffuser within each conditioned zone.

Supply Ceiling Diffusers (SCD) shall be complete with opposed blade damper and equalizing grid. SCDs shall be two, three or four-way throw as required by their locations. Size and capacity of all inlet and outlet shall meet the requirement of the system

COPYRIGHT AND CONFIDENTIAL

The information on this document is the property of Bharat Heavy Electricals Limited. It must not be used directly or indirectly in anyway detrimental to the interest to the company

 <p>बी एच ई एल CBU - EPD</p>	<p>PURCHASE SPECIFICATION Industrial Air Conditioning Unit for Process Area</p>	Spec. No	EP:PVM:EQS:10
		Rev. No	00
		Page 19 of 35	

5.9.9 Duct Accessories

A. Manual Volume Dampers

Manually Operated Multi-blade Dampers (Rectangular Ductwork):

- a. Configuration: Manually operated dampers shall be of the opposed blade type. Single blade dampers are not acceptable. Where required, duct-mounted dampers shall be fabricated with blades parallel to the longest side of the ductwork in which they are installed.
- a. Frames: Frames shall be fabricated of 7.6 cm. wide by 18 ga. USS (minimum) roll-formed galvanized steel or 5 cm. x 1.27 cm. (min.) galvanized structural channel with integral reinforcing ribs and counting flanges for ease of installation.
- b. Blades: Blades shall be fabricated of 16 ga. USS (minimum) galvanized steel and sized no greater than 15.2 cm. in width or 121.9 cm. in length.
- c. Blade Shafts and Bearings: Blade shafts shall be 1.27 cm. round, hex or square, cadmium plated steel and shall operate in nylon or oil impregnated bronze bearing mounted in the damper frame. Round blade shafts are to be thru-bolted or thru-pinned to the damper blades.
- a. Linkage: Linkage shall be cadmium plated steel assembly of interconnecting crank arms attached to the shaft of each damper blade. This Linkage is to be mounted external to the air stream.
- d. Seals: Dampers shall be provided with flexible metal or elastomeric jamb seals. Additionally, an extruded vinyl or elastomeric edge seal is required along the length of each blade.
- e. Accessories: Each damper shall be furnished with an extra shaft extension, hat channel bracket, manual lever and locking quadrant.

B. Motorized Dampers

The Contractor shall furnish and install, control dampers as required for the proper functioning of the system. All control dampers shall be opposed blade. Dampers frames shall be for formed channels of not less than 1.8 mm galvanized steel with mounting holes for enclosed duct mounting.


Damper blades shall be of not less than 1.5 mm form galvanized steel. Blades on multi-blade dampers shall not exceed 200 mm in width and 1200 mm in length. Blade shaft bearings shall be provided at the ends of each blade. Blade side edges shall seal off against spring stainless steel seals. Dampers shall be supplied in standard sizes, in 50 mm even increments, with transition as necessary to mating duct sections. Dampers shall be suitable for operation within the temperature limit of – 40°C to 93°C. Horizontal dampers shall have a rated face velocity of 2 m/s at 1500h Pa static pressure differential. Dampers used for shut of function shall be if the low leakage type. Damper blades shall have neoprene or PVC edging on all outside air dampers.

C. Back draft Dampers

Back draft dampers shall be low leakage with parallel blades and neoprene edge seals. Damper frames shall be constructed from galvanized sheet steel with aluminum blades. Bearing shafts

COPYRIGHT AND CONFIDENTIAL

**The information on this document is the property of Bharat Heavy Electricals Limited.
It must not be used directly or indirectly in anyway detrimental to the interest to the
company**

 <p>बी एच ई एल CBU - EPD</p>	<p>PURCHASE SPECIFICATION Industrial Air Conditioning Unit for Process Area</p>	Spec. No	EP:PVM:EQS:10
		Rev. No	00
		Page 20 of 35	

shall be stainless steel, on brass bearings. All blades shall be coupled at the blade centers and shall be in width of not more than 1000 mm, with maximum blade size of 200 mm. Leakage shall not exceed 10 m³/h per m² at 1000 Pa (Damper closed) pressure differential.

D. Fire Dampers

Fire dampers shall be provided in the ducting systems where ducting passes through a wall or floor forming a fire zone or barrier. All fire dampers shall be electrically operated interfaced with the HVAC control system to close by spring return actuator on de-energisation of the power supply. On restoration of power, the actuator motor shall open the damper and shall simultaneously prime the spring release. Opening and closing times of the damper shall not exceed 10 seconds. All dampers shall be complete with a micro-switch to indicate the status of the damper (open or closed) at the main air conditioning control panel. Damper casings shall be completely air tight and constructed from galvanized sheet steel of not less than 1.6 mm thickness with continuously welded corners. Inlet and outlet connections shall be spigots formed as an integral part of the construction. Any damper blade or shutter shall be constructed so as not to distort in use and shall be made from stainless steel or non-combustible asbestos free fiber silicate plates, 40 mm thick. Damper blades shall close against a steel stop around the whole periphery of the damper with at least 20 mm overlap. The clearance between the blade and sides of the duct shall be at least 0.01 mm of damper diameter length of side. Multi-leaf damper blades shall overlap by at least 20 mm. An insulated, double skin access door shall be provided adjacent to each fire damper for service inspection and resetting. Where the damper is fitted to a wall or floor, the damper casing shall be fitted with building-in lugs.

E. Access Doors

1. General: Access doors are to be installed in ducts, casings, and housings as specified below. Unless otherwise noted, access doors are to be made of the same material as ducts, casings, or housings in which they are installed. Insulate access door with an equal amount of insulation as required for the ductwork or housings in which they are installed.

2. Access Doors for Rectangular Ducts


- Access doors are to be installed in ducts at each vane elbow or tee, volume damper, fire damper, smoke damper, duct-mounted coil, fan, air flow measuring station, and any duct-mounted instrumentation.
- Access doors shall be installed in the largest duct side unless this location provides poor access or is obstructed by surrounding conditions. Doors shall be furnished in accordance with SMACNA.

F. Hangers and Support Systems

1. Duct hangers and support systems shall be sized and installed in accordance with SMACNA.
2. Sway bracing shall be fabricated to insure proper rigidity of the duct.

COPYRIGHT AND CONFIDENTIAL

**The information on this document is the property of Bharat Heavy Electricals Limited.
It must not be used directly or indirectly in anyway detrimental to the interest to the
company**

 <p>CBU - EPD</p>	<p>PURCHASE SPECIFICATION Industrial Air Conditioning Unit for Process Area</p>	Spec. No	EP:PVM:EQS:10
		Rev. No	00
		Page 21 of 35	

3. Duct support should be installed to handle a proper portion of the load.

G. Duct Connections to Equipment

1. Duct connections to air conditioning equipment shall be angle reinforced, flanged connections secured by 0.64 cm. dia. bolts on 20.3 cm centers (maximum). Joints are to be gasketed with red rubber on high density neoprene and sealed air-tight.

This requirements applies to such equipment as air handling units, fans, packaged units, cooling coils, automatic dampers, filtration equipment, airflow measuring devices, sound attenuators, etc. unless specifically noted otherwise.

5.9 Duct insulation

All insulation materials, including adhesives, sealants, and tapes, shall have flame spread, smoke developed, and fuel contributed ratings of not more than 25, 50 and 50 respectively, in compliance with NFPA 90A. The insulation materials shall be suitable for temperatures up to 121 °C.

Thermal Insulation

a.) Thermal insulation to ductwork shall be carried out by specialists and strictly in accordance with this Specification. No thermal insulation shall be applied to any low velocity ductwork prior to inspection by the Engineer and a site instruction received in writing from the Engineer authorizing the application of thermal insulation. No thermal insulation shall be applied to high velocity ductwork prior to the ductwork being inspected by the Engineer, satisfactorily pressure tested and a site instruction received in wiring authorizing the application of thermal insulation.

b.) In order that tests can be made of the thickness of the applied insulation, the Contractor shall allow for the cost of cutting away any one section of each thickness of insulation to ductwork or plant for inspection by the Engineer. If the insulation proves to be the thickness specified then the cut section shall be made good and the whole installation shall be completed. Should any cut portion show a deficiency in thickness, further portions shall be cut away at the direction of the Engineer-in-charge for inspection. If a deficiency of thickness or any other defects are found, the Contractor shall remove the whole of the insulation installed, or as the Engineer-in-charge directs, and shall then supply, deliver and apply new insulation complying with the Specification and install it to the satisfaction of the Engineer. This work shall be carried out at the Contractor's own expense.

c.) Insulation shall be applied to all ductwork, volume control dampers, sound attenuators, and other items of equipment contained within the Specification detailed below.

d.) No insulation shall be concealed within false ceilings, vertical or horizontal builder's work shafts prior to inspection and approval by the Engineer-in-charge.

e.) All fiber glass slabs shall have a density of not less than 48 kilograms / cubic meter.

COPYRIGHT AND CONFIDENTIAL

**The information on this document is the property of Bharat Heavy Electricals Limited.
It must not be used directly or indirectly in anyway detrimental to the interest to the
company**

 <p>बी एच ई एल CBU - EPD</p>	<p>PURCHASE SPECIFICATION Industrial Air Conditioning Unit for Process Area</p>	Spec. No	EP:PVM:EQS:10
		Rev. No	00
		Page 22 of 35	

f.) All insulation shall be carefully applied using appropriate adhesive, ends and edges of sheets shall be lapped sufficiently and sealed where insulated ductwork enters or leaves the building.

g.) Rectangular supply air ductwork within air conditioned zones shall be insulated using 25 mm rigid fiberglass slabs, aluminum foil-backed secured to the ductwork using an approved adhesive and 75 mm wide aluminum tape at all joints. Insulation shall also have 25 mm wide galvanized bands secured at 600 mm centers. The whole shall be securely wrapped in 4 oz. canvas, all joints lapped, sealed with adhesive and then sewn in position. Two coats 'Sealfas' vapor seal shall be applied. Ductwork within air conditioned ceiling zones shall have one further final vapor seal brush coat. Ductwork exposed to view shall be finished two coats gloss paint to an approved color. Return air ductwork within air conditioned zones need not be insulated

5.10 Volume dampers

Volume damper shall be one gauge heavier than the duct and reinforced where required. Damper over 200 mm in height shall be of multiple opposed blade type with factory manufactured linkage assembly.

5.11 Electric duct heaters

5.11.1 General

Electric Heat shall be duct mounted, with tubular fins, flanged type construction if required. The unit shall consist of framing, heater elements, terminal box and safety device all wire-up and assembled ready for installation. Each electric heater shall be UL listed.

5.11.2 Framing

Electric heater frame and control box shall be fabricated from heavy gauge aluminized steel. Frames shall have 40 mm. flanges with pre-drilled holes designed for mounting between flanged sections of ductwork. Control box shall be hinged, solid cover type. Fibreglass insulation, 15 mm, thick and 48 kg per cubic meter density shall be provided between the heating coil and control box for condensation protection. Stainless steel hardware shall be provided for corrosion resistance.

5.11.3 Heater Element

Elements shall be finned tubular type having copper plated steel fins brazed to copper plated steel sheath. Terminals shall be sealed with silicone rubber to protect against moisture. The heating element shall be rated for 415 Volts AC, 3-Phase, 50 Hertz. Control circuit voltage shall be derived by the Vendor from the main 415 Volts AC, 3 phase, 50 hertz supply. Resistance element shall be 80% nickel, 20% chromium, Type A, wire. Heating element shall be SCR controlled.

COPYRIGHT AND CONFIDENTIAL

**The information on this document is the property of Bharat Heavy Electricals Limited.
It must not be used directly or indirectly in anyway detrimental to the interest to the
company**

 <p>बी एच ई एल BHEL CBU - EPD</p>	<p>PURCHASE SPECIFICATION Industrial Air Conditioning Unit for Process Area</p>	Spec. No	EP:PVM:EQS:10
		Rev. No	00
		Page 23 of 35	

5.11.4 Terminal Box and Safety Devices

Terminal box shall be provided with solid cover to minimize dust infiltration and shall be hinged interlocking disconnect switches shall be provided. Heater terminal box shall be totally enclosed without perforated louvers or grills. All factory wiring shall be rated at 105°C and 600 V. Main supply terminals shall be provided for copper supply wires. Built-in components shall include disconnecting break magnetic three pole contactors, door interlock switch, 100 percent step less modulation SCR solid state controller, pressure-type airflow switch, branch circuit fusing, “power on” pilot light, and single terminal block to accept the number, type and size of conductors as shown on the electrical power supply drawings. Safety devices shall be a linear limit automatic reset thermal cut-out for primary over temperature protection and a secondary linear limit cut outs with manually reset in the power lines to de-energize elements if the primary cut-out fails. All safety devices shall be serviceable through terminal box without removing heater frame from duct. The heater controls shall be arranged so that the heating elements cannot be energized when minimum air flow through the heater does not exist.

5.12 Humidifier

5.12.1 General

Humidifier Units shall be self-contained manufactured package, cabinet type, electric evaporative, consisting of disposable steam cylinders, fill and drain assembly and associated controls.

Unit shall be provided with steam dispersion system complete with vapour hose, condensate drain tubes and accessories.

Unit shall be provided with mounting supports and suitable for 415 Volts, 3-Phase, 50 Hertz power supply.

The humidifier cabinet shall be constructed of sheet steel with baked enamel finish. Cabinet shall have a hinged and locked access door on the electrical compartment and a separate removable and lockable access door on the cylinder compartment. The cabinet shall contain the steam cylinder, fill and drain assembly and the electric / control compartment.

5.12.2 Steam Cylinders

The Steam Generating Cylinders shall be disposable plastic containers complete with grid type electrodes, sensing probes, quick change fittings for steam, electrical and fill / drain connections. The sensing probes shall detect water level and actuate safety control circuit as necessary.

5.12.3 Fill and Drain Assembly

The Fill and Drain Assembly shall consist of solenoid valves, one for fill and one for drain and fill cup with air gap between the fill pipe and cup. The Fill Solenoid Valve shall have a built-in strainer and flow regulating orifice. The Fill and Drain assembly shall provide automatic refill, low water cut-off functions and automatic drain / flush sequence.

COPYRIGHT AND CONFIDENTIAL

**The information on this document is the property of Bharat Heavy Electricals Limited.
It must not be used directly or indirectly in anyway detrimental to the interest to the
company**

 <p>बी एच ई एल CBU - EPD</p>	<p>PURCHASE SPECIFICATION Industrial Air Conditioning Unit for Process Area</p>	Spec. No	EP:PVM:EQS:10
		Rev. No	00
		Page 24 of 35	

5.12.4 Electrical and Control Devices

Electrical and control devices shall be provided and mounted on a sub-panel within the enclosure. Control devices shall include solid state control system, magnetic contactor for each heater, fuse for heating elements, control circuit transformer, numbered terminal strips and other devices.

The solid state control system shall provide the following functions as a minimum:

- Monitor water conductivity in the cylinder.
- Automatic filling / draining system in order to maintain the desired water conductivity
- Control the steam generation by the room humidistat. The steam output capacity shall be adjustable from 20 to 100 percent.
- Prevent overfilling of the cylinder to keep water from entering the steam supply outlet and energize the safety control circuit

5.12.5 Steam Dispersion System

The Steam Dispersion Device shall consist of steam discharge manifold / separator and dispersion tubes. The steam discharge manifold shall span the width of the duct, constructed of stainless steel tube and fitted with connections for dispersion tubes. The dispersion tube shall extend the height of the duct and fitted with two rows of tubelets centered on the diametric line and spaced at 1-1/2" apart or as recommended by manufacturer. The tubelets shall be made of non-metallic material designed for steam temperatures and shall extend through the wall of and into the center of dispersion tubes and incorporate a properly sized calibrated orifice. The Steam Discharge Manifold / Separator shall be provided with a return leg to remove the condensate from the manifold. The Steam Dispersion Unit shall be furnished complete with steam supply hoses and condensate return hoses. The steam supply hoses shall be covered with a braided reinforcing jacket.

5.13 Diffusers/Grilles


Supply air diffusers/grilles shall be suitable for the room they serve in terms of aesthetics, airflow pattern, volume flow rate, noise generation and distance of throw of air. They shall be selected to meet requirements over the full range of airflow temperatures and room temperatures, which are designed in each case

5.14 Refrigerants

No CFC and HCFC refrigerants shall be used in air conditioning or cooling equipment. The HFC chlorine free refrigerant R 134a shall be considered for air conditioning equipment.

COPYRIGHT AND CONFIDENTIAL

**The information on this document is the property of Bharat Heavy Electricals Limited.
It must not be used directly or indirectly in anyway detrimental to the interest to the
company**

 <p>बी एच ई एल BHEL CBU - EPD</p>	<p>PURCHASE SPECIFICATION Industrial Air Conditioning Unit for Process Area</p>	Spec. No	EP:PVM:EQS:10
		Rev. No	00
		Page 25 of 35	

5.15 HVAC control system

5.15.1 General Requirements

Standalone Microprocessor Based Control System and Panel shall be used for the HVAC system at Substation building. The control panel shall perform functions dedicated to HVAC equipment safety, operator assistance in the starting and stopping the associated equipment, and for preventing incorrect operation of the HVAC equipment as a clustered system. The Control system unit shall be capable of performing but not limited to the following:

- a. Start/Stop optimization
- b. Time of day scheduling supply air temperature reset
- c. Control signals that direct operate dampers and motors
- d. Until load monitoring
- e. Emergency shutdown
- f. Reset after any failure

HVAC Control Panel vendor's proposal to include full details including bill of materials and wiring diagrams. HVAC control panel vendor to design and propose suitable arrangement to achieve the following:

Each unit shall be capable of providing auto changeover control on hour's run and unit failure basis. HVAC system in rooms or building protected by fire and gas alarm panel shall shutdown when the fire protection operates.

The HVAC Control System panel shall be designed as a fail-safe system, with outputs failing to a fail-safe state. Hardwired switches, Sensors and Transmitters shall be hardwired to the HVAC Control System panel. The system includes Micro Processor based hardware/software I/O modules, communication modules, memory, etc. It has a PID capability to control all HVAC equipment functions. Fully independent and separate from any other system. The system shall be composed of standard, "off-the-shelf" hardware, firmware, and software products that can be configured to meet the stated requirements.

The Control Panel shall be of modular, integrated, and configurable accepting future expansion or replacement hardware and software. It also shall provide spare I/O modules. The HVAC Control System hardware shall include provisions for on-board self-memory back up. Memory back-up methods shall include battery backup memory. The HVAC Control System Panel hardware shall include protection from radio frequency and electrical interference such that the presence of such interference will not cause processor, logic, or memory corruption and will not damage Hardware components and Software as well. Signal transmission shall be designed to protect the

COPYRIGHT AND CONFIDENTIAL

The information on this document is the property of Bharat Heavy Electricals Limited. It must not be used directly or indirectly in anyway detrimental to the interest to the company

 <p>CBU - EPD</p>	<p>PURCHASE SPECIFICATION Industrial Air Conditioning Unit for Process Area</p>	Spec. No	EP:PVM:EQS:10
		Rev. No	00
		Page 26 of 35	

integrity of instrument signals from electrical noise brought about by electro-magnetic induction, electrostatic or capacitive coupling, and electrical conduction.

HVAC Control System design shall have provision to transmit alarms signals to DCS for monitoring of the HVAC units in case of a general failure, High temperature alarms in order to monitor the status. The CONTRACTOR shall Design, Engineering, supply and install the required HVAC Unit and Control's system etc. The CONTRACTOR shall review and receive COMPANY approval of HVAC instrumentation's and control's interface with the plants supervisory system design prior to installation.

5.15.2 Cabinet Requirements

The HVAC Control System Panel cabinet shall be suitable for indoor installation and shall be rigid metal construction, wall mounted cabinet, with hardware and accessories completely wired. The IP class for the HVAC control panel shall be IP41.

HVAC Control Panel hardware shall be housed in an air-conditioned HVAC building. All instruments located in these cabinets shall be capable of operating at an ambient temperature of 50°C maximum in the event of air conditioning failure. The cabinets shall be designed for top or bottom entry of cables. A drawing holder (pocket) shall be mounted on Control Panel door.

Terminations


Terminals for power distribution and for incoming and outgoing cables shall be located so that they are easily accessible. Adequate space and/or barriers shall be provided to prevent touching the microprocessor or other electronic hardware when working at terminal strips for field cables and power distribution wiring. Cabinet terminal strips for incoming and outgoing field cables shall be properly tagged.

Wiring and Cabling

Wiring shall be pre-assembled, cut to length, terminated, and tagged ready for site installation. All spare I/O, including spare cards, shall be terminated at both ends. Wiring between the field side rail and termination assemblies shall be furnished and shall be run via suitable slotted raceways, which permit easy modification at site. Wire markers shall be provided on both ends and shall include source / loop / destination tags. The shield drain wire on the ungrounded end of a cable shall be cut and taped to prevent unintentional grounding. Facilities shall be provided for the grounding of cable armors and signal screens, etc. as required by the instrument grounding system. Except for co-axial cables, instrument cable shields shall never be used or considered as signal conductors. Tie-wrap edges shall not be sharp. Tie-wraps shall not be used to mount equipment. Manufacturer's recommendations for cable bending radius shall not be exceeded.

COPYRIGHT AND CONFIDENTIAL

**The information on this document is the property of Bharat Heavy Electricals Limited.
It must not be used directly or indirectly in anyway detrimental to the interest to the company**

 <p>बी एच ई एल CBU - EPD</p>	<p>PURCHASE SPECIFICATION Industrial Air Conditioning Unit for Process Area</p>	Spec. No	EP:PVM:EQS:10
		Rev. No	00
		Page 27 of 35	

5.15.3 New Field Instruments

The HVAC Control System and Panel vendor in accordance with project specifications shall provide new Field Instruments. The field-mounted instruments shall be suitable for operation under the outdoor design conditions mentioned in clause 5.0 of this document. Instrument components shall be of materials that are compatible with the media being handled as well as with the environmental air pollutants present where the instruments are installed. The instruments shall be of the solid state; electronic type designed to suit the particular needs of the HVAC Control Panel. They shall not be susceptible to nearby sources of spurious signals. Enclosures shall meet the requirements of the electrical area classification of their locations in accordance with the latest standards.

5.15.4 Sensors and Transmitters

- a) Sensors (general): All temperature sensors shall be of two-wire thermistor type, with a resistance of [3K, 10K] ohms at 74 degrees F.
- b) Space sensors: Shall have a finished decorative cover, with set point adjustment (limited through software), and override button.
- c) Duct Sensors: Shall be of the insertion type, with a length no shorter than 8 inches for duct widths up to 24 inches, no shorter than 12 inches for duct widths up to 36 inches, and no shorter than 18 inches for duct widths larger than 36 inches.
- d) Transmitters: All variables not capable of being measured by passive devices are to be measured by transmitters. This includes pressure and relative humidity. Signals generated by transmitters shall be [1-5 VDC, 2-10 VDC, 4-20 mA HART type].

Humidity Sensor: It shall be installed in the common return air duct. It will send a signal to the HVAC control system panel when the RH is lower than 40% and higher than 60%.

5.15.5 Switches

- a) High Limit Static Pressure Switches: Shall be of the manual reset, diaphragm type
- b) Differential Pressure Switches: Shall be used where practical, for status indication, in lieu of pressure sensing switches.
- c) Air Pressure Switches (for static differential pressure applications): Shall be diaphragm type pressure switches
- d) Clogged Filter Switches: Shall be diaphragm type pressure switches.

5.15.6 End Devices

- a) Damper Actuator: Shall be of the direct mount type, suitably sized for the dampers they serve. They shall require 240-Volt AC power, and unless two-position control is explicitly specified, shall be able to accept a proportional control signal of 0-10 or 2-10 VDC. Unless otherwise specified, they shall be spring-return.
- b) Control Dampers: Shall be duct size if two position, and sized for the appropriate pressure drop

COPYRIGHT AND CONFIDENTIAL

**The information on this document is the property of Bharat Heavy Electricals Limited.
It must not be used directly or indirectly in anyway detrimental to the interest to the
company**

 <p>बी एच ई एल CBU - EPD</p>	<p>PURCHASE SPECIFICATION Industrial Air Conditioning Unit for Process Area</p>	Spec. No	EP:PVM:EQS:10
		Rev. No	00
		Page 28 of 35	

if modulating. All control dampers shall be low leakage type. Dampers used in modulating applications shall be of the opposed blade type

c) Zone Damper Actuators: Shall be of the direct mount type, shall require 24-volt AC power, and shall be able to accept either a proportional or floating type control signal. The application shall dictate whether or not they will be spring-return.

5.15.7 Miscellaneous Devices

a) Control Enclosures: Shall be NEMA 3 (indoor, general use), or NEMA 7 (outdoor use) with perforated mounting panels and hinged doors.

b) Relay and Contactors: Shall be suitable for the loads that they handle

c) Control Transformers and Power Supplies: Shall be UL listed, 24-volt, Class 2 current limiting type, or shall have fusing on both the primary and secondary sides

Transducers: Shall be utilized where there is a need to convert one type of control signal to another. An example of this is an electronic-to-pneumatic transducer, which can take a 2-10 VDC or 4-20 mA electronic control signal, and convert it to a 3-15 psi pneumatic control signal, for modulation of a pneumatic actuator.

5.16 Electric power supply

BHEL will provide power supply at a single point in the control room, design, supply and laying of cable from this point in distribution board to condensing units. Further distribution to the HVAC equipment shall be under the scope of HVAC Vendor. Independent HVAC electrical panel to power and control the individual HVAC units shall be provided by the vendor for connection to the site electrical system. The panel shall be positioned in the HVAC plant room or in the room where HVAC equipment are positioned. A local isolator shall be provided adjacent to each item of equipment. All externally mounted air conditioning equipment shall contain all necessary starters, motor protection and, automatic controls. The power supply to the HVAC Control Panel for the air conditioning system shall be furnished from 240V AC/1-Phase/50Hz power source, which are over-current protected. The HVAC Control Panel shall include a 24V DC power supplies to drive local lamps, powering transmitters and for any other 24V DC requirements. This power has to be derived internally. The HVAC Control Panel shall also include power supplies to drive the motorized dampers and for any other requirements. All system cabinet power supply main and branched circuit breakers shall be properly arranged and clearly tagged inside the cabinet.

COPYRIGHT AND CONFIDENTIAL

The information on this document is the property of Bharat Heavy Electricals Limited. It must not be used directly or indirectly in anyway detrimental to the interest to the company

 <p>बी एच ई एल CBU - EPD</p>	<p>PURCHASE SPECIFICATION Industrial Air Conditioning Unit for Process Area</p>	Spec. No	EP:PVM:EQS:10
		Rev. No	00
		Page 29 of 35	

6.0 INSTALLATION, TESTING, COMMISSIONING AND ACCEPTANCE TEST

6.1 Installation

Equipment and components shall be completely installed to insure proper and sequential operation of the equipment and its controls. Install all HVAC equipment, such as air handling units, air cooled condensing units, ductwork, controls, according to the manufacturer's written instructions. Arrange installation of units to provide access space around air handling units, air cooled condensing units for service and maintenance. Install suspended and/or wall mounted units in accordance with manufacturer's and SMACNA requirements.

Provide Software programming, Factory Acceptance Test (FAT), Site Acceptance Test (SAT), Site Inspection Test (SIT), training and all other related activities.

6.2 Testing & Commissioning

The system shall be tested and commissioned by fully experienced crew having previous experience in the installation of this type of systems. The systems shall be installed in strict accordance with the Manufacturer's recommendations.

The Testing and Balancing work shall comply fully with procedural standards adopted.

6.3 Traceability

Materials and Equipment shall be traceable against Purchase Order No., Purchase Order Item No., and Tag No, when applicable. The Certification to cover components, raw materials, and parts shall be fully identifiable and traceable against Part No., Tag No., and Purchase Order Item No. and Purchase Order No. wherever applicable

7.0 Quality Assurance /Quality Control


The contractor shall have in effect at all times, a QA/QC program which clearly establishes the authority and responsibilities of those responsible for the quality system. People performing quality functions shall have sufficient and well defined authority to enforce quality requirements, initiate, identify, recommend and provide solutions to quality problems and verify the effectiveness of the corrective action.

7.1 Vendor

VENDOR shall comply with the requirements as stated in the ISO 9001:2000, for maintaining comprehensive quality control over all aspects of design and manufacture of the equipment.

COPYRIGHT AND CONFIDENTIAL

**The information on this document is the property of Bharat Heavy Electricals Limited.
It must not be used directly or indirectly in anyway detrimental to the interest to the
company**

 <p>बी एच ई एल CBU - EPD</p>	<p>PURCHASE SPECIFICATION Industrial Air Conditioning Unit for Process Area</p>	Spec. No	EP:PVM:EQS:10
		Rev. No	00
		Page 30 of 35	

8.0 Painting

Surface preparation, painting, coating and the color number shall be in accordance with relevant standards. Vendor may offer his standard painting system as an option; however this is subject to BHEL approval. Vendor to indicate complete details of his standard, including surface finish, paint specification including full details of each coat material and thickness and application.

Vendor shall paint the equipment and materials within his scope of supply, which shall be done at Vendor facilities to the maximum extent possible. Applied painting procedures shall be suitable for a marine environment. Paint materials to be used shall be suitable for the maximum operating temperature.

Paint quality inspection reports shall be provided by the Vendor for all painting executed in his facilities or those of Sub-Vendors. These reports shall be provided with the manuals and shall be used for finishing all paint work to be done at site.

Touch-up painting of surfaces in the field, shall be done by others after completion of the installation. Vendor shall submit procedure for repair of painting/coating at site.

9.0 Vendor drawings and documentation

Vendor shall submit drawings and documentation as per Supplier Data

Requirements

Calculations:

Calculations shall be complete, neatly bound and indexed for submittal to the BHEL in the techno-commercial bid for review and approval at each phase of design required.

Design conditions, building "U" factors, and other basis of calculations shall be clearly shown on the lead sheet of the calculations.

Drawings:

- a. Each drawing shall be provided with a title block in the bottom right-hand corner incorporating the following information:
 - Official trade name of the COMPANY
 - Fabricator's drawing number
 - Drawing title giving the description of the contents whereby the drawing can be identified
 - A symbol or letter indicating the latest issue or revision
- b. The drawings shall indicate the required size and general arrangement for all equipment and

COPYRIGHT AND CONFIDENTIAL

**The information on this document is the property of Bharat Heavy Electricals Limited.
It must not be used directly or indirectly in anyway detrimental to the interest to the
company**

 <p>CBU - EPD</p>	<p>PURCHASE SPECIFICATION Industrial Air Conditioning Unit for Process Area</p>	Spec. No	EP:PVM:EQS:10
		Rev. No	00
		Page 31 of 35	

components, all laid out to scale using the most current architectural drawing building plans as the background for the HVAC plans.

- c. All equipment shall be identified by unique equipment tag numbers
- d. Routing of ducting and/or any other part of the installation shall be coordinated with the designs of other trades. The design of all ductwork, piping and other parts of the installation shall be arranged accordingly.
- e. Routing of ductwork shall be shown in double line format, and piping may be shown as a single line.
- f. Detailed sections and enlarged plans shall be used where required to provide a complete, constructible set of drawings.

The Subcontractor/Vendor shall submit drawings, specifications, materials and equipment data, shop drawings, manuals, reports, and all other items required in the format and quantities required at milestones designated by the contract documents:

- a. Shop Drawings. The Subcontractor shall prepare any supplementary (shop) drawings required for clarifying details regarding shop fabrication or field installations
- b. Submittals of Material and Equipment Data Submittal shall be made of each type of material and equipment to be used.
- c. Operating and Maintenance Manuals Submit operating instructions for each system including step-by-step preparation for starting, normal operation, and stopping, and instructions for maintaining the equipment items. These shall be bound with an index sheet and shall contain wiring and control diagrams, written sequence of operation, spare parts list, and manufacturer's catalogue information of equipment items.

d. As-Built Drawings

Record as-built drawings shall be submitted in accordance with the contract and this specification. Final drawings shall be made available in digital format in AUTOCAD. Any P&ID/PFD for this project shall be developed in SMART PLANT. Additional documents to be submitted by Vendor shall include the following information as a minimum:

- a. Completed data sheets
- b. General arrangement drawings of all equipment.
- c. Schedules and drawings of electrical, instrument and mechanical termination points.
- d. Equipment layout and support details.
- e. Equipment Support Schedule, Isometrics as applicable.
- f. Foundation design data.
- g. Control wiring, Schematic and connection diagrams of main, control, status indication, alarm,

COPYRIGHT AND CONFIDENTIAL

The information on this document is the property of Bharat Heavy Electricals Limited. It must not be used directly or indirectly in anyway detrimental to the interest to the company

 <p>CBU - EPD</p>	<p>PURCHASE SPECIFICATION Industrial Air Conditioning Unit for Process Area</p>	Spec. No	EP:PVM:EQS:10
		Rev. No	00
		Page 32 of 35	

metering, protection, trip, shut down and auxiliary circuits.

h. Material specifications.

i. Equipment list.

j. Recommended spare parts.

k. Test and inspection procedures.

l. Manufacturing data reports, incorporating all verified documents of all tests and inspections performed.

m. Operating and maintenance manuals, incorporating unpacking, de-preservation, installation, commissioning, operating and maintenance instructions and fault finding procedures.

n. Manufacturer's proposed service and repair support after warranty.

o. FDS for control panel I/O list, GA/BOQ/wiring drawing, ITP FOR FAT/SAT/SIT cause and effect. Operation and control philosophy and all other relevant documents, as required.

The Subcontractor/Vendor shall submit documents and quantity of drawings for CONTRACTOR'S authorization or information as listed in the individual Material Requisition and Purchase Orders. Mutual agreement on scheduled submittal of drawings and engineering data shall be integral part of any formal Purchase Order.

Comments made by the CONTRACTOR on the drawings submittal shall not relieve the Subcontractor or Vendor of any responsibility in meeting the requirements of the Project Specifications. Such comments shall not be construed as permission to deviate from requirements of the Purchase Order unless specific and mutual agreement is reached and confirmed in writing.

10.0 SCOPE OF WORK:

The scope of work under this section shall apply to HVAC systems for the Solar PV Module Manufacturing Shop as mentioned and broadly but not limited includes:

Engineering and design of the HVAC system

- a. Design calculations
- b. Construction drawings
- c. Construction specifications & work procedure

Supply and installation of the HVAC system

- a. HVAC equipment and materials including control systems
- b. Shop drawings of equipment and installations
- c. Complete installation of HVAC systems
- d. Provide all work and materials for the complete installation of automatic temperature control system
- e. Complete testing and balancing of HVAC systems

COPYRIGHT AND CONFIDENTIAL

**The information on this document is the property of Bharat Heavy Electricals Limited.
It must not be used directly or indirectly in anyway detrimental to the interest to the
company**

 <p>CBU - EPD</p>	<p>PURCHASE SPECIFICATION Industrial Air Conditioning Unit for Process Area</p>	Spec. No	EP:PVM:EQS:10
		Rev. No	00
		Page 33 of 35	

- f. Startup of the HVAC systems
- g. Warranty of HVAC systems after acceptance
- h. Test and inspection reports
- i. Operation and maintenance manuals
- j. As-built drawings
- k. Spare Parts and Special Tools


11.0 WARRANTY

- a. Vendor shall be fully responsible for all equipment supplied including bought out items. All the equipment shall be fully guaranteed for a period of Twelve (12) months from the date of installation & Commissioning and Provisional Acceptance Certificate. The Vendor shall provide all Certification for the equipment and shall ensure that dimensional compatibility, shaft system critical speeds, vibration, noise levels and acceptability of pipe loads are within the relevant specification limits. Provision of all data necessary for the design of lifting equipment, support and structures is required.
- b. In the event that the equipment is rectified or replaced by the Vendor under the provisions of this article, the warranty period shall be extended for a period of Twelve (12) months following the satisfactory completion of the rectification or replacement of the equipment.
- c. The VENDOR shall confirm in writing that the design and construction of the HVAC system comply with the statutes, local regulations, etc.
- d. The VENDOR shall provide performance guarantee for all equipment including auxiliary items. This guarantee shall include also efficiency guarantee and a guarantee at design load. The following conditions shall be met as part of guarantee:
 - Each design is guaranteed to meet the process duty stated within the data sheets. The equipment supplied shall be suitable for continuous operation at any of the range of performance conditions stipulated.
 - Any equipment that does not meet the design performance requirements shall be modified by VENDOR at the VENDOR's expense.

Factory Acceptance Test (FAT) on all major equipment and systems shall be conducted. COMPANY representative may witness Factory Acceptance Test (FAT). Site Acceptance Test (SAT) and Site Installation Test (SIT) shall be conducted by the VENDOR and witnessed by BHEL.

COPYRIGHT AND CONFIDENTIAL

The information on this document is the property of Bharat Heavy Electricals Limited. It must not be used directly or indirectly in anyway detrimental to the interest to the company

 <p>बी एच ई एल CBU - EPD</p>	<p>PURCHASE SPECIFICATION Industrial Air Conditioning Unit for Process Area</p>	Spec. No	EP:PVM:EQS:10
		Rev. No	00
		Page 34 of 35	

12.0 SPARE PARTS

The following definitions with regard to spare parts shall be used:

- a. Construction, Pre-commissioning and Commissioning spare parts: These spare parts are required to prepare the equipment ready for start-up.
- b. 2 years operation spare parts: Spare parts for normal operation should adequately cover the requirements of the day to day maintenance for a period of Two years following the initial start-up.
- c. Insurance spare parts: Those parts of equipment, equipment assemblies or complete items of equipment that are required for replacement of items not subject to deterioration by normal use, but failure of which is really critical for continuous operation of the plant. Vendor shall provide a list of recommended spare parts

13.0 SPECIAL TOOLS

All special tools that are required for the installation, commissioning, operation and maintenance of HVAC Equipment Package shall be provided by the Vendor with a detailed list. This shall include any special lifting facilities for the entire package and each major subcomponent of the package.

14.0 PERFORMANCE GUARANTEE

In order to determine compliance of the SYSTEM with the performance requirements set forth in this specification, a performance test shall be carried out for a period of three (3) consecutive days. Should any of the performance tests as described above be deemed unsuccessful, the VENDOR shall, at its own cost, make any and all the modifications required to achieve a successful test.

Once all three performance tests are successful, the BHEL shall issue a Final Acceptance letter to the Vendor.

COPYRIGHT AND CONFIDENTIAL

**The information on this document is the property of Bharat Heavy Electricals Limited.
It must not be used directly or indirectly in anyway detrimental to the interest to the
company**

 <p>बी एच ई एल CBU - EPD</p>	<p>PURCHASE SPECIFICATION Industrial Air Conditioning Unit for Process Area</p>	Spec. No	EP:PVM:EQS:10
		Rev. No	00
		Page 35 of 35	

15.0 PRE-QUALIFICATION CRITERION

1. The vendor shall be an Original Equipment Manufacturer (OEM). Only the OEM or their authorized dealers along with an authorization letter can participate in the tender. An authorized Representative/Dealer cannot quote for the same equipment from more than one OEM.
2. Offer shall be for new equipment and not for any refurbished / used equipment. All the parts used in the machine shall also be new and not used / refurbished ones. A declaration to the above effect to be furnished.
3. The vendor should have already supplied and installed a minimum of 3 nos. of similar kind of industrial or large commercial establishment air-conditioning system in India during the past 3 years and these must be operating satisfactorily. The details of the customers with contact details date of installations etc. to be provided. BHEL reserves the right for independent verification of the references provided.
4. The vendor or their authorized service representatives shall have trained engineers for commissioning & service for the offered equipment and shall be in a position to provide prompt after sales service and spares support for our installations in Bengaluru.
5. The vendor shall be in a position to provide service support for the equipment supplied, after the expiry of the warranty/ guarantee period either directly or through a service representative.

Note:

1. Pre-qualification will be carried out based on the details furnished by the vendor / feedback from their customers / inspection of the company / product if required by BHEL and at its sole discretion.
2. The Pre-qualification criteria are mandatory requirements and the technical bids will be evaluated only when the Pre-Qualification criteria are met.

COPYRIGHT AND CONFIDENTIAL

The information on this document is the property of Bharat Heavy Electricals Limited. It must not be used directly or indirectly in anyway detrimental to the interest to the company