

BHEL PEM-ELECTRICAL

**PRE-QUALIFYING REQUIREMENTS FOR TREFOIL CLAMPS
DOC. NO. PE-PQ-999-507-E005, REV. 0**

ITEMS : Trefoil clamps
Vendor may be considered for evaluation for either or both type of trefoil clamps :
Type 1 – Nylon-6 material
Type 2 – Aluminium alloy

SCOPE:

Supply : YES; Erection & Commissioning : NO;

A) GENERAL CRITERIA FOR EVALUATION

1. Vendor has his own facility for manufacturing applicable type of trefoil clamps:
 - a) Nylon-6 material
 - b) Aluminium alloy
2. Trefoil clamps for single core cable of overall dia. of upto 60mm should be in vendor's range of manufacturing.
3. Manufacturing capacity shall be about 20000 nos. per month for the applicable type of trefoil clamps.
4. Availability of applicable routine and type test certificates (for 125kA peak or above) for the applicable type of trefoil clamps.
- 5a. Experience certificates for minimum 2 years of trouble free operation from minimum 2 different end users from power plant/ process plant/ refinery for the applicable type of trefoil clamps.

OR
- 5b. Repeat order received from 2 different end users for the applicable type of trefoil clamps during last 5 years provided the gap between award of two PO's is minimum 3 years.

OR
- 5c. 1 no. experience certificate (as per sl. no. 5a) and 1 no. repeat order (as per sl. no. 5b).

OR
- 5d. Successful execution of a major order (i.e. supply of at least 10000 nos. of trefoil clamps) for NTPC EOC, Noida/ EIL/ NPCIL for the applicable type of trefoil clamps.

Notes :

- i. Vendor(s) not registered with BHEL-PEM Noida for the applicable type of 'Trefoil clamps' shall submit relevant documents in support of above mentioned General Criteria.

[Signature]
31/03/14

[Signature]
31/3/14

[Signature]
31/3/14

[Signature]
31/3/14

[Signature]
31.03.14


BHEL PEM-ELECTRICAL

PRE-QUALIFYING REQUIREMENTS FOR TREFOIL CLAMPS DOC. NO. PE-PQ-999-507-E005, REV. 0


- ii. For registration of additional works by a vendor already registered with BHEL-PEM Noida for the applicable type of 'Trefoil clamps', vendor shall submit relevant documents in support of sl. no. 1, 2 & 3 of the above mentioned General Criteria for the proposed additional works.

B) PROJECT SPECIFIC CRITERIA AGAINST ENQUIRY


1. Bidder(s) already registered with BHEL-PEM Noida for the applicable type of 'Trefoil clamps' need not submit credentials for General Criteria indicated above.
2. After satisfactory fulfilment of all the above criteria/ requirement, offer shall be considered for further evaluation as per NIT and all the other terms of the tender.
3. Consideration of offer will be subject to customer's approval of bidder (if applicable).
4. Any other project specific requirement shall be as per Annexure-I and bidder shall submit relevant supporting documents.


31/03/14

AK Rawat
[Technical Convenor]


31/3/14


SK Gurumukhi
[SH-E02]


31/3/14

Rajnish Goyal
[SH-E03]


31/3/14

Anuj Kumar
[SH-E01]


31.03.14


Meena Kesri
[DH-Electrical]


BHEL PEM-ELECTRICAL
PRE-QUALIFYING REQUIREMENTS FOR TREFOIL CLAMPS
DOC. NO. PE-PQ-999-507-E005, REV. 0

ANNEXURE – I

PROJECT SPECIFIC CRITERIA AGAINST ENQUIRY

- NIL -


26/05/14
[Section Head]


26.5.14
[DH-Electrical]