	POWER SECTOR-PEM NOIDA	PACKAGE: COMPRESSED AIR SYSTEM	
	TECHNICAL PRE-QUALIFICATION REQUIREMENTS (FOR OPEN/GLOBAL TENDERS/REGISTRATION) To be read in conjunction with PEM general PQR	DEPARTMENT : MECHANICAL AUXILIARY PROJECT-370 MW (109 FB) CCPP YELAHANKA	
	Sheet no 1 of 2	Rev 00	Dt: 20.01.2016

The following technical details are required from bidder to comply technical PQR:

Oil free Screw machines - minimum capacity of 10 Nm³/min with min discharge pressure of 7.5 kg/sqcm (g). Vendor should be OEM.

Supplier should have designing/manufacturing capability and having testing facility (in house or outsourced).

Compressed air system should have been successfully in use for at least one year as on date of bid submission in power plant or other industries e.g. refinery / steel / process / commercial etc. For this the supplier has to submit either of following supporting documents meeting below mentioned conditions

i) Copy of minimum one (1) performance certificate in English from end user along with copy of related Purchase Order specifying that the product is running successfully for one (1) year from date of commissioning.


OR

ii) Minimum one second/repeat purchase order (placed with a minimum gap of one (1) year after commissioning of first order) from same purchaser meeting the minimum pre-qualifying requirement.

OR

iii) Minimum three purchase orders (placed with minimum gap of one (1) year from previous purchase order) from same purchaser meeting the minimum pre-qualifying requirement.

PREPARED BY			CHECKED & REVIEWED BY			APPROVED BY		
Mausam kumar	<i>Mausam kumar</i>	25/01/16	Sayan Roy/Harish kumar	<i>Sayan Roy</i>	25/01/2016	Praveen Kishore	<i>Praveen Kishore</i>	25/01/2016
NAME	SIGNATURE	DATE	NAME	SIGNATURE	DATE	NAME	SIGNATURE	DATE




	POWER SECTOR-PEM NOIDA TECHNICAL PRE-QUALIFICATION REQUIREMENTS (FOR OPEN/GLOBAL TENDERS/REGISTRATION) To be read in conjunction with PEM general PQR	PACKAGE: COMPRESSED AIR SYSTEM DEPARTMENT : MECHANICAL AUXILIARY PROJECT-370 MW (109 FB) CAPP YELAHANKA	
	Sheet no 2 of 2	Rev 00	Dt: 20.01.2016

Note:

- i) Vendor shall submit design documents to substantiate technical parameters specified in PQR, if the same is not mentioned in performance certificate/purchase order.
- ii) Minimum two (2) nos. Purchase orders shall be submitted which should not be more than ten (10) years old as on date of bid submission, for establishing continuity in business.
- iii) Vendor may also qualify based on the credential of principal meeting package specific pre-qualifying requirements having technical valid collaboration/licensing agreement.
- iv) In case documents submitted for meeting PQR are in language other than English, notarized English translation shall also be submitted.

General:

- 1) PEM registered vendors are also required to submit the credentials to meet the PQR.
- 2) Notwithstanding anything stated above, BHEL reserves the right to assess the capabilities and capacity of the bidder/collaborators to perform the contract, as per BHEL evaluation procedure, should the circumstances warrant such assessment in the overall interest of BHEL.
- 3) Final acceptance of Bidder is subject to End Customer's approval.

PREPARED BY			CHECKED & REVIEWED BY			APPROVED BY		
Mausam kumar		25/01/16	Sayan Roy/Harish kumar		25/01/2016	Praveen Kishore		25/01/2016
NAME	SIGNATURE	DATE	NAME	SIGNATURE	DATE	NAME	SIGNATURE	DATE